# Occupational Analyses Series

# Construction Electrician

2011

Trades and Apprenticeship Division Division des métiers et de l'apprentissage

Workplace Partnerships Directorate Direction des partenariats en milieu de

travail

National Occupational Classification: 7241

Disponible en français sous le titre : Électricien/électricienne (construction)

You can order this publication by contacting:

Trades and Apprenticeship Division Workplace Partnership Directorate Human Resources and Skills Development Canada 140 Promenade du Portage, Phase IV, 5<sup>th</sup> Floor Gatineau, Quebec K1A 0J9

Online: www.red-seal.ca

This document is available on demand in alternative formats (Large Print, Braille, Audio Cassette, Audio CD, e-Text Diskette, e-Text CD, or DAISY) by contacting 1 800 O-Canada (1-800-622-6232). If you have a hearing or speech impairment and use a teletypewriter (TTY), call 1-800-926-9105.

© Her Majesty the Queen in Right of Canada, 2011

Paper

Cat. No.: HS42-1/21-2011E ISBN: 978-1-100-18516-3

**PDF** 

Cat. No.: HS42-1/21-2011E-PDF

ISBN: 978-1-100-18517-0

**FOREWORD** 

The Canadian Council of Directors of Apprenticeship (CCDA) recognizes this National Occupational Analysis as the national standard for the occupation of Construction Electrician.

#### Background

The first National Conference on Apprenticeship in Trades and Industries, held in Ottawa in 1952, recommended that the federal government be requested to cooperate with provincial and territorial apprenticeship committees and officials in preparing analyses of a number of skilled occupations. To this end, Human Resources and Skills Development Canada (HRSDC) sponsors a program, under the guidance of the CCDA, to develop a series of National Occupational Analyses (NOAs).

The NOAs have the following objectives:

- to describe and group the tasks performed by skilled workers;
- to identify which tasks are performed in every province and territory;
- to develop instruments for use in the preparation of Interprovincial Red Seal Examinations and curricula for training leading to the certification of skilled workers;
- to facilitate the mobility of apprentices and skilled workers in Canada; and,
- to supply employers, employees, associations, industries, training institutions and governments with analyses of occupations.

#### **ACKNOWLEDGEMENTS**

The CCDA and HRSDC wish to express sincere appreciation for the contribution of the many tradespersons, industrial establishments, professional associations, labour organizations, provincial and territorial government departments and agencies, and all others who contributed to this publication.

Special acknowledgement is extended by HRSDC and the CCDA to the following representatives from the trade.

Nick Barrowcliffe Ontario

Trent Chaytor Newfoundland and Labrador

Pat Coggar New Brunswick Michael Todd Holland Nova Scotia

Tony Lawlor International Brotherhood of Electrical Workers (IBEW)
Barnaby McHarg International Brotherhood of Electrical Workers (IBEW)

Ryan Moir Prince Edward Island

Andrew Paterson Manitoba Ryan Saunders Alberta

Merlin Trower Saskatchewan Monty Wood British Columbia

This analysis was prepared by the Workplace Partnerships Directorate of HRSDC. The coordinating, facilitating and processing of this analysis were undertaken by employees of the NOA development team of the Trades and Apprenticeship Division. Jacques Austin for the host jurisdiction of Saskatchewan also participated in the development of this NOA.

# TABLE OF CONTENTS

FOREWORD			I			
ACKNOWLEDGEMENTS						
TABLE OF CONTENTS						
LIST OF PUBL	ISHED NATION	JAL OCCUPATIONAL ANALYSES	V			
STRUCTURE C	OF ANALYSIS		VII			
DEVELOPMEN	NT AND VALID	ATION OF ANALYSIS	IX			
		ANALYSIS				
SAFETY			3			
SCOPE OF TH	E CONSTRUCT	ION ELECTRICIAN TRADE	4			
OCCUPATION	JAL OBSERVAT	TIONS	6			
ESSENTIAL SK	CILLS SUMMAR	XY	7			
BLOCK A	COMMON	N OCCUPATIONAL SKILLS				
	Task 1	Performs safety-related functions.	10			
	Task 2	Uses and maintains tools and equipment.	13			
	Task 3	Organizes work.	15			
	Task 4	Fabricates and installs support components.	19			
	Task 5	Commissions and decommissions electrical systems.	21			
BLOCK B	SYSTEMS	, DISTRIBUTION AND SERVICES				
	Task 6	Installs service entrance and distribution equipment.	23			
	Task 7	Installs bonding, grounding and cathodic protection systems.	30			
	Task 8	Installs power generation systems.	33			

	Task 9	Installs high voltage systems.	34						
	Task 10	Installs transformers.	37						
BLOCK C	WIRING M	WIRING METHODS							
	Task 11	Installs raceways and cables.	40						
	Task 12	Installs branch circuitry.	44						
	Task 13	Installs heating, ventilation and cooling (HVAC) systems.	47						
	Task 14	Installs emergency lighting systems.	49						
BLOCK D	MOTORS .	AND CONTROL SYSTEMS							
	Task 15	Installs motor controls and protection.	51						
	Task 16	Installs motors.	54						
BLOCK E	SIGNALLI	NG AND COMMUNICATION SYSTEMS							
	Task 17	Installs signalling systems.	57						
	Task 18	Installs communication systems.	59						
	Task 19	Installs integrated control systems.	61						
BLOCK F	UPGRADING, SERVICE AND MAINTENANCE								
	Task 20	Upgrades electrical systems.	64						
	Task 21	Services electrical systems.	66						
	Task 22	Maintains electrical systems.	67						
		APPENDICES							
APPENDIX A	TOOLS AN	ND EQUIPMENT	73						
APPENDIX B	GLOSSAR	Y	76						
APPENDIX C	ACRONYN	MS	78						
APPENDIX D	BLOCK AN	ND TASK WEIGHTING	80						
APPENDIX E	PIE CHAR	Т	84						
APPENDIX F TASK PROFILE CHART									

# LIST OF PUBLISHED NATIONAL OCCUPATIONAL ANALYSES (Red Seal Trades)

TITLE	NOC* Code
Agricultural Equipment Technician (2007)	7312
Appliance Service Technician (2011)	7332
Automotive Painter (2009)	7322
Automotive Service Technician (2009)	7321
Baker (2006)	6252
Boilermaker (2008)	7262
Bricklayer (2007)	7281
Cabinetmaker (2007)	7272
Carpenter (2010)	7271
Concrete Finisher (2006)	7282
Construction Craft Worker (2009)	7611
Construction Electrician (2011)	7241
Cook (2008)	6242
Electrical Rewind Mechanic (1999)	7333
Floorcovering Installer (2005)	7295
Glazier (2008)	7292
Hairstylist (2009)	6271
Heavy Duty Equipment Technician (2009)	7312
Industrial Electrician (2011)	7242
Industrial Mechanic (Millwright) (2009)	7311
Instrumentation and Control Technician (2010)	2243
Insulator (Heat and Frost) (2007)	7293
Ironworker (Generalist) (2010)	7264
Ironworker (Reinforcing) (2010)	7264
Ironworker (Structural/Ornamental) (2010)	7264
Landscape Horticulturist (2010)	2225
Lather (Interior Systems Mechanic) (2007)	7284

-

<sup>\*</sup> National Occupational Classification

TITLE	NOC* Code
Machinist (2010)	7231
Metal Fabricator (Fitter) (2008)	7263
Mobile Crane Operator (2009)	7371
Motorcycle Mechanic (2006)	7334
Motor Vehicle Body Repairer (Metal and Paint) (2010)	7322
Oil Heat Systems Technician (2006)	7331
Painter and Decorator (2007)	7294
Partsperson (2010)	1472
Plumber (2010)	7251
Powerline Technician (2009)	7244
Recreation Vehicle Service Technician (2006)	7383
Refrigeration and Air Conditioning Mechanic (2009)	7313
Rig Technician (2008)	8232
Roofer (2006)	7291
Sheet Metal Worker (2010)	7261
Sprinkler System Installer (2009)	7252
Steamfitter/Pipefitter (2010)	7252
Tilesetter (2010)	7283
Tool and Die Maker (2010)	7232
Transport Trailer Technician (2008)	7321
Truck and Transport Mechanic (2010)	7321
Welder (2009)	7265

#### Requests for printed copies of National Occupational Analyses may be forwarded to:

Trades and Apprenticeship Division Workplace Partnerships Directorate Human Resources and Skills Development Canada 140 Promenade du Portage, Phase IV, 5<sup>th</sup> Floor Gatineau, Quebec K1A 0J9

These publications can be ordered or downloaded online at: <u>www.red-seal.ca</u>.

## STRUCTURE OF ANALYSIS

To facilitate understanding of the occupation, the work performed by tradespersons is divided into the following categories:

**Blocks** the largest division within the analysis that is comprised of a

distinct set of trade activities

Tasks distinct actions that describe the activities within a block

**Sub-Tasks** distinct actions that describe the activities within a task

**Key Competencies** activities that a person should be able to do in order to be called

'competent' in the trade

The analysis also provides the following information:

**Trends** changes identified that impact or will impact the trade including

work practices, technological advances, and new materials and

equipment

**Related Components** a list of products, items, materials and other elements relevant to

the block

**Tools and Equipment** categories of tools and equipment used to perform all tasks in the

block; these tools and equipment are listed in Appendix A

**Context** information to clarify the intent and meaning of tasks

**Required Knowledge** the elements of knowledge that an individual must acquire to

adequately perform a task

The appendices located at the end of the analysis are described as follows:

Appendix A — Tools and Equipment	a non-exhaustive list of tools and equipment used in this trade
Appendix B — Glossary	definitions or explanations of selected technical terms used in the analysis
Appendix C — Acronyms	a list of acronyms used in the analysis with their full name
Appendix D — Block and Task Weighting	the block and task percentages submitted by each jurisdiction, and the national averages of these percentages; these national averages determine the number of questions for each block and task in the Interprovincial exam
Appendix E — Pie Chart	a graph which depicts the national percentages of exam questions assigned to blocks
Appendix F — Task Profile Chart	a chart which outlines graphically the blocks, tasks and sub-tasks of this analysis

# DEVELOPMENT AND VALIDATION OF ANALYSIS

#### **Development of Analysis**

A draft analysis is developed by a committee of industry experts in the field led by a team of facilitators from HRSDC. This draft analysis breaks down all the tasks performed in the occupation and describes the required knowledge and key competencies required for a tradesperson to demonstrate competence in the trade.

#### **Draft Review**

The National Occupational Analysis (NOA) development team then forwards a copy of the analysis and its translation to provincial and territorial authorities for a review of its content and structure. Their recommendations are assessed and incorporated into the analysis.

#### Validation and Weighting

The analysis is sent to all provinces and territories for validation and weighting. Participating jurisdictions consult with industry to validate and weight the document, examining the blocks, tasks and sub-tasks of the analysis as follows:

**BLOCKS** Each jurisdiction assigns a percentage of questions to each block for an

examination that would cover the entire trade.

**TASKS** Each jurisdiction assigns a percentage of exam questions to each task within

a block.

**SUB-TASKS** Each jurisdiction indicates, with a YES or a NO, whether or not each sub-task

is performed by skilled workers within the occupation in its jurisdiction.

The results of this exercise are submitted to the NOA development team who then analyzes the data and incorporates it into the document. The NOA provides the individual jurisdictional validation results as well as the national averages of all responses. The national averages for block and task weighting guide the Interprovincial Red Seal Examination plan for the trade.

This method for the validation of the NOA also identifies common core sub-tasks across Canada for the occupation. If at least 70% of the responding jurisdictions perform a sub-task, it shall be considered common core. Interprovincial Red Seal Examinations are based on the common core sub-tasks identified through this validation process.

#### Definitions for Validation and Weighting

YES sub-task performed by qualified workers in the occupation in a specific

jurisdiction

NO sub-task not performed by qualified workers in the occupation in a

specific jurisdiction

**NV** analysis Not Validated by a province/territory

ND trade Not Designated in a province/territory

NOT sub-task, task or block performed by less than 70% of responding COMMON jurisdictions; these will not be tested by the Interprovincial Red Seal

**CORE (NCC)** Examination for the trade

NATIONAL average percentage of questions assigned to each block and task in

**AVERAGE** % Interprovincial Red Seal Examination for the trade

#### Provincial/Territorial Abbreviations

NL Newfoundland and Labrador

NS Nova Scotia

PE Prince Edward Island

NB New Brunswick

QC Quebec
ON Ontario
MB Manitoba
SK Saskatchewan

AB Alberta

BC British Columbia
NT Northwest Territories
YT Yukon Territory

NU Nunavut



**SAFETY** 

Safe working procedures and conditions, accident prevention, and the preservation of health are of primary importance to industry in Canada. These responsibilities are shared and require the joint efforts of government, employers and employees. It is imperative that all parties are aware of circumstances and conditions that may lead to injury or harm. Safe learning experiences and work environments can be created by controlling the variables and behaviours that may contribute to accidents or injury.

It is generally recognized that safety-conscious attitudes and work practices contribute to a healthy, safe and accident-free work environment.

It is imperative to apply and be familiar with the Occupational Health and Safety (OH&S) Acts and Workplace Hazardous Materials Information System (WHMIS) regulations. As well, it is essential to determine workplace hazards and take measures to protect oneself, co-workers, the public and the environment.

Safety education is an integral part of training in all jurisdictions. As safety is an imperative part of all trades, it is assumed and therefore it is not included as a qualifier of any activities. However, the technical safety tasks and sub-tasks specific to the trade are included in this analysis.

# SCOPE OF THE CONSTRUCTION ELECTRICIAN TRADE

"Construction Electrician" is this trade's official Red Seal occupational title approved by the CCDA. This analysis covers tasks performed by a construction electrician whose occupational title has been identified by some provinces and territories of Canada under the following names:

	NL	NS	PE	NB	QC	ON	MB	SK	AB	ВС	NT	YT	NU
Construction Electrician	>	>	✓	✓			<b>✓</b>					<b>&gt;</b>	
Electrician								✓	✓	✓			✓
Electrician (Construction)					✓						✓		
Electrician Construction and Maintenance						<b>√</b>							

Construction electricians plan, assemble, install, alter, repair, inspect, verify, commission, operate and maintain electrical systems. Electrical systems provide heating, lighting, power, security, communication and control in residential, commercial, institutional, industrial and entertainment environments. Construction electricians may be self-employed or employed by electrical contractors, utilities, operations and maintenance departments of various facilities.

Construction electricians must read and interpret electrical, mechanical, civil and architectural drawings and specifications such as electrical, building, fire and jurisdictional codes to complete electrical installations. They use electrical test equipment to ensure system safety, functionality and compatibility.

Construction electricians require good communication skills to negotiate, coordinate and facilitate work with customers, co-workers, jurisdictional authorities and other trades. Organizational skills are required to successfully plan and execute their work. They also require strong analytical and problem-solving skills in order to read and interpret diagrams, drawings and specifications. They require mechanical aptitude to install, diagnose and repair systems and components. It is beneficial for construction electricians to have good vision, the ability to distinguish colours, manual dexterity and a willingness to keep up with new developments in the trade.

Their work may be performed indoors or outdoors, at heights, in confined spaces and in hazardous environments. They require stamina as construction electricians spend much of their time performing static and physical tasks. Occupational risks include shocks, industrial diseases, arc flashes, falls and injury from repetitive motion, lifting and kneeling.

This analysis recognizes similarities or overlaps with the work of industrial electricians, powerline technicians, instrumentation and control technicians, and refrigeration and air conditioning mechanics. Construction electricians work with a wide variety of construction tradespeople, engineers and inspectors.

With experience, construction electricians may act as mentors and trainers to apprentices in the trade. They may also advance to positions such as foremen, instructors, project managers, superintendents, estimators, electrical inspectors or start their own contracting business. Construction electricians may enhance their skills in different fields such as restorative, service or retrofit work rather than new construction.

#### OCCUPATIONAL OBSERVATIONS

The industry is moving toward energy saving, efficient and environmentally friendly construction techniques and devices such as alternative power and light emitting diode (LED) lighting.

Safety standards are becoming more emphasized and recognized in all aspects of the trade. Safety training is branching out to include new areas such as arc flash, safety excellence, high voltage and supervision. There is an understanding that electricians have the responsibility to use their expertise on the worksite to assess risks, manage hazards and report issues as they arise.

More than ever, construction electricians need to constantly upgrade their skills either through formal training, manufacturer's training or on the job training to stay current with new technologies such as programming logic control, solar power systems, wind power systems, smart buildings and Leadership in Energy and Environmental Design (LEED).

Communication systems such as voice, data, audio, video and signalling are constantly evolving requiring construction electricians to expand and upgrade their knowledge and abilities in fibre optics, satellite integration, and wireless and local area networks.

It's becoming cost effective to replace rather than repair electronic parts. The part is either disposed of or repaired by the manufacturer. However, a greater knowledge of electronic systems is required to work with more complex electrical control systems such as solid-state or computer-controlled.

Construction electricians are starting to use three dimensional (3D) modelling to facilitate construction methods such as interpreting and updating drawings. They are using mobile devices to receive specifications and other information and assist in diagnostic procedures.

#### ESSENTIAL SKILLS SUMMARY

Essential skills are needed for work, learning and life. They provide the foundation for learning all other skills and enable people to evolve with their jobs and adapt to workplace change.

Through extensive research, the Government of Canada and other national and international agencies have identified and validated nine essential skills. These skills are used in nearly every occupation and throughout daily life in different ways.

A series of CCDA-endorsed tools have been developed to support apprentices in their training and to be better prepared for a career in the trades. The tools can be used independently or with the assistance of a tradesperson, trainer, employer, teacher or mentor to:

- understand how essential skills are used in the trades;
- learn about individual essential skills strengths and areas for improvement; and
- improve essential skills and increase success in an apprenticeship program.

The tools are available online or for order at: <a href="www.hrsdc.gc.ca/essentialskills">www.hrsdc.gc.ca/essentialskills</a>

The essential skills profile for the construction electrician trade indicates that the most important essential skills are **reading**, **numeracy** and **thinking skills** such as **problem solving**.

The application of these skills may be described throughout this document within the competency statements which support each sub-task of the trade. The following are summaries of the requirements in each of the essential skills, taken from the essential skills profile. A link to the complete essential skills profile can be found at <a href="https://www.red-seal.ca">www.red-seal.ca</a>.

#### Reading

Construction electricians read several types of documents such as purchase order agreements and instructions for installing systems and components. They also need to read and understand the Canadian Electrical Code (CEC), which contains legal and highly technical language. They also read other tradespersons' plans and specifications to understand the sequences of installation and locations of apparatus.

#### Document Use

Construction electricians apply document use skills when they read, interpret and collate information from several documents such as plans, specifications, diagrams and schematics. They reference and interpret those documents when installing, assembling, diagnosing and repairing electrical components and systems. The translation of two-dimensional and three-dimensional drawings into three-dimensional applications also requires strong document use skills.

#### Writing

Writing skills are required for construction electricians to record information about their daily work, including hours worked, job locations and details of conversations about the job. They may also be required to record details on an incident or an accident report. They also make notations on as-built drawings to indicate changes from the original drawings, accurately describing the current installation. Labelling and identifying electrical systems also require this skill.

#### **Oral Communication**

Strong oral communication skills are needed for construction electricians as they often need to relay messages, give directions, coordinate tasks with co-workers and discuss electrical code requirements with safety or building inspectors. They also regularly interact with supervisors, engineers, owners, architects, inspectors and other tradespersons to solve technical problems, to discuss work progress, and to ensure that work can meet scheduling and code requirements. They also exchange opinions with co-workers regarding critical safety issues related to complex installations.

#### Numeracy

Construction electricians use their numeracy skills to size and place electrical systems and components, ensuring that installations meet electrical code requirements. They take measurements and perform complex calculations using principles of mathematics such as geometry and trigonometry. Construction electricians also use numeracy skills to design or modify electrical installations.

#### Thinking Skills

Construction electricians use thinking skills when they plan their work in order to ensure efficient use of time and resources. These skills also entail resolving issues such as system routing, and equipment placement and interconnection taking into account customer specifications and code requirements. Additionally, these skills are called upon when consulting with other experienced tradespersons, manufacturers' representatives or engineers to solve technical problems.

#### Working with Others

Construction electricians often work with co-workers, other trades, supervisors, owner's representatives, architects, engineers, inspectors and suppliers. They may be required to demonstrate how to perform a task to other workers, and orient or train new employees. They also participate in discussions about work processes or product improvement.

#### Computer Use

Construction electricians use their computer skills to improve the efficiency of product research, communication, record keeping, job tracking and information exchange with co-workers, other trades, supervisors, owner's representatives, architects, engineers, inspectors and suppliers. They also use different types of software to interface with electrical equipment, such as programmable logic controllers (PLC) and motor control centers (MCC), and to aid in diagnosing system and component failure.

#### Continuous Learning

It is important for construction electricians to stay up-to-date with changing requirements of the electrical code or with changes in technology, such as computer controls. They must keep an open mind to change to advance their skills and increase their knowledge. These learning skills are applied when attending classes offered through unions, employers and other groups.

# **BLOCK A**

#### COMMON OCCUPATIONAL SKILLS

**Trends** New technology such as smart phones and electronic note books are

being utilized to improve organization of work site, estimation and ordering. Advancing technology in arc flash gear aids in worker safety. Evolving technology increases efficiency of tools, equipment and

materials used by construction electricians.

Related Components All components apply.

Tools and Equipment

See Appendix A.

#### Task 1

#### Performs safety-related functions.

#### Context

Construction electricians are responsible for ensuring the safety of themselves and others in the work environment. They must follow company and jurisdictional regulations.

It is critical that construction electricians be constantly aware of their surroundings and the hazards they may encounter.

#### Required Knowledge

K 1	types of personal protective equipment (PPE) such as hard hats, safety glasses, safety footwear, gloves, fall arrest equipment and respiratory protection equipment
K 2	types of safety equipment such as first aid kits and eye wash stations
K 3	certification and training requirements for PPE and safety equipment
K 4	types and operation of fire extinguishing equipment
K 5	location of PPE and safety equipment
K 6	shelf life of PPE and safety equipment
K 7	OH&S regulations
K 8	arc flash ratings and regulations such as National Fire Protection Association (NFPA) 70E and Canadian Standards Association (CSA) Z462
K 9	WHMIS
K 10	company and site safety policies and procedures

K 11	site-specific fire safety and work permit procedures
K 12	emergency procedures for situations such as evacuation, fire and hazardous chemical alarms
K 13	CSA approved equipment
K 14	confined spaces and confined space procedures
K 15	transportation of dangerous goods (TDG) regulations
K 16	lock-out and tagging procedures and legislation governing minimum standards
K 17	safety checks of equipment

Sub-task												
A-1.0	1	Us	es pers	onal pi	rotectiv	e equi	pment	(PPE) a	and saf	ety eq	uipmeı	nt.
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
ves	NV	NV	NV									

## **Key Competencies**

A-1.01.01	identify site hazards and regulations requiring the use of PPE and safety equipment
A-1.01.02	locate and select PPE and safety equipment such as arc flash kits, fall protection, fire extinguishers and signage appropriate for individual tasks and situations
A-1.01.03	ensure proper fit of PPE such as respirators and face shields
A-1.01.04	recognize worn, damaged or defective PPE and safety equipment such as worn boots and cracked safety glasses
A-1.01.05	report and replace damaged or faulty equipment
A-1.01.06	organize, clean and store PPE and safety equipment according to specifications
A-1.01.07	apply safety regulations such as WHMIS and OH&S
A-1.01.08	recognize limitations of use of PPE and safety equipment

Sub-ta	ısk											
A-1.02 Maintains safe work environment.												
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	Key Competencies											
A-1.02.	.01	perf	orm ho	usekeep	oing pra	ctices						
A-1.02.	.02		ntify, rep oil spill		d correc	t potent	ial and	existing	g hazard	ls such a	as arc fl	ashes
A-1.02.	.03	info	rm surr	oundin	g co-wo	orkers co	oncernii	ng safet	y and w	ell-beir	ıg	
A-1.02.	.04	stor	e materi	ials and	equipn	nent						
A-1.02.	.05	ider	ntify and	l respec	t physic	cal limit	ations	of self a	nd othe	rs		
A-1.02.	.06	set up and identify location of safety zone containing components such as first aid kits, fire extinguishers, material safety data sheets (MSDS) and eye wash stations										
A-1.02.	.07		ument it ries and			-	-		zards, s	afety m	eetings,	,
A-1.02.	.08	part	participate in safety meetings and tool box meetings									
A-1.02.	.09	enfo	orce safe	work p	oractice	s						
Sub-ta	ask											
A-1.03	}	Per	forms	lock-o	ut and	tagging	g proce	dures.				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Competencies												
A-1.03.	.01		oordinate lock-out and tagging requirements with appropriate authorities and other trades									
A-1.03.	.02		ntify circ presen			t and ta	gging, a	and reco	ognize o	ther eq	uipmen	t that
A-1.03.	.03		select approved device to ensure proper lock-out and tagging according to regulations									
A-1.03.04 identify power source, and de-energize and lock-out equipment												

A-1.03.05	test system for zero potential using equipment such as voltmeters and high voltage testers
A-1.03.06	verify proper lock-out and tagging

# Task 2 Uses and maintains tools and equipment.

#### Context

Construction electricians must be able to select, use and maintain tools and equipment in a safe and effective manner relevant to the task being performed.

#### Required Knowledge

K 1	types of hand tools such as screwdrivers, pliers, wrenches and measuring tapes, and their limitations
K 2	types of power tools such as drills and saws, and their limitations
K 3	types of powder-actuated tools, and their applications and accessories
K 4	certification requirements to operate powder-actuated tools
K 5	manufacturers' specifications, and operating and maintenance instructions
K 6	types of electrical measuring equipment such as multimeters, voltage testers, non-contact voltage testers, insulation resistance meters, clamp ammeters and phase rotation meters
K 7	applications of electrical measuring equipment
K 8	limitations and ratings of electrical measuring equipment
K 9	electrical measuring equipment components such as leads and batteries
K 10	types of specialty tools such as knock-out punches, compression tools, diagnostic tools, benders and cutters, and their limitations
K 11	types of access equipment such as scissor lifts, lift tables, scaffoldings and articulated boom lifts, and their limitations
K 12	certification requirements and regulations regarding the use of access equipment
K 13	safe angles of ladders and three-point contact rule
K 14	worksite surroundings
K 15	certification requirements regarding rigging, hoisting and lifting equipment
K 16	types of rigging, hoisting and lifting equipment and their limitations
K 17	hoisting and lifting considerations such as anchor points, load ratings and environmental conditions

Sub-ta	ask											
A-2.01	[	Ma	intains	s tools	and eq	uipme	nt.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
A-2.01	.01	organize and store tools and components according to specifications										
A-2.01	.02		n, sharp cification		ricate a	nd adju	st tools	and equ	uipment	accord	ing to	
A-2.01	.03	ensı	ıre calik	oration	of meas	uring e	quipme	nt accor	ding to	specific	cations	
A-2.01	.04	ider	ntify wo	rn, dan	naged ai	nd defe	ctive to	ols and	equipm	ent		
A-2.01	.05	change tool components such as chucks, bits and blades										
A-2.01		•	replace tool components such as cords and attachment plugs									
A-2.01		•	repair tools according to specifications									
A-2.01	.08	ider	identify hazards associated with tools and equipment									
Sub-ta	ask											
A-2.02	2	Use	es acces	ss equi	pment	•						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
A-2.02	.01		ntify trai	ffic area	ıs and p	otential	hazard	ls such a	as confi	ned spa	ces and	
A-2.02	.02	inst	all barri	cades a	nd sign	age to c	ontain v	work zo	ne			
A-2.02	.03					ich as la ing to ta		scissor-l	ifts, sca	ffolding	gs and	
A-2.02	.04	set ı	ap and s	secure s	tep lad	ders and	d extens	sion lad	ders			
A-2.02	.05		•		•	inspect ecificat			0			ess
A-2.02	.06	_	ort, tag a ipment	and dec	ommiss	sion uns	afe, wo	rn, dam	naged an	nd defe	ctive acc	cess
A-2.02	.07	orga	anize an	d store	access 6	equipm	ent acco	ording to	o specif	ications		
A-2.02	.08	wor	work from approved access equipment									

#### Sub-task

#### A-2.03 Uses rigging, hoisting and lifting equipment.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

A-2.03.01	identify traffic areas and potential hazards such as confined spaces and trenches
A-2.03.02	install barricades and signage to contain work zone
A-2.03.03	use and interpret hand and audible signals
A-2.03.04	select and secure rigging, hoisting and lifting equipment according to application
A-2.03.05	ensure capacity of rigging, hoisting and lifting equipment according to specifications and jurisdictional regulations
A-2.03.06	visually and mechanically inspect for worn, damaged and defective rigging, hoisting and lifting equipment according to specifications
A-2.03.07	report, tag and decommission unsafe, worn, damaged and defective rigging, hoisting and lifting equipment
A-2.03.08	secure load for application according to specifications, jurisdictional regulations and company policy
A-2.03.09	clean, lubricate and store rigging, hoisting and lifting equipment
A-2.03.10	perform minor field maintenance on equipment
A-2.03.11	move load to final position

Task 3	Organizes work.
I ask 3	Olganizes work.

#### Context

Construction electricians organize projects in order to safely and efficiently use material, labour, tools and equipment. They interpret drawings, plans and specifications to identify required resources. Communication and planning skills are essential to this trade.

#### Required Knowledge

K 1	regulations such as building codes, the CEC and jurisdictional codes
K 2	OH&S regulations
K 3	code and regulation updates

K 4	components of plans, drawings and specifications such as scaling rulers, legends, details and symbols
K 5	types of documents such as shop drawings and catalogues
K 6	company policies and procedures
K 7	WHMIS
K 8	trade terminology
K 9	project or task to be completed and sequence of operations
K 10	site location, conditions and restrictions
K 11	other trades' work requirements
K 12	delivery dates and availability of materials
K 13	supply authorities' specification requirements and scheduling
K 14	building components such as walls, ceilings and floors
K 15	system components such as panel boards, switchgear and MCC
K 16	work site hazards such as existing utilities, dust, asbestos, temperature, chemicals and weather
K 17	inventory systems
K 18	storage requirements such as temperature, environmental conditions and stacking limitations

Sul	b-task

A-3.01	Interprets	plans, drawings	and specifications.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	$\underline{YT}$	<u>NU</u>
yes	NV	NV	NV									

## **Key Competencies**

A-3.01.02 scale dimensions to determine location of devices	
A-5.01.02 Scale difficultions to determine location of devices	
A-3.01.03 locate and cross-reference information on plans, drawings, specifications a contract documents	and
A-3.01.04 visualize finished product	
A-3.01.05 utilize schematics and wiring diagrams to perform tasks such as diagnosis maintaining and installing systems	ng,
A-3.01.06 determine if plans, schematics and drawings are current	

Sub-ta	ask												
A-3.02	2	Org	ganizes	s mater	ials an	d supp	lies.						
NL	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>on</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key C	ompete	ncies											
A-3.02	.01	identify and select materials and supplies according to specifications and CEC									nd		
A-3.02	.02					deliver ailability	•				0		
A-3.02	.03					terials a		plies acc	cording	to facto	rs such	as	
A-3.02	.04			_		_		ired ma	iterial a	nd supp	olies		
A-3.02	.05	COO1	perform material take-off to identify required material and supplies coordinate receiving of materials and supplies to ensure delivery of shipment									pment	
A-3.02	.06	verify shipments of materials and supplies to ensure that quality and quantity match order											
A-3.02	.07	perf	perform inventory control										
Sub-ta	ask												
<b>A-3.0</b> 3	3	Pla	ns pro	ect tas	ks and	proced	lures.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key C	ompete	ncies											
A-3.03	.01	visually inspect work environment to determine scope of work from approved documentation								from			
A-3.03	.02		etermine labour and equipment requirements according to specifications uch as wire sizes, load requirements and locations										
A-3.03	.03					edules a roject pi		0	teria su	ich as w	eather,		
A-3.03	.04	COO1		work w	ith othe	er trades	C		nts such	ı as shu	tdown a	and	
A-3.03	.05		w and s	-	Ü								

Sub-t	ask														
A-3.04	4	Pre	pares v	work s	ite.										
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	QC	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>			
yes	yes							yes		NV	NV	NV			
yes	yes	yes	yes yes yes yes yes yes NV NV N								1 🕻 🕻				
Key C	ompete	ncies													
A-3.04	.01	perf	perform pre-job assessment												
A-3.04	.02		ıally ins fined sp	-	-		areas ar	nd potei	ntial haz	zards su	ıch as				
A-3.04	.03	inst	all barri	cades a	nd sign	age to c	ontain v	work zo	ne						
A-3.04	.04	crea	te open	ings an	d penet	rations	in struc	tures ar	nd equip	oment					
A-3.04	.05	ensi	are suffi	icient li	ghting a	nd ven	tilation	of work	c area						
A-3.04.06 ensure required materials and equipmen							uipment	t are ons	site						
A-3.04.07 control workplace access															
A-3.04	.08	ensi	are surv	eys and	d locates	s are coi	mpleted	l and m	arked-o	ut					
Sub-t	ask														
A-3.05	5	Fin	alizes	require	ed docu	ımenta	tion.								
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>			
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV			
Key C	ompete	encies													
A-3.05	.01	document alterations by modifying plans, schematics and drawings to rechanges and additions made to original application								reflect					
A-3.05	5.02	para	log data from various sources such as variable frequency drive (VFD) parameters, PLC programs and overload settings to assist with maintenance and replacement												
A-3.05	5.03		ipile ma		nce man	uals fro	m insta	lled equ	uipment	manuf	acturers	3′			
A-3.05	5.04		mit requ comer	uired fir	nal docu	ımentat	ion, inc	luding a	as-built	drawin	gs, to				

#### Task 4

#### Fabricates and installs support components.

#### Context

Construction electricians fabricate support structures to protect and support equipment and components. They use various methods to secure equipment to structure in order to maintain a safe installation, and reduce hazards and unwanted movements. Seismic restraint systems are used as a secondary support.

#### Required Knowledge

K 1	types of brackets such as L, U and straight brackets
K 2	types of hangers such as strut, pipe and threaded rod
K 3	types of fasteners such as screws, bolts and anchors
K 4	types of seismic restraint systems
K 5	regulations regarding seismic restraint systems
K 6	specifications and regulations for fastening and supporting components
K 7	supporting weight and shear tensile strength
K 8	equipment such as panel boards, transformers, switchgear and MCCs
K 9	basic construction methods
K 10	metric and imperial measurements
K 11	building materials such as those used in walls, ceilings and floors
K 12	work site hazards such as existing utilities, explosive atmosphere, dust, temperature, chemicals and weather

#### Sub-task

## **A-4.01** Fabricates support structures.

<u>NL</u>	<u>NS</u>	$\underline{PE}$	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV

#### **Key Competencies**

A-4.01.01	measure equipment to determine structure size
A-4.01.02	draw scale sketch
A-4.01.03	determine material to be used such as wood, steel and aluminium according to specifications and CEC considering factors such as environment and cost
A-4.01.04	select and use tools and equipment such as chop saws, drills and wrenches
A-4.01.05	select and use fasteners such as nuts, bolts and screws according to specifications and CEC

A-4.01	.06	pre	pare ma	terial b	y cuttin	g to size	e and dr	illing h	oles				
A-4.01	.07	asse	assemble material to create structure										
Sub-t	ask												
A-4.02	2	Ins	stalls b	rackets	, hang	ers and	fasten	ers.					
<u>NL</u>	<u>NS</u>	PE	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key C	ompete	encies											
A-4.02	01	sele	ect and u	ise tools	s and ec	quipmer	nt such a	as hand	tools ar	nd pow	er tools		
A-4.02	2.02	select brackets, hangers and fasteners according to specifications and CEC								EC			
A-4.02	2.03	determine installation location to avoid obstructions such as duct wo							ct work,	,			
		plu	plumbing pipes and equipment										
		secure brackets, hangers and fasteners to structure according to specifications and CEC											
A-4.02	2.04			kets, ha	ingers a	nd faste	eners to	structu	re accor	ding to	specific	ations	
A-4.02	2.04			kets, ha	ingers a	nd faste	eners to	structu	re accor	ding to	specific	cations	
A-4.02	2.04			kets, ha	ingers a	nd faste	eners to	structu	re accor	ding to	specific	cations	
A-4.02				kets, ha	ingers a	nd faste	eners to	structu	re accor	ding to	specific	cations	
	ask	and						structu	re accor	ding to	specific	cations	
Sub-t	ask	and	CEC					structu:	re accor	ding to	specific	eations NU	
Sub-t A-4.03	ask 3	and Ins	CEC	eismic :	restraii	nt syste	ems.						
Sub-t. A-4.03  NL yes	ask 3 <u>NS</u> no	Ins	cEC stalls se	eismic :	restrain	nt syste	ems. <u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>	
Sub-t A-4.03 NL yes Key C	ask 3 NS no compete	Ins PE no encies	stalls se	eismic : QC yes	restrain ON yes	nt syste MB no	e <b>ms.</b> <u>SK</u> yes	<u>AB</u> yes	BC yes	NT NV	YT NV	<u>NU</u> NV	
Sub-ti A-4.03 NL yes Key C	ask 3 NS no compete	Ins  PE no encies sele	Stalls se  NB  yes	<b>QC</b> yes	restrain ON yes s and ec	nt syste MB no	e <b>ms.</b> S <u>K</u> yes	AB yes	BC yes	<u>NT</u> NV	<u>YT</u> NV able plie	<u>NU</u> NV	
Sub-t A-4.03 NL yes Key C	ask 3 NS no compete	Ins  PE  no  encies  sele  sele	stalls se	OC yes use tools	restrain ON yes s and ec	nt syste MB no	e <b>ms.</b> S <u>K</u> yes	AB yes	BC yes	<u>NT</u> NV	<u>YT</u> NV able plie	<u>NU</u> NV	
Sub-ti A-4.03 NL yes Key C	ask 3 NS no compete	Ins  PE no encies sele sele regu pos	Stalls see  NB  yes  ect and u	OC yes use took	on yes s and eq	nt syste MB no quipment c restraint	ems.  SK yes  nt such a int syste	AB yes as crimpems acco	BC yes pers and ording t	NT NV I adjusta	YT NV able plic	NU NV ers	

#### Task 5

#### Commissions and decommissions electrical systems.

#### Context

Construction electricians commission electrical systems to ensure safe and correct operation. They also shut down systems to perform preventative maintenance or to replace defective equipment. They decommission systems to prepare them for removal.

#### Required Knowledge

K 1	commissioning procedures such as rotational testing, voltage readings and current readings
K 2	required documentation
K 3	specifications and regulations
K 4	sequence of operation of equipment
K 5	lock-out and tagging procedures
K 6	decommissioning procedures
K 7	testing equipment
K 8	PPE and safety procedures
K 9	equipment ratings such as voltage and current

#### Sub-task

#### A-5.01 Performs start-up and shut-down procedures.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

A-5.01.01	identify equipment that need to be energized or de-energized
A-5.01.02	follow specifications sequence for start-up and shut-down
A-5.01.03	test cables for ground faults and phase identification
A-5.01.04	check system peripherals such as detection and alarm systems for correct operation
A-5.01.05	select and use tools and equipment such as megohmmeters, voltmeters and ammeters
A-5.01.06	apply safety ground on shut-down, and remove on start-up
A-5.01.07	verify busbar connections and torquing of bolts

A-5.01		and	verify that safety and shipping material has been removed from equipment and check for tools and loose hardware prior to start-up notify required personnel of start-up and shut-down procedures												
Sub-t	ask														
A-5.0	2	Co	nducts	operat	ional t	ests.									
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>			
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV			
Key C	ompete	encies													
A-5.02	2.01		ct and u	ıse tools	s and ec	quipmer	nt such a	as mego	hmmet	ers, vol	tmeters	and			
A-5.02	2.02	check for motor rotation													
A-5.02	2.03		check system peripherals such as detection and alarm systems for correoperation							or corre	ct				
A-5.02	2.04	-								-	ections,				
A-5.02	2.05	perf	orm vis	ual ins <sub>l</sub>	pections	s to ider	ntify pro	blems							
A-5.02	2.06	adju	ıst comj	onents	to achi	eve des	ired ope	eration							
A-5.02	2.07	perform short-circuit tests on conductors													

# **BLOCK B**

# SYSTEMS, DISTRIBUTION AND SERVICES

**Trends** The scope of alternative power systems is expanding and becoming

more complex. Construction electricians need to adapt and develop

new skills to design and install those systems.

Related Components (including, but not limited to) Cables, panels, sub-panels, transformers, uninterruptible power supply (UPS) equipment, switchgear, capacitors, motors, cathodic protection equipment, surge protection equipment, meters, generators, turbines, transfer switches, rectifiers, converters, temporary power equipment, conduit, solar panels, control panels, wind turbines, fences,

towers, cabinets.

Tools and **Equipment** 

See Appendix A.

#### Task 6

#### Installs service entrance and distribution equipment.

#### Context

The service entrance and distribution equipment provides power for all electrical systems and equipment. Consumer services can provide normal, emergency and temporary power. This equipment allows for the safe utilization of electricity.

Construction electricians install panels, sub-panels and their associated components to distribute power in facilities.

#### Required Knowledge

K 1	types of supply services such as underground and overhead
K 2	supply service components such as conductors, insulators, meter bases, conduit and panels
K 3	installation methods and conditions pertaining to different environments for supply services
K 4	grounding and bonding methods and requirements
K 5	types of raceways and feeders such as triplex, TECK 90 and R90
K 6	connection methods to consumer service
K 7	types of wiring methods
K 8	installation methods for underground application

K 9	types of metering transformers such as current transformers (CT) and potential transformers (PT)
K 10	types of transformers such as service and distribution transformers
K 11	types of meters such as digital and analog
K 12	supply authority requirements
K 13	types of cabinets and enclosures
K 14	types of fuses such as time delay, high rupture capacity (HRC) and non-time delay
K 15	types of circuit breakers such as mechanical and adjustable
K 16	branch circuit loads and demand factors
K 17	available fault current
K 18	interrupting capacity and ratings of breakers and fuses
K 19	types and clearances of power distribution centres/equipment such as single-phase panel, three-phase panel and MCC
K 20	power and distribution regulations according to CEC and local jurisdictions
K 21	types of portable panels, cables and conductors used for temporary power
K 22	surge protection components such as lightning arresters, ground fault protection and grounding systems
K 23	phase and voltage rating
K 24	types of electrical equipment that require surge protection such as computers, electronic equipment and lighting
K 25	types of power conditioning devices and installation procedures
K 26	power factor and power factor corrections
K 27	requirements for battery bank installations
K 28	types of UPS systems and components such as transfer switches, battery banks and generators
K 29	requirements and uses of UPS systems such as lighting, computers and telephones
K 30	types of panels and sub-panels, and their application
K 31	panel and sub-panel ratings such as current, voltage and capacity
K 32	parallel conductors including the effects of induction
K 33	types of fittings and connectors
K 34	installation and support of panels, sub-panels, feeders and raceways
K 35	line loss and voltage drop

Sub-ta	ask											
B-6.01		Ins	talls co	nsume	er/supp	ly serv	rices.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	ompete	ncies										
B-6.01.	01		rmine s tempor								_	
B-6.01.	-6.01.02 select components such as supports, conductors, enclosures, raceways and cabinets according to specifications, CEC and local supply authorities											
B-6.01.	-6.01.03 select and use tools and equipment such as knock-out cutters, hole saws and drills											
B-6.01.												
B-6.01.	supply authorities  determine trench size and minimum cover requirements to allow for the installation of direct burial cables and underground raceways according to specifications, CEC and local supply authorities											
B-6.01.	06	erec	t and se	cure se	rvice co	mponei	nts such	as con	duit and	d cables		
B-6.01.	07		int encloply auth		and equ	ipment	accordi	ing to sp	ecificat	ions, Cl	EC and	local
B-6.01.	08		ninate co norities	onnectio	ons acco	ording t	o specif	ications	s, CEC a	nd loca	l supply	7
B-6.01.	09	ider	itify and	l label c	ompon	ents acc	ording	to speci	fication	s and C	CEC	
B-6.01.	10	bon	d and g	round o	compon	ents acc	ording	to speci	fication	s and C	CEC	
Sub-ta	ask											
B-6.02		Ins	talls m	etering	g systei	ns.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	ompete	ncies										
B-6.02.	B-6.02.01 select and use tools and equipment such as knock-out cutters, hole saws and drills											
B-6.02.	B-6.02.02 determine metering requirements according to service size, specifications, CEC and local supply authorities											

B-6.02	B-6.02.03 select components such as conductors, enclosures, raceways and cabinets according to specifications and CEC												
B-6.02	.04		unt com	-	s such a s	s meter	ing cabi	inets, C	Ts, PTs	and rela	ated ele	ctrical	
B-6.02	.05		, install ipment	and sec	cure cab	les, race	eways a	nd fittir	ngs asso	ciated t	o meter	ring	
B-6.02	.06	tern	ninate c	onnecti	ons usir	ng mech	anical a	and com	npressio	n type f	ittings		
B-6.02	.07	ider	ntify and	d label d	compon	ents acc	ording	to speci	ificatior	s and C	EC		
B-6.02	.08	bon	d and g	round o	compon	ents acc	cording	to speci	ificatior	s and C	CEC		
Sub-t	ask												
B-6.03	3	Ins	talls ov	vercuri	ent pro	otection	1.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key C	ompete	encies											
B-6.03	.01		ct and u extracto		and eq	uipmen	t such a	s wrenc	ches, he	x keys,	testers a	and	
B-6.03	.02		ulate and current		terrupti s	ng capa	city and	d trip se	ettings to	o ensure	e operat	tion of	
B-6.03	.03	fuse	s, one-ti	me fuse	enclosur es and b ch as lig	reakers	based o	on load,	enviro			y	
B-6.03	.04	secu	re and t	ermina	te overd lders ac	urrent p	orotecti	on usin	g fasten		n as boli	ts,	
Sub-t	ask												
B-6.04	l	Ins	talls po	ower d	istribu	tion ce	ntres.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key C	ompete	encies											
B-6.04	.01	sele	ct and 1	ise tools	s and eq	uipmer	nt						
B-6.04		dete	ermine l	ocation	and lay	out of o	compon						

B-6.04.	03	mount components and interconnect with required cables, raceways and conductors according to specifications and CEC												
B-6.04.	04					ents acc			fication	ıs and C	CEC			
Sub-ta	ask													
B-6.05	;	Ins	talls te	mpora	ry pow	er.								
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies												
B-6.05.	01	sele	select and use tools and equipment											
B-6.05.	02		select and use tools and equipment determine cable and system routing and protection according to specifications and CEC											
B-6.05.	03	prot acce		ponent	s from e	environ	mental	and me	chanica	l damag	ge, and ]	public		
B-6.05.	04	CDI	-			transfo r locatio								
B-6.05.	.05			-		terconn pecificat		-	ed cable	es, racev	ways an	d		
B-6.05.	06	inst	all grou	nding a	nd bon	ding aco	cording	to spec	ificatior	ns and C	CEC			
B-6.05.	07		ntify and CEC	d label o	compon	ents and	d condu	ictors ac	ecording	g to spe	cificatio	ns		
Sub-ta	ask													
B-6.06	,	Ins	talls su	ırge su	ppress	ion sys	tems.							
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	y Competencies													
B-6.06.	01	sele	ct and u	se tools	and eq	uipmer	nt							
B-6.06.	02	crea	te a sing	gle line	diagrar	n for sy	stem en	gineerii	ng and	design				
B-6.06.02 create a single line diagram for system engineering and design B-6.06.03 select components according to specifications and CEC														

B-6.06.	04	install and connect surge suppression components according to specifications and CEC												
B-6.06.	05	ensı	ıre com	-	ty with ed grou		ted elec	trical sy	stems s	uch as l	ightnin	g		
Sub-ta	ask													
B-6.07	•	Ins	talls po	ower co	onditio	ning s	ystems	•						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies	es											
B-6.07.	01		select and use tools and equipment such as power quality analyzers and ammeters											
B-6.07.	02	perf	perform calculations to size transformers											
B-6.07.	03	size	capacit	ors acco	ording t	o specif	ications	3						
B-6.07.	04	select components such as filters, capacitors and transformers according to specifications and CEC												
B-6.07.	05				nnect co	-		as cabl	es, conc	duit and	condu	ctors		
B-6.07.	06		lyze sys allation	tem ou	tput to e	ensure e	ffective	eness of	power (	conditio	oning			
B-6.07.	07	inst	all grou	nding a	ind bon	ding aco	cording	to spec	ificatior	ns and C	CEC			
Sub-ta	ask													
B-6.08	}	Ins	talls u	ninterr	uptible	e powe	r supp	ly (UPS	S) syste	ems.				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>on</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies												
B-6.08.	01	sele	ct and u	se tools	s and eq	uipmer	nt							
B-6.08.	02	determine installation requirements of UPS such as volt/amp (VA) ratings												
					ing to sp					• •	•	=		
B-6.08.	verify integrity of support base for UPS according to specifications and CEC									CEC				

B-6.08.04 position, mount and interconnect UPS components such as translatery banks, transformers, inverters and rectifiers according to specifications and CEC  B-6.08.05 install grounding and bonding according to specifications and continuous according to specifications.											)	tches,	
Sub-task Table 1													
B-6.09	3-6.09 Installs panels and sub-panels.												
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key C	ompete	encies											
B-6.09.	.01		ct and u ue wrei		-		nt such a	as knocl	k-out cu	tters, h	ole saws	5,	
B-6.09.	.02	acco	ermine r ording to nand, vo	o specif	ications	and CI	EC, and	conside	ering fac			i	
B-6.09.	.03		sure, la	-		nt pane	ls and s	ub-pane	els acco	rding to	•		
B-6.09.04 assemble panel and sub-panel components such as breake pan fronts, cover assemblies, and grounding and neutral k										mblies,	dead		
B-6.09.05 interconnect panels and sub- and CEC							ls with	raceway	s accor	ding to	specific	ations	
B-6.09.	.06	ider	identify and label panels and sub-panel components according to										

specifications and CEC

#### Task 7

#### Installs bonding, grounding and cathodic protection systems.

#### Context

Bonding and grounding systems are used to protect life and equipment from

transient and fault current.

Ground fault protection systems are used to protect against electrical shock.

Cathodic protection systems introduce a current onto a tank, pipe or structure

to limit corrosion and oxidization.

#### Required Knowledge

K 1	grounding requirements and components such as rods, plates, electrodes, wires and crimps
K 2	step potential
K 3	bonding requirements and components such as lugs, wires and crimps
K 4	ground fault equipment such as relays and CTs
K 5	applications for ground fault protection systems such as pools, shipyards, kitchens and bathrooms
K 6	installation methods and procedures
K 7	location, clearance and access requirements for ground fault protection systems
K 8	types and purpose of lightning arresters
K 9	components of cathodic protection systems such as controllers and sensors
K 10	purpose of cathodic protection systems
K 11	hazards of working on cathodic protection systems
K 12	rectifier circuits

#### Sub-task

#### B-7.01 Installs grounding systems.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

B-7.01.01	select and use tools and equipment such as thermit welding equipment, crimping tools, pipe clamps, ground plates and ground rods
B-7.01.02	lay out ground system according to specifications, CEC and local supply authorities
B-7.01.03	excavate area according to specifications, CEC and local supply authorities

B-7.01.	04	install and interconnect grounding system components such as ground rods, plates and conductors according to specifications, CEC and local supply authorities										
B-7.01.	05	perf	orm gro	ound re	sistance	test to	verify s	ystem				
Sub-ta	ask											
B-7.02		Ins	talls bo	onding	condu	ctors.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
B-7.02.	-										tools an	d
B-7.02.	02	calc	ulate an	d size ł	onding	conduc	ctors acc	cording	to spec	ificatior	ns and C	CEC
B-7.02.	03	-	ı layout s, direct				-		_	rs such	as locati	ion of
B-7.02.	04		ninate b	-						and CE	EC	
Sub-t	ask											
B-7.03	}	Ins	talls gr	ound i	fault pı	otectio	n syste	ems.				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
B-7.03.	01	sele	ct and u	se tools	s and eq	uipmer	ıt					
B-7.03.02 determine type of installation required such as life or equivaccording to specifications and CEC								uipmen	t protec	tion		
B-7.03.	03	position, mount and interconnect ground fault system components in enclosure										
B-7.03.	04	set ground fault protection systems to required specifications and CEC										

Sub-ta	Sub-task													
B-7.04	<u> </u>	Ins	talls li	ghtnin	g arres	ters.								
	) I C	D.E.	. ID		0.17	. m	OT 6	4.5	D.C.	) IT	<b>)</b> (TF			
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT NU	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies												
B-7.04.	B-7.04.01 select and use tools and equipment such as crimping tools and thermit welding equipment  8-7.04.02 select and lay out lightning protection components such as conductors													
B-7.04.	B-7.04.02 select and lay out lightning protection components such as conductors, ground rods and isolated supports according to specifications and CEC													
B-7.04.	B-7.04.03 install ground rods according to specifications and CEC													
B-7.04.	B-7.04.04 position, mount and interconnect lightning arrester components according to specifications and CEC													
B-7.04.	.05	test	and ver	ify inst	allation	with m	anufact	urer to	ensure (	operatio	on of sys	stem		
Sub-ta	Sub-task													
B-7.05	;	Ins	talls ca	thodic	protec	tion sy	stems.							
					•	,								
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies												
B-7.05.	.01	sele	ct and u	se tools	and eq	uipmer	ıt							
B-7.05.	.02	sele	ct comp	onents	accordi	ng to sp	ecificat	ions and	d CEC					
B-7.05.	B-7.05.03 position, mount and interconnect components of cathodic protection systems according to specifications and CEC													

#### Task 8

## Installs power generation systems.

#### Context

Generators and alternative power generation systems can be used when power from the utility is unavailable or the building is isolated from the power grid. Some forms of alternative power generation systems can also feed energy back to the power grid.

#### Required Knowledge

K 1	types of generators
K 2	types of transfer switches such as manual and automatic
K 3	load requirements
K 4	generator requirements such as clearances, access, ventilation and fuel systems
K 5	operation of transfer switches and generators
K 6	control circuits and alarms for transfer switches and generators
K 7	types of alternative power generation systems such as photovoltaic, tidal and wind
K 8	utility company requirements and regulations regarding alternative power generation systems
K 9	operation of alternative power generation systems
K 10	location of alternative power generation systems for maximum efficiency
K 11	synchronization of generators

#### Sub-task

#### B-8.01 Installs generators and transfer switches.

]	<u>NL</u>	<u>NS</u>	<u>PE</u> ]	<u>NB</u>	<u>QC</u> (	<u> </u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
,	yes :	yes :	yes y	yes :	yes :	yes ]	yes	yes j	yes :	yes	NV	NV	NV

B-8.01.01	select and use tools and equipment
B-8.01.02	determine system requirements according to CEC and specifications such as
	primary and secondary source of power, size of fuel reserve and interconnections
B-8.01.03	verify integrity of base supporting generator
B-8.01.04	determine size of generator and transfer switches according to specifications and CEC

B-8.01.05	place and anchor generator according to specifications
B-8.01.06	install and interconnect components such as transfer switches, utility power, generator and load with cables, raceways and conductors according to specifications and CEC
B-8.01.07	ground and bond generator according to specifications and CEC
B-8.01.08	program generator controls for start-up and shut-down sequences

#### Sub-task

#### B-8.02 Installs alternative power systems.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

B-8.02.01	select and use tools and equipment
B-8.02.02	determine scope of work based on specifications
B-8.02.03	install ground grids according to specifications and CEC
B-8.02.04	position, mount and interconnect alternative power system and control system components according to specifications and CEC
B-8.02.05	test and verify installation with manufacturer to ensure operation of system

## Task 9 Installs high voltage systems.

#### Context

Construction electricians assemble, install, erect and connect equipment and cables for high voltage applications such as switchyards, sub-stations and electrical vaults. In these applications, they use specific equipment, tests and procedures to ensure safety.

It is extremely important to perform this work properly and safely due to the inherent hazards in working with high voltage systems that can cause property damage, serious injury or death.

K 1	high voltage principles and practices
K 2	types of high voltage equipment such as switchgear, load regulators, transformers, insulators, poles and towers
K 3	grounding, bonding and step potential

K 4	effect of induction
K 5	limits of approach for personal safety
K 6	hazards related to high voltage such as arc flashes
K 7	installation specifications
K 8	location of high voltage equipment such as underground and overhead
K 9	guarding requirements and methods
K 10	bending radius of high voltage cables
K 11	direct burial requirements
K 12	types of cables such as armoured and concentric
K 13	types of conductors such as aluminium and copper
K 14	configurations, spacing and barriers
K 15	marking requirements and practices
K 16	installation materials such as insulators and supports
K 17	high voltage termination techniques
K 18	types of tests such as high potential test, and inductor test and their purpose and requirements
K 19	lockout, testing and grounding procedures for high voltage systems

B-9.01 Install	ls 1	high	voltage	equipment.
----------------	------	------	---------	------------

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
ves	ves	ves	ves	ves	ves	yes	ves	ves	ves	NV	NV	NV

B-9.01.01	select and use tools and equipment such as torque wrenches and knock-out cutters
B-9.01.02	determine installation requirements such as location and spacing of equipment according to specifications and CEC
B-9.01.03	anchor and assemble high voltage components such as capacitor banks and rectifiers according to specifications and CEC
B-9.01.04	interconnect high voltage components according to specifications and CEC
B-9.01.05	ground and bond electrically conductive components such as fences, towers, doors and enclosures according to specifications and CEC

Sub-ta	ask											
B-9.02	B-9.02 Installs high voltage cables.											
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
B-9.02.	B-9.02.01 select and use tools and equipment such as tuggers, cranes, reel jacks and ropes									nd		
B-9.02.	02	cons	rmine la sidering ribution	factors	such as	locatio	n of ree	els and t				ıll,
B-9.02.	03	iden	itify and	l label v	vires an	d cable	s accord	ling to s	specifica	ations a	nd CEC	
B-9.02.	04	-	tion, mo	ount an	d secur	e cables	and co	nductor	s accord	ding to	specific	ations
B-9.02.	05		and ver lation to	,			d condı	uctors u	sing me	ethods s	uch as	
Sub-ta	ask											
B-9.03	•	Ter	minate	s high	voltag	e cable	es.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
B-9.03.01 select and use tools and manufacturers' specified equipment such as cable benders, hydraulic crimpers and cable cutters												
B-9.03.	02	sele	ct termi	nation l	kit to ma	atch cab	ole type	accordi	ng to sp	ecificat	ions	
B-9.03.03 prepare termination points using techniques such as sanding, vulcanizing and stripping according to specifications								ng				
B-9.03.	04	insta	all termi	ination	kit and	lugs ac	cording	to spec	ification	ns and C	CEC	
B-9.03.	B-9.03.05 secure and support cables according to specifications and CEC											

$\circ$ 1		1
<b>\11</b>	b-ta	$\mathbf{c}\mathbf{r}$
Ou,	v-ta	$\sigma$

#### B-9.04 Tests high voltage systems.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

B-9.04.01	select and use test equipment
B-9.04.02	verify installation according to specifications and CEC to ensure integrity of installation
B-9.04.03	isolate components to perform and allow for safe testing procedures
B-9.04.04	perform tests, such as high potential and insulation tests, on equipment and conductors according to specifications
B-9.04.05	discharge residual capacitance from high voltage cables
B-9.04.06	interpret test data to verify integrity of system and compliance with specifications before re-energization

Task 10	Installs transformers.
I doll Io	mistaris transformers.

#### Context

Construction electricians install extra-low, low and high voltage transformers to condition or alter voltage and current. Common transformer uses include control, isolation, distribution and transmission.

K 1	sizes and types of transformers such as dry, oil-filled, single-phase and three-phase
K 2	transformer installation procedures and location
K 3	tap settings
K 4	purpose of transformers such as step-up, step-down and isolation
K 5	transformer clearances
K 6	transformer winding configuration
K 7	purpose of transformer grounding
K 8	conductor spacing and insulation for different applications

Sub-ta	ask											
B-10.0	1	Ins	Installs extra low voltage transformers.									
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes										NV
Key Co	ompete	ncies										
B-10.01.01 select and use tools and equipment												
B-10.01	1.02	dete	rmine s	upply v	oltage	and req	uired o	utput V	A rating	3		
B-10.01	1.03	dete	rmine l	ocation	of trans	sformer	to be in	stalled	and req	uired e	nclosur	es
B-10.01	1.04	-		ount an	d interc	onnect	compor	nents ac	cording	to spec	rification	ns and
		CEC										
Sub-ta	ask											
B-10.0	2	Ins	talls lo	w volt	age tra	nsform	ers.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	ompete	ncies										
B-10.02	2.01	sele	ct and u	se tools	and eq	uipmen	ıt					
B-10.02	2.02	dete	rmine s	ystem 1	equirer	nents, s	uch as i	nput/oı	ıtput vo	ltage, p	hasing,	VA
		ratir CEC	_	e size a	nd over	current	protect	ion, acc	ording	to speci	fication	s and
B-10.02	2.03		rmine a			formers	accord	ing to l	ocation,	intende	ed use,	
B-10.02	2.04	•	tion, mo			onnect	compor	nents ac	cording	to spec	rificatio	ns and
B-10.02	2.05			hange t	ap settii	ngs of tı	ansforr	ners				
B-10.02				_	_	ig to spe			CEC			
B-10.02		perf	orm tes	ts, such	as high	potent and CE	ial and			, on equ	ıipment	

#### Sub-task

## B-10.03 Installs high voltage transformers.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

B-10.03.01	select and use tools and equipment
B-10.03.02	determine system requirements, such as input/output voltage, VA ratings, wire size and overcurrent protection, according to specifications and CEC
B-10.03.03	determine and select transformers according to location, intended use, specifications and CEC
B-10.03.04	position, mount and interconnect components according to specifications and CEC
B-10.03.05	select and change tap settings of transformer
B-10.03.06	ground and bond according to specifications and CEC
B-10.03.07	perform tests, such as high potential and insulation tests, on equipment according to specifications and CEC

## **BLOCK C**

### WIRING METHODS

#### **Trends**

The industry is moving toward energy-saving and environmentally friendly devices such as photo-luminescent lighting, LED lighting and alternative emergency systems. User friendly components such as quick connectors for cable and fluorescent lighting are becoming commonplace. Ergonomically designed connectors are making installation easier and faster.

Related Components (including, but not limited to) Conduit, cables, boxes, straps, fittings, raceways, devices, luminaires, conductors, splitters, cabinets, electric heaters, heating cables, overcurrent devices, batteries, lighting and mechanical control devices.

Tools and Equipment

See Appendix A.

#### Task 11

#### Installs raceways and cables.

#### Context

Construction electricians install raceways, conductors and cables to interconnect components. The raceways support and protect conductors. Enclosures may be used to access and terminate the content of the raceway, and to facilitate the pulling and the interconnection of components. Raceways and cables are installed in various environments.

K 1	types and sizes of raceways such as conduit, tray, floor duct and cellular floors
K 2	types of fittings such as couplings and connectors
K 3	installation requirements such as number of bends, support spacing and types of supports
K 4	cable types and applications
K 5	installation environment
K 6	types of cable supports and fasteners such as staples and straps
K 7	termination requirements such as connectors, anti-oxidants and bushings
K 8	pulling tension for cable installation
K 9	types of underground conduit and cable

K 10	conductor protection, marking and spacing
K 11	underground wiring techniques
K 12	types of enclosures such as boxes and cabinets
K 13	clearances and accessibility
K 14	sizing requirements for enclosures
K 15	size, number and types of conductors
K 16	lubricants
K 17	fishing techniques and related hazards

Sub-t	ask											
C-11.0	)1	Ins	talls ra	ceway	S.							
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

C-11.01.01	select and use tools and equipment such as pipe benders, hammer drills and wrenches
C-11.01.02	determine installation requirements such as route, height, supports and space availability according to specifications and CEC
C-11.01.03	select components according to the installation environment such as weathertight, dust-tight and explosion-proof fittings
C-11.01.04	measure, cut, bend and assemble raceway components according to specifications and CEC considering factors such as environment and site conditions
C-11.01.05	determine layout of raceway components such as fittings, straps and pipes for ease of installation
C-11.01.06	position, mount and support raceways according to specifications and CEC

Sub-t	ask											
C-11.0	)2	Ins	talls ca	bles.								
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
C-11.0	2.01	select and use tools and equipment such as cable cutters, cable strippers and tuggers										
C-11.0	C-11.02.02 determine installation requirements such as route, height, supports and space availability according to specifications and CEC											
C-11.0	2.03	sele	ct cable:	s, conne	ectors ar	nd supp	orts acc	cording	to speci	fication	s and C	EC
C-11.0	2.04		select components according to the installation environment such as weathertight, dust-tight and explosion proof fittings									
C-11.0	2.05	measure, cut, bend and assemble cable components according to specifications and CEC considering factors such as environment and site conditions										
C-11.0	2.06	position, mount and support components such as fittings, straps and cables according to specifications and CEC										
C-11.0	2.07	tern	ninate c	ables								
Sub-ta	ask											
C-11.0	)3	Ins	talls uı	ndergr	ound c	ables a	nd race	eways.				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>on</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
C-11.0	3.01	ensı	ıre area	is marl	ked by s	supply a	uthorit	ies for e	xisting	utility s	ervices	
C-11.0	3.02				•			as shove	C	•		chers
C-11.0	3.03	dete	ermine i	nstallat	-	uiremen	ts such	as route				
C-11.0	3.04				-			ording to and site	-		and CE	C
C-11.0	3.05	mea com	sure, cu ponent	ıt, bend s accord	and ass	semble i	undergi	round cand CEC	able and	d racew	-	ch as

C-11.0	3.06	install components such as fittings and chair rails for cable and raceway installation												
C-11.0	3.07	-	ition, su cification		-	and mai	rk cable	s and ra	aceways	accord	ing to			
C-11.0	3.08	mar	k and b	ackfill t	renches	accord	ing to s	pecifica	tions ar	nd CEC				
Sub-task														
C-11.0	04	Installs enclosures.												
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	encies												
C-11.04.01 select and use tools and equipment such as levels, measuring tapes and drills														
C-11.0	4.02	determine installation requirements such as location, supports, accessibility and clearances according to specifications and CEC												
C-11.0	4.03	select components according to installation requirements, specifications and CEC												
C-11.0	4.04		oare enc aceways				-			knockou	its for ca	ables		
C-11.0		posi	ition and	d moun	t enclos	sure acc	ording t	to speci	fication	s and C	EC			
C-11.0	4.06	mar	k enclos	sure acc	cording	to speci	fication	s and C	EEC					
Sub-t	ask													
C-11.0	)5	Ins	talls co	nduct	ors in r	aceway	7 <b>S.</b>							
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	encies												
C-11.0	5.01		ct and u		s and eq	uipmer	it such a	as fish t	apes, lir	nesman	pliers, v	wire		
C-11.0	5.02	dera	ermine i ating of CEC		-					<b>5</b> I		0		
C-11.0	5.03		select conductors and materials such as rags, lubricant, polytwine and labels according to specifications and CEC											

C-11.05.04	mark and identify conductors according to specifications and CEC
C-11.05.05	prepare raceways for installation using fish tapes or pull ropes
C-11.05.06	lubricate, feed and draw conductors into raceways according to specifications and CEC

## Task 12 Installs branch circuitry.

#### Context

Various devices and fixtures are installed by construction electricians to meet the power and lighting requirements of the end users. They are installed in a manner which makes the power safe and convenient to use. Lighting systems are used to properly illuminate specified areas according to consumer needs. Lighting controls adjust lighting levels and save power.

K 1	types, functions and applications of luminaires
K 2	types of fasteners
K 3	structure surfaces such as T-bar, concrete and steel
K 4	installation environment and classification
K 5	types of supports such as chains, cables and boxes
K 6	support and protection requirements
K 7	branch circuitry installation procedures related to components such as light posts, branch circuit protection and devices
K 8	types of devices and lighting controls such as relays, dimming systems, photocells, motion sensors and timers
K 9	operation of lighting control systems
K 10	types of light posts such as street lights, traffic lights, bollard lights and parking lights
K 11	uses and requirements of light posts
K 12	types of branch circuit protection such as circuit breakers, fuses and ground fault protection
K 13	conductor sizes and ampacity
K 14	available fault current
K 15	other trades' activities in order to coordinate work completion schedules

Sub-ta	ask												
C-12.0	)1	Ins	talls lu	minai	res.								
<u>NL</u>	<u>NS</u>	PE	<u>NB</u>	<u>QC</u>	<u>on</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	YT	<u>NU</u>	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
Key Competencies													
C-12.0	1.01		select and use tools and equipment such as levels, measuring tapes and light meters										
C-12.0	1.02	dete	ermine c	circuitry	and de	emand l	oad acc	ording	to speci	fication	s and C	EC	
C-12.0	1.03	asse	mble lu	minaire	es accor	ding to	specific	ations					
C-12.0	1.04	-	position, mount and support luminaires to structure according to specifications and CEC										
C-12.0	1.05	-	position, mount and secure seismic restraint systems to structure using material such as aircraft cables, tie wires and chains										
C-12.0	1.06	tern	ninate co	onnecti	ons acco	ording t	o specif	ications	and CI	EC			
C-12.0	1.07	inst	all lamp	s									
Sub-ta	ask												
C-12.0	)2	Ins	talls w	iring d	levices	•							
<u>NL</u>	<u>NS</u>	PE	<u>NB</u>	QC	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	YT	NU	
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV	
J	J	J	J	J	J	J	J	J	J				
Key C	ompete	encies											
C-12.0	2.01		ct and u sman pl		s and eq	luipmer	nt such a	as screw	drivers	, stripp	ers and		
C-12.0	2.02		ermine d	levice c	onfigur	ation ar	nd ratin	gs acco	ding to	specific	cations		
C-12.0	2.03	tern	ninate co	onnecti	ons acco	ording t	o specif	ications	and CI	EC			
C-12.0	2.04	posi	ition and	d moun	t device	es to end	closure						
C-12.0	2.05	sele	select and install faceplates and covers										

Sub-ta	ask											
C-12.0	03	Ins	talls li	ghting	contro	ls.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	ompete	ncies										
C-12.03	3.01	select and use tools and equipment such as screwdrivers, strippers and linesman pliers										
C-12.03	3.02	dete	ermine o	control	compon	ents acc	cording	to spec	ificatior	s and C	CEC	
C-12.03	3.03	dete	ermine o	circuitry	and de	emand l	oad acc	ording t	to speci	fications	s and C	EC
C-12.03	3.04	assemble control components such as time clocks, photo cells and motion sensors										
C-12.03	3.05	position and mount lighting controls										
C-12.03	3.06	tern	terminate connections according to specifications and CEC									
C-12.03	3.07	program lighting controls										
Sub-task Sub-task												
Sub-ta	ask											
C-12.0		Ins	talls li	ght pos	sts.							
		<b>Ins</b> <u>PE</u>	talls lig	ght pos	ots.	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
C-12.0	04		·			MB yes	<u>SK</u> yes	<u>AB</u> yes	BC yes	<u>NT</u> NV	<u>YT</u> NV	<u>NU</u> NV
C-12.0 <u>NL</u> yes	)4 <u>NS</u>	<u>PE</u> yes	<u>NB</u>	<u>QC</u>	<u>ON</u>						· <u> </u>	
C-12.0 <u>NL</u> yes	NS yes ompete	<u>PE</u> yes encies selec	<u>NB</u> yes	QC yes	<u>ON</u> yes		yes	yes	yes	NV	NV	NV
C-12.0  NL yes  Key Co	NS yes ompete	PE yes encies selection fit fa	NB yes ct and unpers abricate	QC yes use tools	ON yes s and eq with co	yes	yes it such a	yes as levels a as cond	yes s, wrenc duit, sle	NV hes and	NV I hydrau	NV alic
NL yes  Key Co	NS yes ompete 4.01 4.02	PE yes encies selection fit fa bolt asse	NB yes  ct and unpers abricate s, studs	QC yes use tools d bases and bro	ON yes s and eq with co	yes Juipmen	yes at such a accordir	yes as levels as cone as cone	yes s, wrenc duit, sle ecificati	NV hes and eves, ar ons and	NV  I hydrau  nchoring	NV alic
NL yes  Key Co C-12.04	NS yes ompete 4.01 4.02 4.03	PE yes encies selection fit fa bolt assee	NB yes  ct and unpers abricate s, studs amble ar alations	QC yes ase tools d bases and bro	ON yes s and eq with co eakaway	yes Juipmen omponer y bolts a	yes  It such a  Its such Iccordir  Iccording t	yes  as levels  as conc  as conc  as to specif	yes s, wrenc duit, sle ecificati fications	NV hes and eves, ar ons and	NV  I hydrau  nchoring	NV alic
NL yes  Key Co C-12.04  C-12.04	NS yes ompete 4.01 4.02 4.03 4.04	PE yes  ncies  selection fit fat bolt assee regu posi	NB yes  ct and unpers abricate s, studs amble ar alations attion, me	QC yes use tools d bases and broad erect	ON yes s and eq with co eakaway light po	yes uipmen omponer y bolts a osts acco	yes  at such a  according to  ag to sp	yes  as levels  as conc  ag to specificat	yes duit, sle ecificati fications	NV hes and eves, ar ons and s and sa	NV I hydrau nchoring I CEC fety	NV alic

0 1		1
<b>411</b>	h_ta	$c \nu$
Ju	b-ta	31

C-12.05 Installs branch circuit protection	C-12.05	Installs	branch	circuit	protection
--	---------	----------	--------	---------	------------

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

C-12.05.01	select and use tools and equipment
C-12.05.02	determine and calculate demand load according to specifications and CEC
C-12.05.03	determine overcurrent protection requirements and components such as fuses and breakers according to manufacturers' enclosure
C-12.05.04	determine special requirements and components such as ground fault circuit interrupters (GFCI) and arc fault breakers according to specifications and CEC
C-12.05.05	position and mount branch circuit protection devices according to specifications and CEC
C-12.05.06	terminate connections according to specifications and CEC
C-12.05.07	update documentation such as panel and maintenance schedule to reflect installation purpose and date according to specifications and CEC

Task 13	Installs heating, ver	ntilation and co	ooling (HVA	C) systems.
---------	-----------------------	------------------	-------------	-------------

#### Context

Construction electricians install and connect electric heating systems. Cooling, ventilation and some heating systems can be supplied by other trades but are electrically connected by construction electricians. They may also be responsible for the installation and wiring of control devices.

K 1	types of electric heating systems
K 2	types of fasteners
K 3	installation environment and classification
K 4	electric heating installation procedures
K 5	heat loss and heat requirement calculations
K 6	types of cooling systems such as refrigeration and air conditioning
K 7	connection procedures
K 8	HVAC system operational requirements

K 9		elec	electrical control devices such as thermostats, sensors and timers												
K 10								oid valv				6			
K 11								equiren		r	J				
								- 1							
Sub-t	ask														
C-13.0	)1	Installs electric heating systems.													
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>			
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV			
Key C	Key Competencies														
C-13.0	C-13.01.01 select and use tools and equipment														
C-13.0	1.02	calculate demand load according to specifications and CEC to select heating system													
C-13.0	1.03	determine branch circuit requirements to select components according to specifications and CEC													
C-13.0	1.04	dete	ermine l	ocation	of insta	allation	accordi	ng to sp	ecificat	ions and	d CEC				
C-13.0	1.05	asse	mble, p	osition	and mo	ount dev	vice								
C-13.0	1.06	tern	ninate c	onnecti	ons acco	ording t	o specií	fications	and C	EC					
Sub-t	ask														
C-13.0	)2	Co	nnects	HVAC	syster	ns.									
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>			
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV			
Kev C	ompete	encies													
C-13.0	-		. المحمد المح	1.			L								
					•	luipmer		ac rurino	ciae er		nt much	a ati a m			
C-13.0	<b>∠.</b> U <b>∠</b>				-			as wire fications			ent prote	ection			
C-13.0	2.03		and disconnect means according to specifications and CEC terminate connections according to specifications and CEC												

$\alpha$ 1		1
<b>611</b>	b-ta	c lz
Ju	v-ta	эл

#### C-13.03 Installs HVAC control systems.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

C-13.03.01	select and use tools and equipment
C-13.03.02	determine installation requirements and components such as thermostats, humidistats and damper motors according to specifications and CEC
C-13.03.03	position, mount, interlock and interconnect electrical control devices according to specifications and CEC
C-13.03.04	calibrate, program and verify control devices

Task 14	Installs emergency	lighting systems.
_ •		

#### Context

Emergency lighting systems are used to facilitate safe egress from buildings during emergency situations. The size and location of lighting systems are determined by building codes. These systems can be powered by batteries or generators.

K 1	types of exit lighting such as self-powered and remote-powered
K 2	building code requirements for spacing and location
K 3	alternating current (AC) and direct current (DC) circuit requirements
K 4	types of fasteners
K 5	installation environment and classification
K 6	types of emergency power supplies such as batteries and generators
K 7	types of battery-operated lighting
K 8	battery types and sizing

Sub-ta	ask											
C-14.0	)1	Ins	talls ex	it ligh	ting.							
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	AB	<u>BC</u>	NT	<u>YT</u>	NU
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
•	•	2	2	J	Ž	,	J	J	Ĭ			
Key Competencies												
C-14.0	1.01	select and use tools and equipment										
C-14.0	1.02	dete	ermine l	ocation	require	ements a	ccordir	ng to sp	ecificati	ons and	I CEC	
C-14.0	1.03		ermine a	nd calc	culate el	ectrical	require	ments a	ccordin	g to spe	ecificatio	ons
C-14.0	1.04	position, mount and assemble exit lighting according to specifications and CEC										
C-14.0	1.05	terminate connections										
C-14.0	1.06	inte	grate ex	it lighti	ing and	emerge	ncy ligł	nting				
Sub-ta	ask											
C-14.0		Ins	talls ba	itterv-	nnerate	d light	ino.					
0 1 10	_				o P o z u o o	· <del></del>	8					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
C-14.02	2.01	sele	ct and u	se tools	s and eq	uipmer	ıt					
C-14.02	2.02	dete	ermine l	ocation	require	ements a	ccordir	ng to sp	ecificati	ons and	l CEC	
C-14.02	2.03				•	ghting r specific	-			attery d	emand	load
C-14.02	2.04	posi	ition, m	ount, as	ssemble	and con	nnect er	nergeno	y light	systems	5	
C-14.02	2.05	adju	ıst and a	aim lun	ninaires	accordi	ng to sp	oecificat	ions an	d CEC		
C-14.02	2.06	inte	grate ex	it lighti	ing and	emerge	ncy ligł	nting				

## BLOCK D

### MOTORS AND CONTROL SYSTEMS

**Trends** Industry demands smaller, more efficient, intelligent and cost-effective

motors and controls. Therefore, construction electricians need to stay

current with this technology as it is continually evolving.

Related Components

(including, but not limited to)

AC and DC motors, starters, overload devices, control devices, push button stations, probes and sensors, actuators, shims, PLCs, VFDs,

computers, software.

Tools and Equipment

See Appendix A.

#### Task 15

#### Installs motor controls and protection.

#### Context

Motors that drive equipment need to be controlled. These controls can be as simple as a switch, or as complex as a PLC. Motors also need to be protected from adverse conditions that affect their performance and longevity. Construction electricians select and install control and protection devices in the motor circuits.

K 1	types of starters such as full voltage, reduced voltage, manual and magnetic starters
K 2	types of enclosures such as dry, wet and hazardous
K 3	types of VFDs and their parameters
K 4	motor specifications and nameplates
K 5	motor sizes, types and characteristics
K 6	line and load conditioning
K 7	harmonics
K 8	types, rating and sizing of overload protection devices
K 9	types, rating and sizing of overcurrent protection devices
K 10	types of motor controls
K 11	system requirements and applications
K 12	control devices such as float and interlock switches

K 13		mul	tiple vo	ltage sy	stems							
K 14		auto	automated control systems									
K 15		inte	interface requirements									
Sub-t	ask											
D-15.0		Inc	Installs starters.									
D-13.	UI	1118	ota115 St	arters.								
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
D-15.0	1.01	dete	ermine t	ype of	starter c	control f	or spec	ific appl	lication			
D-15.0	1.02					on of sta		0				•
		data such as size of motor, full load amps (FLA), service factor and voltage									age	
D-15.0		select and use tools and equipment										
D-15.0		calculate feeder requirements according to specifications and CEC										
D-15.0		mount, assemble and connect starter assembly according to functionality										
D-15.0		set up and adjust starters										
D-15.0	1.07	interconnect starter with cables, raceways and conductors according to specifications and CEC										
		spec	cincatio	ns and	CEC							
Sub-t	ask											
D-15.0	02	Ins	talls va	ariable	freque	ency dr	ives (V	FD).				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
D-15.0	2.01	dete	ermine t	ype of	VFD co	ntrol foi	specifi	c applic	ation			
D-15.0	2.02					on of VF	-			acturers	s' namep	olate
		data	a such a	s size o	f motor,	, FLA ar	nd volta	ige				
D-15.0	2.03	sele	ct and u	se tool	s and ec	quipmer	nt					
D-15.0	2.04				-	ents acco	_	-				U
			line rea		iaitions	such as	sineidi	nig requ	memen	is, iengi	ui Oi Cal	ле
D-15.0	2.05	pos	position, mount and connect VFD									

D-15.0	2.06	calibrate and program VFD according to functionality and established parameters										
D-15.0	02.07	inte	interconnect with required cables, raceways and conductors according to specifications and CEC									to
Sub-t	ask											
D-15.0	03	Ins	talls ov	verload	l prote	ction.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
D-15.0	3.01	calculate overload protection requirements according to manufacturers' motor nameplate data, specifications and CEC									,	
D-15.0	3.02	select and use tools and equipment										
D-15.0	3.03	position, mount and connect overload protection device according to specifications and CEC										
D-15.0	3.04	select and adjust overload protection device according to specifications and CEC								and		
D-15.0	3.05	interconnect with components such as starters, contactors and auxiliary contacts according to specifications and CEC										
Sub-t	ask											
D-15.0	04	Ins	talls au	ıtomat	ed con	trol sys	tems.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
D-15.0	4.01		ct autor				0 1	1	ls such	as start-	-stop sta	itions,
D-15.0	4.02	dete	ermine p	ower s	upply r	equiren	nents fo	r peripl	nerals			
D-15.0	4.03	sele	ct and u	se tools	s and eq	uipmer	ıt					
D-15.0	14.04	-	ition, m							ols and	interfac	e
D-15.0	4.05	write and verify automated control program according to specifications								;		

D-15.04.06	test automated control program and adjust
D-15.04.07	interconnect with required cables, raceways and conductors according to specifications and CEC

Sub-t	ask											
D-15.05 Installs motor overcurrent protection.												
						_						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
D-15.0	5.01				ent requ ecificati			ding to	manufa	cturers'	motor	

	nameplate data, specifications and CEC
D-15.05.02	select overcurrent protection devices and enclosures according to specifications and CEC
D-15.05.03	select and use tools and equipment
D-15.05.04	position, mount and connect overcurrent protection devices according to specifications and CEC
D-15.05.05	interconnect with required cables, raceways and conductors according to specifications and CEC

Task 16	Installs motors.
Context	Construction electricians install motors to convert electrical energy to mechanical energy.

K 1	types of motors such as single-phase, three-phase and DC
K 2	motor applications
K 3	power, starting and duty requirements
K 4	installation environment and classification
K 5	electrical system requirements
K 6	types and sizes of fuses and breakers
K 7	types of motor starters

K 9		selection of required motor rotation										
Sub-t	ask											
D-16.	01	Installs alternating current (AC) motors.										
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>PE NB QC ON MB SK AB BC NT YT 1</u>									<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
•	D-16.01.01 determine type of AC motor required according to criteria such as voltage availability, motor function and location										nge	
D-16.0	1.02	sele	ct and u	se tools	and eq	uipmen	ıt					
D-16.0	1.03		ermine o			accordir	ng to ma	anufactı	ırers' m	otor na	meplate	e data,
D-16.0	1.04	ensi	are that	overloa	nd and o	overcuri	ent dev	ices are	installe	ed to pr	otect m	otor
D-16.0	1.05	fina	lize con	nection	of moto	or leads	accordi	ing to sp	pecifica	tions an	d CEC	
D-16.0	1.06	ensi	are that	control	devices	s are ins	talled fo	or moto	r contro	ols		
D-16.0	1.07	posi	ition and	d moun	t motor	•						
D-16.0	1.08	veri	fy rotati	ion to e	nsure o	peratior	ı					
D-16.0	1.09	_	n and ir ipressor		nect mo	tor to ec	quipmei	nt such	as blow	ers, pui	mps and	i
D-16.0	01.10		rconnec cification		-	l cables,	racewa	iys and	conduc	tors acc	ording	to
Sub-t	ask											
D-16.	02	Ins	talls di	rect cu	rrent (	DC) mo	otors.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
D-16.0	2.01			J I		or requi n and lo		ording	to criter	ia such	as volta	ige
D-16.0	availability, motor function and location .02.02 select and use tools and equipment											

types of conductors

K 8

D-16.02.03	determine conductor size according to manufacturers' motor nameplate data, specifications and CEC
D-16.02.04	ensure that overload and overcurrent devices are installed to protect motor
D-16.02.05	finalize connection of conductors within motor circuit according to specifications and CEC
D-16.02.06	ensure that control devices are installed for motor controls
D-16.02.07	position and mount motor
D-16.02.08	verify rotation to ensure operation
D-16.02.09	align and connect motor to equipment for commercial, industrial and manufacturing applications
D-16.02.10	interconnect with required cables, raceways and conductors according to specifications and CEC

## BLOCK E

# SIGNALLING AND COMMUNICATION SYSTEMS

#### **Trends**

The industry is increasingly moving towards the use of communication systems and away from signalling systems. The automation of building operation functions is becoming more sophisticated. Satellite radio and television is becoming more common, reducing the need for land-based communication systems.

Related Components (including, but not Conductors, cables, raceways, racks, panels, enclosures.

Tools and Equipment

limited to)

See Appendix A.

## Task 17

#### Installs signalling systems.

#### Context

Construction electricians install signalling systems which allow for the protection and management of people and property. These types of systems may be low voltage circuit or extra low voltage circuit.

K 1	codes and regulations applying to fire alarm system installation
K 2	types and components of fire alarm systems
K 3	wiring methods
K 4	manufacturers' specifications
K 5	ancillary devices and circuits such as fan shut down, elevator recall and door release
K 6	types and components of nurse call systems
K 7	types of security systems such as card access, door access and intrusion
K 8	types of surveillance systems such as video, motion and heat
K 9	operating principles of signalling systems

Sub-t	ask											
E-17.0	)1	Ins	talls fi	re aları	m syste	ems.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	encies										
E-17.0	1.01	sele	ct and u	se tools	s and eq	uipmer	ıt					
E-17.0	1.02				m syste /stems a	-					ınd	
E-17.0	1.03		ermine s ding Co	•	layout a BC)	ccordin	g to spe	ecificatio	ons, CE	C and tl	ne Natio	onal
E-17.0	1.04		ct syste n/strobe	-	onents	such as	fire ala	rm pan	els, heat	t sensor	s and	
E-17.0	1.05	-	position, mount and assemble system components according to specifications and CEC									
E-17.0	1.06		terminate and interconnect components and associated systems according to specifications and CEC									
E-17.0	1.07	grou	and and	l bond a	accordir	ng to spe	ecificati	ons and	CEC			
Sub-t	1											
	asĸ											
E-17.0		Ins	talls n	urse ca	11 syste	ms.						
E-17.0 <u>NL</u>		<u>Ins</u>	talls no	urse ca <u>QC</u>	ll syste	ms. <u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
	)2				•		<u>SK</u> yes	AB yes	<u>BC</u> yes	<u>NT</u> NV	<u>YT</u> NV	<u>NU</u> NV
<u>NL</u> yes	)2 <u>NS</u>	<u>PE</u> yes	<u>NB</u>	<u>QC</u>	<u>on</u>	<u>MB</u>		· <u></u>	· <u></u>		·	
<u>NL</u> yes	NS yes ompete	PE yes	<u>NB</u> yes	<u>QC</u> yes	<u>on</u>	MB yes	yes	· <u></u>	· <u></u>		·	
NL yes <b>Key</b> C	NS yes ompete	PE yes encies sele dete	NB yes ct and uermine r	OC yes use tools	ON yes	MB yes uipmer m requi	yes ut rements	yes s such a	yes s audib	NV	NV	
NL yes <b>Key C</b> E-17.02	NS yes compete 2.01 2.02	PE yes encies sele dete com	NB yes ct and uermine rabination	OC yes use tools nurse ca n accord	ON yes s and eq	MB yes uipmer m requi	yes at rements ations a	yes s such a nd CEC	yes s audib	NV NV	NV	
NL yes <b>Key C</b> E-17.02	NS yes compete 2.01 2.02	PE yes encies seled detection detection	NB yes ct and uermine relationships sermine se	QC yes use tools nurse ca n accore	ON yes s and equall system	MB yes uipmer n requi specifica	yes  It  rements ations a g to spe	yes s such a nd CEC	yes s audib ons and	NV le, visua CEC	NV	NV
NL yes <b>Key C</b> E-17.02 E-17.02	NS yes compete 2.01 2.02 2.03 2.04	PE yes encies sele dete com dete sele posi	NB yes  ct and usermine relationships ermine sect system	QC yes use tools nurse ca n accord system I	ON yes s and eq all system ding to a	MB yes  uipmer m requi specifica ccordin such as	yes  trements ations a g to spe switche	yes s such a nd CEC ecifications, push	yes s audib ons and button	NV le, visua CEC s and p	NV al or	NV
NL yes Key C E-17.02 E-17.02 E-17.02	NS yes compete 2.01 2.02 2.03 2.04 2.05	PE yes encies sele dete com dete sele posi and term	NB yes  ct and usermine relabination ermine sermine se	OC yes use tools nurse can n accord system m comp ount an	ON yes s and equall system ding to selected assented asonted assented assented assented assented assented assented assen	MB yes  uipmer m requi specifica ccordin such as nble sys	yes  tements ations a g to spe switche tem cor	yes s such a nd CEC ecification es, push mponen	yes s audib ons and button ts accor	NV le, visua CEC s and p ding to	NV al or ull cord	NV seations

Sub-task												
E-17.0	13	Installs security and surveillance systems.										
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	Key Competencies											

E-17.03.01	select and use tools and equipment such as coaxial cable terminating tools and crimpers
E-17.03.02	determine security and surveillance system requirements according to specifications and CEC
E-17.03.03	determine system layout according to specifications and CEC
E-17.03.04	select system components such as cameras, monitors, digital video recorders (DVR) and motion sensors
E-17.03.05	position, mount and assemble system components according to specifications and CEC
E-17.03.06	terminate and interconnect components and associated systems according to specifications and CEC

Task 18	Installs communication systems.
Context	Communication systems allow information to be transmitted from one point to another, using different methods and materials such as fibre optic, category class and coaxial cables. These types of systems may be low voltage power circuit, extra low voltage power circuit or low energy power circuit.
	7 81

K 1	types of cables such as fibre optic, category class and coaxial
K 2	installation standards according to specifications and CEC
K 3	manufacturers' specifications such as bend radius, jacket stripping and splicing
K 4	types of communication signals such as analog and digital
K 5	types of public address (PA) systems
K 6	community antenna distribution, and radio and television equipment
K 7	types of building automation systems such as energy management systems, integrated building systems and smart buildings

K 8		com	ponent	s of buil	lding au	ıtomatio	on syste	ms sucl	n as cab	les and	sensors	
K 9			test equipment such as optical time-domain reflectometer (OTDR) testers and data testers									
K 10		Clas	Class 1 and 2 circuitry									
Sub-ta	ask											
E-18.0	1	Ins	talls vo	oice/da	ta syste	ems.						
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
E-18.01	1.01		ct and u		s and eq	uipmer	nt such a	as cable	termina	ating to	ols, netv	work
E-18.03	1.02	dete CEC		voice/da	ata syste	em requ	iremen	ts accor	ding to	specific	ations a	nd
E-18.01	1.03	dete	ermine s	system l	ayout a	ccordin	g to spe	ecificatio	ons and	CEC		
E-18.0	1.04	sele	ct syste	m comp	onents	such as	ports, 1	outers a	and mo	nitors		
E-18.01	1.05	-	position, mount and assemble system components according to specifications and CEC									
E-18.01	1.06		ninate a		rconnec CEC	t compo	onents a	nd asso	ciated s	systems	accordi	ng to
E-18.0	1.07	test	and lab	el syste	m comp	onents,	and do	ocumen	t results	;		
Sub-ta	ask											
E-18.0	2	Ins	talls pı	ublic a	ddress	(PA) sy	ystems	•				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
E-18.02	2.01	sele	ct and u	se tools	s and eq	uipmer	nt					
E-18.02	2.02	dete	ermine I	PA syste	em requ	iremen	ts accor	ding to	specific	ations a	and CEO	
E-18.02	2.03	dete	ermine s	system l	ayout a	ccordin	g to spe	ecificatio	ons and	CEC		
E-18.02	2.04	sele	ct systei	m comp	onents	such as	speake	rs, micr	ophone	s and co	ontrol u	nits

E-18.02.05	position, mount and assemble system components according to specifications and CEC
E-18.02.06	terminate and interconnect components and associated systems according to specifications and CEC

E-18.03 Installs community antenna distribution, and radio and television systems.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

E-18.03.01	select and use tools and equipment
E-18.03.02	determine system requirements according to specifications and CEC
E-18.03.03	determine system layout according to specifications and CEC
E-18.03.04	select system components such as broadcast transmitters, receiving equipment, noise suppressors and satellite dishes
E-18.03.05	position, mount and assemble system components according to specifications and $\ensuremath{CEC}$
E-18.03.06	terminate and interconnect components and associated systems according to specifications and CEC
E-18.03.07	ground and bond according to specifications and CEC

Task 19	Installs integrated	control systems.
		J

#### Context

Integrated control systems and building automation systems involve connecting building components through a computerized system in order to achieve automated control over systems such as HVAC, lighting and security systems.

#### Required Knowledge

K 1	types of cables such as category 6 (CAT-6), fibre optic and RG 6 coaxial
K 2	installation standards
K 3	manufacturers' specifications such as bend radius, terminating methods and pull tensions

K 4		type	os of cor	nmunic	ention et	andardi	e euch a	e analo	r and d	igital		
K 5			types of communication standards such as analog and digital types of PA and intercom systems									
K 6		<i>J</i> 1	community antenna distribution, and radio and television equipment									
K 7			types of building automation systems such as energy management systems,									∘ms
107				_		-			216y 1110	anagem	cite by be	emo,
K 8		integrated building systems and smart buildings components of building automation systems such as cables, sensors and controllers								I		
Sub-ta	ask											
E-19.0	1	Ins	talls b	uilding	g auton	nation s	system	s.				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
E-19.01	1.01	select and use tools and equipment such as data punch down, toner and soft wraps										
E-19.0	1.02	determine system requirements and compatibility with the building management system according to specifications and CEC										
E-19.0	1.03	dete	ermine s	system l	layout a	ccordin	g to spe	ecificatio	ons and	CEC		
E-19.0	1.04	sele	ct syste	m comp	onents	such as	fibre bo	oards, s	ensors a	and cabl	les	
E-19.0	1.05	posi	tion, m	ount an	d assen	nble sys	tem con	nponen	ts			
E-19.0	1.06	terminate and interconnect components and associated systems according to specifications and CEC							ng to			
E-19.0	1.07	prog	gram sy	stem ac	cording	to spec	cificatio	ns				
Sub-ta	ask											
E-19.0	2	Ins	talls b	uilding	g contro	ol syste	ems.					
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key C	ompete	ncies										
E-19.02	2.01	sele	ct and u	se tools	s and eq	uipmer	nt					
E-19.02		dete	ermine s	system 1	requirer		nd comp	-	-	the build	ding	

E-19.02.03	determine system layout according to specifications and CEC
E-19.02.04	select system components such as damper motors, valves, thermostats and sensors
E-19.02.05	position, mount and assemble system components
E-19.02.06	terminate and interconnect components and associated systems according to specifications and CEC
E-19.02.07	program system according to specifications

## BLOCK F

# UPGRADING, SERVICE AND MAINTENANCE

**Trends** Predictive maintenance using equipment such as infrared detection and

specialized test equipment is becoming more common. Therefore, construction electricians are becoming more efficient regarding the diagnostic process, improving their ability to prevent system downtime

and equipment failure.

Related

Components

All components apply.

Tools and **Equipment** 

See Appendix A.

#### Task 20

#### Upgrades electrical systems.

#### Context

Construction electricians are required to be familiar with electrical systems and the options that are available to upgrade and improve them. Reasons for upgrading include meeting the customer's requirements such as comfort, cost saving, environmental factors and convenience.

#### Required Knowledge

K 1	system components such as MCCs, transformers, panel boards and splitters
K 2	types of electrical systems and their use
K 3	building system operations such as HVAC, fire alarms and control systems
K 4	service calculation and demand factors
K 5	code rules and jurisdictional regulations
K 6	removal and disposal procedures
K 7	design changes to electrical systems
K 8	de-energizing, lock-out, tag-out and system testing procedures

Sub-ta	ask											
F-20.0	1	Eva	luates	existin	g elect	rical sy	stems.	•				
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	ompete	ncies										
F-20.01	1.01	sele	ct and u	se tools	and eq	uipmen	ıt					
F-20.01	.02	dete	rmine e	xisting	electrica	al instal	lation a	nd asse	ss comp	atibilit	y for red	quired
		char	nges acc	ording	to speci	fication	s and C	CEC				
F-20.01	.03	dete	ermine u	ıpgrade	s to me	et speci	fication	s and C	EC			
F-20.01	.04	list 1	upgrade	option	s to clie	nt						
<u> </u>	1											
Sub-ta	ask											
F-20.0	2	Rej	places e	electric	al syste	ems an	d equi	pment	,			
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV
Key Co	ompete	ncies										
F-20.02	2.01	sele	ct and u	se tools	and eq	uipmen	ıt					
F-20.02	2.02	determine electrical system and equipment requirements according to										
F-20.02	0.02	-	specifications and CEC									
Γ-20.02	2.03	determine layout for equipment or system to be replaced according to specifications and CEC										
F-20.02	2.04	select system components to be installed										
F-20.02	2.05	rem	ove exis	ting co	mponer	nts and	dispose	accord	ing to s	pecificat	tions	
F-20.02	2.06	-	tion, mo					ect repla	icement	compo	nents	
F-20.02	2.07	-	ate requ						_	ams, an	d	

Task 21	Services electrical systems
I usk ZI	Services electrical systems

#### **Context** Construction electricians respond to service demands from clients. They

diagnose and repair defective components to maintain operation of all electrical systems. Construction electricians need to return equipment to operation in a timely manner.

#### Required Knowledge

K 1	types of electrical systems
K 2	electrical system design and operation
K 3	diagnostic techniques
K 4	schematic, diagrams and specifications
K 5	electrical components and supply availability
K 6	organizational and planning skills
K 7	de-energizing, lock-out, tag-out and system testing procedures

#### Sub-task

#### F-21.01 Diagnoses electrical systems.

<u>NL</u>	<u>NS</u>	$\underline{PE}$	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV

#### **Key Competencies**

F-21.01.01	obtain detailed description of the malfunction from client to assist in diagnosis
F-21.01.02	select and use tools and equipment
F-21.01.03	conduct field assessment such as a sensory and technical inspections using devices such as multimeters and voltage testers
F-21.01.04	determine source of malfunction based on field assessment
F-21.01.05	determine course of action

#### Sub-task

#### F-21.02 Repairs electrical components.

<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>
yes	NV	NV	NV									

#### **Key Competencies**

F-21.02.01	select and use tools and equipment
F-21.02.02	recognize defective electrical components
F-21.02.03	select equivalent replacement components
F-21.02.04	remove defective components
F-21.02.05	install replacement components with minimal disruptions and interruptions
F-21.02.06	clean, lubricate and adjust components
F-21.02.07	record and update documentation to reflect repair

## Task 22 Maintains electrical systems.

## **Context** Maintenance requires the construction electrician to establish and follow a


schedule that predicts and prevents potential failures.

#### Required Knowledge

K 1	system design and sequence of operations
K 2	cleaners and lubricants
K 3	operation of equipment
K 4	equipment being maintained
K 5	manufacturers' specifications
K 6	customer requirements
K 7	environmental conditions
K 8	safety requirements

Sub-task														
F-22.0	1	Im	plemer	nts mai	ntenan	ce sch	edule.							
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	<u>NT</u>	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies												
F-22.0	1.01	dete	ermine r	nainten	ance re	quireme	ents acc	ording	to speci	fication	s			
F-22.01.02 create maintenance schedule based on maintenance requiremen														
F-22.0	1.03	follow maintenance schedule												
F-22.0	1.04	record and update maintenance schedule data												
Sub-t	ask													
	Sub-task F-22.02 Tests system operation.													
Γ <b>-</b> ΖΖ <b>.</b> U	F-22.02 Tests system operation.													
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key C	ompete	ncies												
F-22.02	2.01		ct and u tachom		s and eq	uipmer	nt such a	as infrai	red cam	eras, lu	men me	eters		
F-22.02	2.02	cone	duct tes	ts accor	ding to	mainte	nance s	chedule	and sp	ecificati	ons			
F-22.02	2.03	record test results in maintenance schedule												
F-22.02	2.04		-	-			U	-	tential s	system o	peratio	n		
		prol	olems fr	om ma	intenan	ce sched	dule dat	a						
Sub-ta	ask													
F-22.0	3	Ma	intains	s electr	ical coı	mpone	nts.							
						•								
<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	<u>SK</u>	<u>AB</u>	<u>BC</u>	NT	<u>YT</u>	<u>NU</u>		
yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	NV	NV	NV		
Key Competencies														
F-22.03	3.01	sele	ct and 11	se tool	s and eo	uipmer	nt							
F-22.03		select and use tools and equipment follow maintenance schedule according to specifications												
							0	r						

F-22.03.03	select and apply cleaners
F-22.03.04	select and apply lubricants
F-22.03.05	carry out mechanical and electrical adjustments such as re-torquing of lugs and testing of battery packs
F-22.03.06	record and update maintenance schedule data



## APPENDIX A

#### TOOLS AND EQUIPMENT

#### **Standard Tools**

adjustable wrench measuring tape

awl needle nose pliers

cable cutter nut drivers
camera pipe benders
caulking gun pipe cutters
centre punch pipe threader
chalk line pipe wrench

cold chisel reamers (EMT and rigid)

combination square screwdrivers – Robertson, Phillips, torx, flat,

combination wrench set tamper-proof crimping pliers side/diagonal cutters

crowbar slip joint pliers drill bits socket set files speed wrench fish tape tap and die set

flashlight tin snips
fuse puller tool belt
hack saw tool bucket
hammers torpedo level
hex key set triple tap
keyhole saw trouble light

knives vise

knockout cutter wire strippers linesman pliers wood chisel

#### **Access Equipment**

articulated boom lift scaffolds (rolling, mechanical, stationary,

boom lifts ladder jack)

construction elevator scissor lift

ladders (extension, fixed, step) swing stage

lift table

#### Personal Protective Equipment and Safety Equipment

arc flash equipment lanyard
barricades life line
confined space equipment lock-out kit
coveralls (fire retardant) portable light

ear plugs and muffs pylons eye wash facilities respirator face shield restraint device fall arresters rope grab fire blanket safety belt fire extinguisher safety boots first aid equipment safety glasses safety harness fume and toxic gas detector safety vest gloves

goggles self contained breathing apparatus

grounding straps signage

hard hat ventilation equipment

insulated gloves warning tape

knee pads

#### **Power Tools and Equipment**

band saws magnetic drill

battery/rechargeable drill pneumatic hammer drill bench grinder power cable feeders

chop saw power drill

circular saw power pipe bender core drill press power pipe cutters power pipe threader

grinder power puller
heat gun power reel lift
hammer drill PVC bender
hole saw kit reciprocating saw

hydraulic bender sump pump

hydraulic crimper tugger jig saw vacuum

#### **Specialty Tools and Equipment**

chain falls portable generator come-along powder-actuated tools

communication devices (cellphones and reel jacks 2-way radio) rope creepers and crawlers shackles extension cords shovels

grip hoist sledgehammer

hot stick slings

inverters spud wrench

knock-out punch soldering apparatus laser level strain relief grips

manual hoist thermit (thermal) welder

picks torque wrench pneumatic hoist wire rack

#### **Measuring Equipment**

ammeter multimeter

cable locator optical time-domain reflectometer (OTDR)

clamp ammeter ohmmeter fault locator oscilloscope

frequency meter phase rotation meter

ground megohmmeter recording meter (watts, volts and amps)

hi-pot tester (dielectric tester) tachometer

inductive voltage detector thermographic imaging camera

insulation resistance meter thermometer (infra red and electronic)

jumpers ultrasonic testing equipment

LAN meter (cable analyser) voltage tester light meter voltmeter watt meter watt meter

motor rotation meter

## APPENDIX B

#### **GLOSSARY**

**ancillary** functions performed by the fire alarm system as an output of the fire alarm

system, controlled by a relay or similar device, for example, elevator recall,

fan shut down and door release

bonding a low impedance path obtained by permanently joining all non-current-

carrying metal parts to assure electrical continuity and having the capacity

to conduct safely any current likely to be imposed on it

cathodic protection

technique to control the corrosion of a metal surface by making that

surface the cathode of an electrochemical cell

extra low voltage any voltage up to and including 30 volts

**grounding** a permanent and continuous conductive path to the earth with sufficient

ampacity to carry any fault current liable to be imposed on it, and of a sufficiently low impedance to limit the voltage rise above ground and to

facilitate the operation of the protective devices in the circuit

low energy

power circuit

a circuit where the power is limited to 100/V Amperes where V is the open

circuit voltage

**luminaires** a complete lighting unit designed to accommodate the lamp(s) and to

connect the lamp(s) to circuit conductors, for example, florescent, High

Intensity Discharge (HID) and incandescent

raceway any channel designed for holding wires, cables, or busbars, and, unless

otherwise qualified by rules of the CEC, the term includes conduit (rigid,

flexible, metal, non-metallic) electrical, metallic and nonmetallic,

underfloor raceway, cellular floors, surface raceways, wireways, cable

trays, busways, and auxiliary gutters

seismic

restraint system a restraint or support system designed to prevent non-structural

components from moving during an earthquake

**specifications** an explicit set of requirements to be satisfied by a material, product or

service including but not limited to local and national building codes, any documentation that holds legal obligations, schematics, manufacturers specs, local code, provincial/federal authority, engineered drawings and diagrams and schematics, customer requirements, warranty documents,

site drawings, shop drawings, company requirements

**voltage** any voltage exceeding 30 but not exceeding 750

system, low

**voltage** any voltage exceeding 750 volts

system, high

## APPENDIX C

### **ACRONYMS**

**3D** three dimensional

**AC** alternating current

**CAT-6** category 6 cable

**CDP** central distribution panel

CEC Canadian Electrical Code

**CSA** Canadian Standards Association

CT current transformer

DC direct current

**DVR** digital video recorder

**FLA** full load amp

**GFCI** ground fault circuit interrupter

HID high intensity discharge

**HRC** high rupture capacity

**HVAC** heating, ventilation and cooling

**LEED** Leadership in Energy and Environmental Design

**LED** light emitting diode

MCC motor control center

MSDS material safety data sheet

**NBC** National Building Code

**NFPA** National Fire Protection Association

OH&S Occupational Health and Safety

PA public address

PLC programmable logic controller

**PPE** personal protective equipment

**PT** potential transformer

TDG transportation of dangerous goods

**UPS** uninterruptible power supply

VA volt-amperes

**VFD** variable frequency drive

WHMIS Workplace Hazardous Materials Information System

# APPENDIX D

### **BLOCK AND TASK WEIGHTING**

#### BLOCK A COMMON OCCUPATIONAL SKILLS

%	<u>NL</u> 12	<u>NS</u> 12	<u>PE</u> 10	<u>N</u>		<u>QC</u> 25	<u>ON</u> 12	<u>M</u> 15			<u>AB</u> 15	BC 15	<u>N</u>		<u>(T</u> JV	NU NV	National Average 14%
																	14 /0
	Task	1	Perf	orms	s saf	ety-r	elate	d fun	ction	s.							
		%	<u>NL</u> 20	<u>NS</u> 20	<u>PE</u> 20	<u>NB</u> 16	<u>QC</u> 20	<u>ON</u> 50	MB 15	<u>SK</u> 20	<u>AB</u> 20		NT NV				23%
	Task 2	2	Uses	s and	l ma	intai	ns to	ols ar	nd eq	uipr	nent.						
		%	<u>NL</u> 20		<u>PE</u> 20	<u>NB</u> 17	<u>OC</u> 5	<u>ON</u> 8	MB 40	<u>SK</u> 10	<u>AB</u> 20		<u>NT</u> NV				18%
	Task 3	3	Org	anize	es w	ork.											
		%	<u>NL</u> 20	<u>NS</u> 20	<u>PE</u> 20	<u>NB</u> 23	<u>QC</u> 20	<u>ON</u> 17	<u>MB</u> 15		<u>AB</u> 27		NT NV				20%
	Task 4	4	Fabi	ricate	es ar	nd ins	stalls	supp	ort c	omp	oner	ıts.					
		%	<u>NL</u> 20		<u>PE</u> 20			<u>ON</u> 8	MB 20		<u>AB</u> 20		NT NV				19%
	Task 5	5	Con	nmis	sion	s and	l dec	omm	issioı	ns ele	ectrio	cal sy	sten	ıs.			
		%		<u>NS</u> 20	<u>PE</u> 20	<u>NB</u> 18	<u>QC</u> 35	<u>ON</u> 17	<u>MB</u> 10	<u>SK</u> 25	<u>AB</u> 13		NT NV				20%

#### BLOCK B SYSTEMS, DISTRIBUTION AND SERVICES

%	<u>NL</u> 25	<u>NS</u> 25	<u>PE</u> 20	<u>N</u> 23		<u>QC</u> 25	<u>ON</u> 24	<u>Ml</u> 25		<u>K</u> 5	<u>AB</u> 25	BC 20	N'		<u>T</u> IV	<u>NU</u> NV	National Average 24%
	Task 6 Installs service entrance and distribution equipment.																
	Task		30	25	25	32	30	ON 21 nding	40	40	28	15	NV	NV	NV	7	29%
		%	<u>NL</u> 30		<u>PE</u> 18	<u>NB</u> 22	<u>OC</u> 20	<u>ON</u> 42	MB 25	<u>SK</u> 20			<u>NT</u> NV				26%
	Task 8 Installs power generation systems.																
		%				<u>NB</u> 15		<u>ON</u> 12	MB 10	<u>SK</u> 15			NT NV				14%
	Task	9	Inst	alls h	nigh	volta	ige sy	stem	ıs.								
		%	<u>NL</u> 10	<u>NS</u> 10	<u>PE</u> 17	<u>NB</u> 12	<u>QC</u> 10	<u>ON</u> 8	MB 10	<u>SK</u> 10			<u>NT</u> NV				12%
	Task	10	Inst	alls t	rans	form	ers.										
		%	<u>NL</u> 20	<u>NS</u> 25	<u>PE</u> 25	<u>NB</u> 19	<u>QC</u> 20	<u>ON</u> 17	MB 15	<u>SK</u> 15			NT NV				19%
BLO	ЭСК С	2	WIR	ING	ME	тнс	DDS										
																	National

	<u>NL</u>	NS	PE	<u>NB</u>	<u>QC</u>	ON	MR	SI/	ΛR	RC	<u>NT</u>	VT	<u>NU</u>	National
	IVL	113	<u>1 L:</u>	IND	<u>QC</u>	$\overline{OIN}$	WID	<u> 31C</u>	AD	<u>bC</u>	<u> 1 N 1</u>	11	110	Average
%	25	26	25	26	20	23	20	35	25	32	NV	NV	NV	25%

Task 11 Installs raceways and cables.

NL NS PE NB QC ON MB SK AB BC NT YT NU 33%

Task 12	Inst	Installs branch circuitry.													
%	<u>NL</u> 40	<u>NS</u> 40	<u>PE</u> 30	<u>NB</u> 33	<u>QC</u> 30	<u>ON</u> 35	<u>MB</u> 35	<u>SK</u> 40	<u>AB</u> 32		<u>NT</u> NV			_	36%
Task 13	Inst	alls h	neati	ng, v	entil	ation	and	cooli	ng (l	HVA	C) s	yster	ns.		
%	<u>NL</u> 20	<u>NS</u> 10	<u>PE</u> 25	<u>NB</u> 19	<u>QC</u> 20	<u>ON</u> 9	MB 10	<u>SK</u> 15	<u>AB</u> 20		<u>NT</u> NV			_	16%
Task 14 Installs emergency lighting systems.															
%	<u>NL</u> 10	<u>NS</u> 20	<u>PE</u> 20	<u>NB</u> 14	<u>QC</u> 20	<u>ON</u> 13	<u>MB</u> 15	<u>SK</u> 15	<u>AB</u> 16		NT NV		<u>NU</u> NV		15%
BLOCK D MOTORS AND CONTROL SYSTEMS															
<u>NL</u> <u>NS</u>	<u>PE</u>	<u>N</u>	<u>B</u> (	QC	<u>ON</u>	<u>M</u>	<u>B</u> <u>S</u>	<u>K</u> .	<u>AB</u>	<u>BC</u>	<u>N'</u>	<u>Γ Υ</u>	<u>/T</u>	<u>NU</u>	National Average

Task 15 Installs motor controls and protection.
---

20

18

15

20

20

15

NV

NV

NV

SK AB BC NT YT NU 63% % 60 60 60 65 55 70 65 75 NV NV NV 56 60

16%

#### Task 16 Installs motors.

15

14

10

10

NL NS PE NB QC ON MB SK AB BC NT YT NU 37% % 40 40 40 35 30 35 25 NV NV NV 45 44 40

#### SIGNALLING AND COMMUNICATION SYSTEMS **BLOCK E**

	<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	<u>ON</u>	<u>MB</u>	SK	AB	BC	NT	<u>YT</u>	<u>NU</u>	National
%	12	15	15		5		5	5	10	10	NV	NV	NV	Average
/0	13	13	13	9	3	11	3	3	10	10	1 <b>N V</b>	INV	INV	10%

#### Task 17 Installs signalling systems.

NL NS PE NB QC ON MB SK AB BC NT YT NU 42% % 50 30 30 32 45 45 33 60 40 50 NV NV NV

NL NS PE NB QC ON MB SK AB BC NT YT NU % 20 50 30 46 20 10 33 25 30 10 NV NV NV 27%

Task 19 Installs integrated control systems.

NL NS PE NB QC ON MB SK AB BC NT YT NU 31%

#### BLOCK F UPGRADING, SERVICE AND MAINTENANCE

	<u>NL</u>	<u>NS</u>	<u>PE</u>	<u>NB</u>	<u>QC</u>	ON	<u>MB</u>	<u>SK</u>	AB	ВС	NT	<u>YT</u>	<u>NU</u>	National Average
%	15	12	15	14	5	12	20	5	5	8	NV	NV	NV	11%

#### Task 20 Upgrades electrical systems.

NL NS PE NB QC ON MB SK AB BC NT YT NU 37%

Task 21 Services electrical systems.

NL NS PE NB QC ON MB SK AB BC NT YT NU
% 35 30 30 36 40 33 25 30 40 50 NV NV NV


Task 22 Maintains electrical systems.

NL NS PE NB QC ON MB SK AB BC NT YT NU

30 20 30 28 30 34 25 20 40 20 NV NV NV

28%

## APPENDIX E



#### TITLES OF BLOCKS

BLOCK A	Common Occupational Skills	BLOCK D	Motors and Control Systems
BLOCK B	Systems, Distribution and Services	BLOCK E	Signalling and Communication Systems
BLOCK C	Wiring Methods	BLOCK F	Upgrading, Service and Maintenance

<sup>\*</sup>Average percentage of the total number of questions on an interprovincial examination, assigned to assess each block of the analysis, as derived from the collective input from workers within the occupation from all areas of Canada. Interprovincial examinations typically have from 100 to 150 multiple-choice questions.

# TASK PROFILE CHART — Construction Electrician

BLOCKS	TASKS		:	SUB-TASKS	5	
A - COMMON OCCUPATIONAL SKILLS	1. Performs safety-related functions.	1.01 Uses personal protective equipment (PPE) and safety equipment.	1.02 Maintains safe work environment.	1.03 Performs lock-out and tagging procedures.		
	2. Uses and maintains tools and equipment.	2.01 Maintains tools and equipment.	2.02 Uses access equipment.	2.03 Uses rigging, hoisting and lifting equipment.		
	3. Organizes work.	3.01 Interprets plans, drawings and specifications.	3.02 Organizes materials and supplies.	3.03 Plans project tasks and procedures.	3.04 Prepares work site.	3.05 Finalizes required documentation.
	4. Fabricates and installs support components.	4.01 Fabricates support structures.	4.02 Installs brackets, hangers and fasteners.	4.03 Installs seismic restraint systems.		
	5. Commissions and decommissions electrical systems.	5.01 Performs start-up and shut- down procedures.	5.02 Conducts operational tests.			
B - SYSTEMS, DISTRIBUTION AND SERVICES	6. Installs service entrance and distribution equipment.	6.01 Installs consumer/supply services.	6.02 Installs metering systems.	6.03 Installs overcurrent protection.	6.04 Installs power distribution centres.	6.05 Installs temporary power.
		6.06 Installs surge suppression systems.	6.07 Installs power conditioning systems.	6.08 Installs uninterruptible power supply (UPS) systems.	6.09 Installs panels and sub-panels.	

BLOCKS	TASKS		SUB-TASKS									
	7. Installs bonding, grounding and cathodic protection systems.	7.01 Installs grounding systems.	7.02 Installs bonding conductors.	7.03 Installs ground fault protection systems.	7.04 Installs lightning arresters.	7.05 Installs cathodic protection systems.						
	8. Installs power generation systems.	8.01 Installs generators and transfer switches.	8.02 Installs alternative power systems.									
	9. Installs high voltage systems.	9.01 Installs high voltage equipment.	9.02 Installs high voltage cables.	9.03 Terminates high voltage cables.	9.04 Tests high voltage systems.							
	10. Installs transformers.	10.01 Installs extra low voltage transformers.	10.02 Installs low voltage transformers.	10.03 Installs high voltage transformers.								
C - WIRING METHODS	11. Installs raceways and cables.	11.01 Installs raceways.	11.02 Installs cables.	11.03 Installs underground cables and raceways.	11.04 Installs enclosures.	11.05 Installs conductors in raceways.						
	12. Installs branch circuitry.	12.01 Installs luminaires.	12.02 Installs wiring devices.	12.03 Installs lighting controls.	12.04 Installs light posts.	12.05 Installs branch circuit protection.						
	13. Installs heating, ventilation and cooling (HVAC) systems.	13.01 Installs electric heating systems.	13.02 Connects HVAC systems.	13.03 Installs HVAC control systems.								
	14. Installs emergency lighting systems.	14.01 Installs exit lighting.	14.02 Installs battery-operated lighting.									

BLOCKS	TASKS			SUB-TASKS	6	
D - MOTORS AND CONTROL SYSTEMS	15. Installs motor controls and protection.	15.01 Installs starters.	15.02 Installs variable frequency drives (VFD).	15.03 Installs overload protection.	15.04 Installs automated control systems.	15.05 Installs motor overcurrent protection.
	16. Installs motors.	16.01 Installs alternating current (AC) motors.	16.02 Installs direct current (DC) motors.			
E - SIGNALLING AND COMMUNICA- TION SYSTEMS	17. Installs signalling systems.	17.01 Installs fire alarm systems.	17.02 Installs nurse call systems.	17.03 Installs security and surveillance systems.		
	18. Installs communication systems.	18.01 Installs voice/data systems.	18.02 Installs public address (PA) systems.	18.03 Installs community antenna distribution, and radio and television systems.		
	19. Installs integrated control systems.	19.01 Installs building automation systems.	19.02 Installs building control systems.			
F - UPGRADING, SERVICE AND MAINTENANCE	20. Upgrades electrical systems.	20.01 Evaluates existing electrical systems.	20.02 Replaces electrical systems and equipment.			
	21. Services electrical systems.	21.01 Diagnoses electrical systems.	21.02 Repairs electrical components.			
	22. Maintains electrical systems.	22.01 Implements maintenance schedule.	22.02 Tests system operation.	22.03 Maintains electrical components.		