

# RESEARCH REPORT



## Demonstration of Duct Installation in Houses Previously Without Ducting Appendices



## CMHC—HOME TO CANADIANS

Canada Mortgage and Housing Corporation (CMHC) has been Canada's national housing agency for more than 60 years.

Together with other housing stakeholders, we help ensure that Canada maintains one of the best housing systems in the world. We are committed to helping Canadians access a wide choice of quality, affordable homes, while making vibrant, healthy communities and cities a reality across the country.

For more information, visit our website at **[www.cmhc.ca](http://www.cmhc.ca)**

You can also reach us by phone at 1-800-668-2642  
or by fax at 1-800-245-9274.

Outside Canada call 613-748-2003 or fax to 613-748-2016.

Canada Mortgage and Housing Corporation supports the Government of Canada policy on access to information for people with disabilities. If you wish to obtain this publication in alternative formats, call 1-800-668-2642.

# Appendices

## Demonstration of Duct Installation in Houses Previously Without Ducting

R. Clarke Designs Ltd.  
3 Sheffield Court  
Oromocto, NB E2V 2N1

for  
Don Fugler  
CMHC Policy and Research Division

March 2004

Entire House	d	2604	42746	17107	933
Ventilation air			5020	1361	
Equip. @ 1.00 RSM				18468	
Latent cooling				5540	
TOTALS		2604	47766	24008	933

**HRAP**  
Load Short Form  
Entire House  
Cert.#: 001528(RH/LG, RASD) R. Clarke Designs Ltd.

### Project Information

## Design Information

Outside db (°F)	Htg	Ctg	Method	Exposure category	Infiltration	F280
Inside db (°F)	-11	84				Sheltered
Design TD (°F)	72	75		Construction		Average
Diary range	83	9		Category		1.0
Inside humidity (%)	-	50		Number of stones		
Moisture difference (gr/lb)	-	21				

## COOLING EQUIPMENT


[illegible]

ROOM NAME	Area (ft <sup>2</sup> )	Hg load (Bluh)	Cig load (Bluh)	Hg AVF (cfm)	Cig AVF (cfm)
Master Bdrm	197	3082	1455	67	79
Kitchen/Dining	303	4557	3175	99	173
Entry	75	2538	798	55	44
Laundry	67	1989	743	43	41
Living Rm.	270	4897	2786	107	152
Front Bdrm.	154	3359	1407	73	77
Mid-Bdrm.	158	2298	945	30	52
Bathroom	113	741	89	16	5
Family Room	337	5951	3397	130	185
Storage	158	2353	1213	51	66
Workshop	135	3647	1099	80	80
Basement	423	3925	0	75	0
Office	217	3458	0	86	0


**HRASoft** wrightsoft Right-Suble Canada Residential 5.6.32 R3RCANW80002  
C:\Old hard drive\My Documents\HRAN\Projects\23013a\hr Calc = F280 Orientation = N

Printout certified by HRAI to meet all requirements of CAN/CSA-F280-M90

# **Appendix A** **House One** **Main Floor Plan Showing Supply & Return Diffusers**



**Appendix A**  
**House One**  
**Basement Plan Showing Supply & Return Diffusers**




HOUSE #1  
 BASEMENT PLAN - SHOWING  
 SUPPLY & RETURN DIFFUSERS

└─



Appendix A  
House One  
Basement Plan Showing Return Duct Sizes



HOUSE #1  
BASEMENT PLAN - SHOWING  
RETURN DUCT SIZES



**Appendix A**  
**House One**  
**Duct Size Calculations Page 1/6**

<b>PART A - DESIGN LOAD SPECIFICATIONS</b>		page 2
A.1 Sub Total Heat Loss <u>42746</u> Btuh.		
A.2 Ventilation Heat Loss <u>5020</u> Btuh.	A.3 Total Heat Loss <u>47766</u> Btuh.. (A.1 + A.2)	
A.4 Sub Total Heat Gain <u>17107</u> Btuh.		
A.5 Ventilation Heat Gain <u>1361</u> Btuh.	A.6 Total Heat Gain <u>18468</u> Btuh. (A.4 + A.5)	
A.7 Volume of House <u>21483</u> cu ft.		
A.8 Ventilation Flow Rate _____ cfm.		
<b>PART B - EQUIPMENT SELECTION</b>		
<b>Heating Equipment:</b>  Make _____ Model _____  Fuel Type: <input type="checkbox"/> Gas <input type="checkbox"/> Oil <input checked="" type="checkbox"/> Electricity <input type="checkbox"/> Other _____  B.1 Heating Output _____ Btuh. ( 100% - 140% of A.3 )  B.2 Approved Temperature rise/ range <u>.5</u> °F  B.3 Equipment External Static Pressure <u>933</u> in. W.C.  B.4 Heating Air Flow Rate. _____ cfm. ( when selected ) _____ RPM/Speed. ( or when single temp rise ) cfm = [ B.1 ÷ ( 1.08 x B.2 ) ]	<b>Cooling Equipment:</b>  Make _____ Model _____ ( indoor coil )  Cooling Medium: <input type="checkbox"/> DX <input type="checkbox"/> Chilled water <input type="checkbox"/> Other _____  B.5 Cooling output _____ (Btuh) _____ Tons. ( 80% - 125% of A.6 )  B.6 Manufacturers Flow Rate/Ton _____ (cfm/ton)  B.7 Coil Pressure Drop _____ in. W.C.  B.8 Cooling Air Flow Rate. _____ cfm. ( when selected ) _____ RPM/Speed. ( or when calculated ) cfm = B.5 (tons) x B.6	
<b>PART C - AIR DISTRIBUTION &amp; PRESSURE</b>		
C.1 Circulation Air Flow Rate. _____ cfm. ( A.7 x .025 )  C.2 System Design Air Flow Rate. <u>933</u> cfm. ( highest of B.4, B.8, C.1 )  C.3 Cooling Air Flow Proportioning Factor ( B.8 ÷ A.4 ) ( calculate to 4 decimal places ) <u>.0545</u> cfm/Btuh.  C.4 Heating Air Flow Proportioning Factor ( C.2 ÷ A.1 ) ( calculate to 4 decimal places ) <u>.0218</u> cfm/Btuh.	C.5 Calculated Heating Temperature Rise _____ °F. [ B.1 ÷ ( B.4 x 1.08 ) ]  C.6 Filter Pressure Drop <u>.0172</u> in. W.C.  C.7 Coil Pressure Drop (B.7) <u>0</u> in. W.C.  C.8 Total of Pressure Drop (C.6 + C.7) <u>.0172</u> in. W.C.  C.9 Available Design Pressure ( B.3 - C.8 ) <u>.43</u> in. W.C.	

**Note:** When furnace standard filter is replaced, subtract its pressure drop from the replacement filter and record on line C.6

**Appendix A**  
**House One**  
**Duct Size Calculations Page 2/6**

PART D - DETERMINING ROOM AND FLOOR DESIGN FLOW RATES									page 3
D.1 Floor	MAIN								
D.2 Room	BDRM #1	KIT/DIN	BACK ENTRY	LAUNDRY	LIV. RM	BDRM #2	BDRM #3	BATH	
D.3 Cooling load (Btuh)	1455	3175	798	743	2786	1407	945	89	
D.4 Room cooling flow rate (D.3 x C.3)									
D.5 Heating load (Btuh)	3082	4557	2538	1959	4897	3339	2298	741	
D.6 Room heating flow rate (D.5 x C.4)	67	99	55	43	107	73	50	16	
D.7 Number of outlets per room	1	1	1	1	2	1	1	1	
D.8 Floor supply air flow rates	510 cfm								

PART D - CONTINUED									
D.1	BASEMENT								
D.2	FAM. RM	STORAGE	WORKSHOP	BASET	OFFICE				
D.3	3397	1213	1099	Ø	Ø				
D.4									
D.5	5951	2353	3647	3925	3458				
D.6	130	51	80	86	75				
D.7	2	1	1	1	1				
D.8	422 cfm								

PART E - INLET FLOW RATES					
Floor level (Location)	Basement (50% D.8 Max)	1st floor (Sum of D.8 Min)	2nd floor (Sum of D.8 Min)	Outside air (100% of A.8)	Total = (C.2) (System cfm)
E.1 Floor return air flow rate	211	510+211=721	/	/	933
E.2 Minimum number of openings			/	/	
E.3 Actual number of openings	2	4	/	/	
E.4 Actual cfm per opening (E.1 ÷ E.3)	105.5	180.25	/	/	

Note: After location of supply outlets and return inlets are determined, produce preliminary drawing.

**Appendix A**  
**House One**  
**Duct Size Calculations Page 3/6**

<b>PART F - SUMMARY OF TOTAL EFFECTIVE LENGTHS FOR RETURN DUCTS</b>										<b>page 4</b>
Inlet No	Equipment Connection (Group 1)	Trunk To Drop Connection (Group 1)	Trunk Transitions (Group 2)	Trunk Fittings (Group 2)	Duct To Joist (Group 3)	Turbulence Effect	Stud To Joist (Group 4)	Grille Opening To Stud (Group 4)	Measured Length (ft)	Branch Effective Length (ft)
R1	C-10	B-35	K-15	G5+5	A-25	80	—	C-10	44	229
R2	C-10	B-35	K-15	G5+5	A-25	80	—	C-10	36	221
R3	C-10	B-35	K-15	G5+5	A-60	40	—	C-10	44.5	224.5
R4	C-10	B-35	K-15	G5+5	—	0	—	C-10	29.5	109.5
R5	C-10	B-35	—	G5+5	A-40	0	B-30	E5+5	25	160
R6	C-10	B-35	—	G5+5	A-40	0	—	D-10	23	128

<b>PART G - DUCT DESIGN PRESSURE</b>	
G.1	(Return Branch Longest Effective Length <u>229</u> ft).
G.2	<p style="text-align: center;"><b>R/A Plenum Pressure:</b></p> <p>Available Design Pressure (Line C.9) x Return Air Apportioning Factor (Appendix C (C3))</p> <p style="text-align: center;">( <u>.48</u> ) x ( <u>.5</u> ) = <u>.24</u> in. W.C. (Record Line H.8)</p>
G.3	<p style="text-align: center;"><b>S/A Plenum Pressure:</b></p> <p>Available Design pressure (Line C.9) - R/A Plenum Pressure</p> <p style="text-align: center;">( <u>.48</u> ) - ( <u>.24</u> ) = <u>.24</u> in. W.C. (Record Line J.7)</p>

**Appendix A**  
**House One**  
**Duct Size Calculations Page 4/6**

<b>PART H - SIZING OF RETURN GRILLES, BRANCHES AND MAIN TRUNK DUCTS</b>										page 5
H.1 Trunk Letter/No	A				B					
H.2 Inlet Location (Room)	BD*1	BD*3	BD*2	BASET	LIV.	BASET				
H.3 Inlet No (R)	R1	R2	R3	R4	R5	R6				
H.4 Inlet flow rate (cfm) (Line E.4 adjusted)	180.25	180.25	180.25	105.5	180.25	105.5				
H.5 Minimum required inlet free area (sq. in.) (Appendix C8)	65	65	65	40	65	40				
H.6 Inlet size (Appendix A)	6x12	6x12	6x12	6x8	6x12	6x8				
H.7 Inlet Pressure Loss (in. W.C.)	.02	.02	.02	.02	.02	.02				
H.8 R/A Plenum pressure (in. W.C.) (Line G.2)	.24	.24	.24	.24	.24	.24				
H.9 Adjusted duct design pressure (H.8 - H.7)	.22	.22	.22	.22	.22	.22				
H.10 Branch effective length (ft) (Part F)	229	221	224.5	109.5	160	128				
H.11 Loss/100 ft. of effective length [(H.9 x 100) ÷ H.10]	.09	.09	.09	.20	.13	.17				
H.12 Branch duct size (round) (H.4, H.11) (Appendix C4.5)	7.5	7.5	7.5	5.5	7	5.5				
H.13 Branch rectangular equivalent (Appendix C6)	14x3 1/4	14x3 1/4	14x3 1/4	10x3 1/4	14x3 1/4	10x3 1/4				
H.14 Joist to trunk opening size (2 x area H.13)	9.5x9.5	9.5x9.5	9.5x9.5		9.5x9.5					
H.15 Trunk flow rate (cfm) accumulation of H.4	180.25	360.5	540.75	646.25	826.5	932				
H.16 Lowest loss/100 ft encountered from duct end.	.09	.09	.09	.09	.09	.09				
H.17 Trunk duct size (round) (H.15, H.16) (Append C4.5)	7.5	9.5	11	12	13	14				
H.18 Trunk rectangular equivalent (Appendix C6)	6x8	9x8	13x8	16x8	18x8	22x8				
H.19 Installed Trunk size (Transitions)	←			16x8	←	22x8				
H.20 Trunk velocity (fpm) fpm = [(cfm x 144) ÷ area]				727		762				

**Duct Size Calculations Page 5/6**

Outlet No	Plenum Fitting (Group 5)	Trunk Transition (Group 6)	Trunk Fittings (Group 6)	Trunk To Branch Take offs (Group 7)	Aspiration Effect	Duct Flex Length (ft)	Branch Elbows (Group 8)	Boot Fitting (Group 8)	Measured Length (ft)	Branch Effective Length (ft)
S1	B-10	A-10+10	K-5	D-10	0	1	D-10+10	B-30	47	142
S2	B-10	A-10+10	K-5	A-40	0		E-5+5	B-30	51	166
S3	B-10	A-10+10	K-5	D-10	10		D-10+10	B-30	43	148
S4	B-10	A-10+10	K-5	D-10	10		D-10+10	B-30	51	156
S5	B-10	A-10+10	K-5	D-10	20		D-10+10+10	C-50	39.5	184.5
S6	B-10	A-10+10	K-5	D-10	30		D-10	B-30	40.5	155.5
S7	B-10	A-10+10	K-5	A-40	40		—	B-30	40.5	185.5
S8	B-10	A-10+10	K-5	A-40	40		—	B-30	20.5	165.5
S9	B-10	A-10+10	—	A-40	0		—	B-30	34.5	134.5
S10	B-10	A-10+10	—	A-40	0		—	B-30	16	116
S11	B-10	A-10+10	—	A-40	10		D-10	—	30	120
S12	B-10	—	—	A-40	20		D-10+10+10	B-30	38	168
S13	B-10	—	—	A-40	20		—	B-30	6	106
S14	B-10	—	—	A-40	30		D-10+10+10	B-30	42	182

**Appendix A**  
**House One**  
**Duct Size Calculations Page 6/6**

PART J - SIZING OF SUPPLY DIFFUSERS, BRANCHES AND MAIN TRUNK DUCTS															page 7
J.1	Trunk Letter/No	A					B								
J.2	Outlet location (Room)	BD #2	FAM.R.	BATH	BD #1	BD #3	OFFICE	FAM.R.	BEGET	K/B	LIV.R.	STORY WORKSHOP	BACK ENTRY	LIV.R.	LAUN.
J.3	Outlet No (S)	S1	S2	S3	S4	S5	S6	S7	S8	S9	S10	S11	S12	S13	S14
J.4	Outlet flow rate (cfm) (Line D.6 ÷ D.7)	73	65	16	67	50	75	65	86	99	53	131	55	54	43
J.5	Outlet size	4x10													
J.6	Outlet pressure loss (in. W.C.)	.01	.01	.005	.01	.01	.01	.01	.01	.02	.01	.04	.01	.01	.01
J.7	S/A Plenum pressure (in. W.C.) (Line G.3)	.24	.24	.24	.24	.24	.24	.24	.24	.24	.24	.24	.24	.24	.24
J.8	Adjusted duct design pressure (J.7 - J.6)	.23	.23	.23	.23	.23	.23	.23	.23	.22	.23	.20	.23	.23	.23
J.9	Branch effective length (ft) (Part I)	142	166	148	156	184.5	155.5	185.5	165.5	134.5	116	120	168	106	182
J.10	Loss/100 ft of effective length [(J.8 x 100) ÷ J.9]	.16	.14	.15	.14	.12	.14	.12	.14	.16	.19	.16	.14	.20	.13
J.11	Branch duct size (round) (J.4, J.10) (Appendix C4.5)	5	5	3	5	4.5	5	4.5	5.5	5.5	4	6	4.5	4	4
J.12	Branch rectangular equivalent (Appendix C6)	10x3 1/4										12x3 1/4	10x3 1/4		
J.13	Trunk flow rate (cfm) accumulation of J.4	73	138	154	221	271	346	411	497	596	649	780	835	889	932
J.14	Lowest loss/100 ft encountered from duct end.	.16	.14	.14	.14	.12	.12	.12	.12	.12	.12	.12	.12	.12	.12
J.15	Trunk duct size (round) (J.13, J.14) (Appendix C4.5)	5	6	6.5	7.5	8.5	9.5	10	10.5	11	11.5	12.5	13	13	13.5
J.16	Trunk rectangular equivalent (Appendix C6)								12x8						20x8
J.17	Installed Trunk size (Transitions)								16x8						20x8
J.18	Trunk velocity (fpm) fpm = [(cfm x 144) ÷ area]								559						839

# **Appendix A** **House One** **Supply-Air Flow Measurements**


## **Supply Airflows Measurements**

Measurements Method	Flow Collar In Duct			Hood At Grille			Branch	Design
Space	Pressure		Airflow	Pressure		Airflow		Airflow
	pa	"wc	cfm	pa	"wc	cfm		
Main Floor								
Master Bedroom	2.6	0.01	50	7.2	0.028	36	S-4	67
Bathroom	2.4	0.009	48	7	0.028	36	S-3	16
Mid. Bedroom	1.9	0.0076	44	5.7	0.022	32	S-5	50
Front Bedroom	4	0.016	64	9	0.036	41	S-1	73
Living Room (1)	could not measure			9.7	0.038	42	S-13	54
Living Room (2)	3.1	0.0124	57	15.6	0.062	53	S-10	53
Kitchen / Dining	6.6	0.026	82	12.9	0.0516	49	S-9	99
Back Entry	5.9	0.023	77	10.6	0.042	44	S-12	55
Laundry	2.6	0.01	51	4	0.016	27	S-14	43
Basement								
Family Room (1)	12.3	0.049	112	could not measure			S-2	66
Family Room (2)	10	0.04	101	could not measure			S-7	65
Storage	2	0.008	45	could not measure			S-11	131
Basement	0.9	0.0036	30	could not measure			S-8	86
Office	6.8	0.027	84	could not measure			S-6	75

## **Notes:**

- \* Measurements were recorded using a digital manometer
- \* Flow collar in duct, 6" dia. saddle style
- \* Hood equipped with 4" dia. Flow collar
- \* Some measurements not collected, no access to duct
- \* Some measurements not collected, no ceiling against which to place hood
- \* Joints of branch ducts were not sealed

**Appendix A**  
**House One**  
**Photographs of System 1 of 13**  
**H1,001**







**Appendix A**  
**House One**  
**Photographs of System 2 of 13**  
**H1,002**



**Appendix A**  
**House One**  
**Photographs of System 3 of 13**  
**H1,003**




**Appendix A**  
**House One**  
**Photographs of System 4 of 13**  
**H1,004**







**Appendix A**  
**House One**  
**Photographs of System 5 of 13**  
**H1,005**




**Appendix A**  
**House One**  
**Photographs of System 6 of 13**  
**H1,006**



**Appendix A**  
**House One**  
**Photographs of System 7 of 13**  
**H1,007**




**Appendix A**  
**House One**  
**Photographs of System 8 of 13**  
**H1,008**






**Appendix A**  
**House One**  
**Photographs of System 9 of 13**  
**H1,009**







**Appendix A**  
**House One**  
**Photographs of System 10 of 13**  
**H1,010**



**Appendix A**  
**House One**  
**Photographs of System 11 of 13**  
**H1,011**



**Appendix A**  
**House One**  
**Photographs of System 12 of 13**  
**H1,012**



**Appendix A**  
**House One**  
**Photographs of System 13 of 13**  
**H1,013**



Entire House	d	2383	41262	15398	900
Ventilation air			10757	1166	
Equip. @ 1.00	RSM			16554	
Latent cooling				4966	
TOTALS		2363	52019	21520	900

Printout certified by HRAI to meet all requirements of CAN/CSA-F280-M90

**VRAN** **wrightsoft** Right-Soft Carrels Residential 5 & 32 RSR/CAN80002  
C:\cd\hard\dwibilly\Documents\VRAN\Project\23013b.vr Cat# = F260 Orientation = NE

2004-Feb-09 18:28:20 Page 2

**HRAD**  
Load Short Form  
Entire House  
R. CLARKE Designs Ltd.  
Cert.#: 001529

3 Sheffield Court, Omarewa, NB, E2V 2N1 Phone: 908-357-3377 Fax: 908-357-3378 E-mail: [rlc@rlcglobal.nb.ca](mailto:rlc@rlcglobal.nb.ca)

## For: CMHC Test House #2

Outside db (°F)	Htg	Ctg	Method	F280
-11	-	84	Exposure category	Sheltered
72	-	76	Construction category	Average
83	-	9	Number of stories	2.0
Design TD (°F)	-	M		
Daily range	-			

## COOLING EQUIPMENT

## HEATING EQUIPMENT

Make	Model	Make	Model
Efficiency	0 HSFP	Efficiency	0 SEER
Heating input	0 Btuh @ 47°F	Heating input	0 Btuh
Heating output	0 Btuh @ 47°F	Heating output	0 Btuh
Temperature rise	900 °cm	Temperature rise	900 °cm
Air flow	0.022 cfm/Btuh	Air flow	0.022 cfm/Btuh
Air flow factor	0.40 in H <sub>2</sub> O	Air flow factor	0.40 in H <sub>2</sub> O
Static pressure		Static pressure	
Load sensible heat ratio		Load sensible heat ratio	77 %


ROOM NAME	Area (ft <sup>2</sup> )	Htg load (Btu/h)	Cig load (Btu/h)	Htg AVF (cfm)	Cig AVF (cfm)
Bedroom #1	132	3299	1588	72	93
Bedroom #2	117	2821	1551	62	91
Upper Hall	101	359	88	18	5
Bedroom	60	852	36	15	23
Attic Storage	204	2358	3654	46	38
Unfin. Attic Room	234	3368	654	74	87
Entry	127	3229	1148	70	87
Ensuite	66	1690	95	37	6
Powder Room	52	1717	502	37	28
Kitchen	118	2448	1030	53	60
Dining	147	4153	2814	80	105
Living Room	133	3483	2814	80	105
Factor Hall	103	4393	2254	95	132
Factor Hall	88	858	14	19	19
Master Bedroom	258	5234	1576	114	92
Main Bath	111	714	17	16	1

Printout certified by HRAI to meet all requirements of CAN/CSA-F280-M90.

**WRIGHTSOFT**  
RightSoft Canada's Residential 6.8.32 RSRCAN80002  
C:\01\hard\shell\Documents\WRIGHT\Projects\230130\rev Calc - F180 Orientation - NE


2004-Feb-09 16:28:29 Page 1

**Appendix B**  
**House Two**  
**Main Floor Plan Showing Supply & Return Diffusers**






**Appendix B**  
**House Two**  
**Upper Floor Plan Showing Supply & Return Diffusers**




**Appendix B**  
**House Two**  
**Upper Floor Plan - Showing Supply Ducts**





**Appendix B  
House Two  
Upper Floor Plan - Showing Return Ducts**



**Appendix B**  
**House Two**  
**Duct Size Calculations Page 1/6**

<b>PART A - DESIGN LOAD SPECIFICATIONS</b>		page 2
<p>A.1 Sub Total Heat Loss <u>41262</u> Btuh.</p> <p>A.2 Ventilation Heat Loss <u>10757</u> Btuh.</p> <p>A.4 Sub Total Heat Gain <u>20354</u> Btuh.</p> <p>A.5 Ventilation Heat Gain <u>1166</u> Btuh.</p> <p>A.7 Volume of House <u>17163</u> cu ft.</p> <p>A.8 Ventilation Flow Rate <u>120</u> cfm.</p>	<p>A.3 Total Heat Loss <u>52019</u> Btuh.. (A.1 + A.2)</p> <p>A.6 Total Heat Gain <u>21520</u> Btuh. (A.4 + A.5)</p>	
<b>PART B - EQUIPMENT SELECTION</b>		
<p><b>Heating Equipment:</b></p> <p>Make _____ Model _____</p> <p>Fuel Type: <input type="checkbox"/> Gas <input type="checkbox"/> Oil <input type="checkbox"/> Electricity <input type="checkbox"/> Other _____</p> <p>B.1 Heating Output <u>52019</u> Btuh. ( 100% - 140% of A.3 )</p> <p>B.2 Approved Temperature rise/ range _____ °F</p> <p>B.3 Equipment External Static Pressure _____ in. W.C.</p> <p>B.4 Heating Air Flow Rate. <u>900</u> cfm. ( when selected ) _____ RPM/Speed. ( or when single temp rise ) cfm = [ B.1 ÷ ( 1.08 x B.2 ) ]</p>	<p><b>Cooling Equipment:</b></p> <p>Make _____ Model _____ ( indoor coil )</p> <p>Cooling Medium: <input type="checkbox"/> DX <input type="checkbox"/> Chilled water <input type="checkbox"/> Other _____</p> <p>B.5 Cooling output <u>24000</u> (Btuh) <u>2</u> Tons. ( 80% - 125% of A.6 )</p> <p>B.6 Manufacturers Flow Rate/Ton _____ (cfm/ton)</p> <p>B.7 Coil Pressure Drop _____ in. W.C.</p> <p>B.8 Cooling Air Flow Rate. <u>900</u> cfm. ( when selected ) _____ RPM/Speed. ( or when calculated ) cfm = B.5 (tons) x B.6</p>	
<b>PART C - AIR DISTRIBUTION &amp; PRESSURE</b>		
<p>C.1 Circulation Air Flow Rate. <u>429</u> cfm. ( A.7 x .025 )</p> <p>C.2 System Design Air Flow Rate. <u>900</u> cfm. ( highest of B.4, B.8, C.1 )</p> <p>C.3 Cooling Air Flow Proportioning Factor ( B.8 ÷ A.4 ) (calculate to 4 decimal places) <u>.0442</u> cfm/Btuh.</p> <p>C.4 Heating Air Flow Proportioning Factor ( C.2 ÷ A.1 ) (calculate to 4 decimal places) <u>.0218</u> cfm/Btuh.</p>	<p>C.5 Calculated Heating Temperature Rise _____ °F. [ B.1 ÷ ( B.4 x 1.08 ) ]</p> <p>C.6 Filter Pressure Drop <u>.01</u> in. W.C.</p> <p>C.7 Coil Pressure Drop (B.7) <u>—</u> in. W.C.</p> <p>C.8 Total of Pressure Drop (C.6 + C.7) <u>.01</u> in. W.C.</p> <p>C.9 Available Design Pressure ( B.3 - C.8 ) <u>.4</u> in. W.C.</p>	

**Note:** When furnace standard filter is replaced, subtract its pressure drop from the replacement filter and record on line C.6

**Appendix B**  
**House Two**  
**Duct Size Calculations Page 2/6**

PART D - DETERMINING ROOM AND FLOOR DESIGN FLOW RATES									
page 3									
D.1 Floor	MAIN FLOOR								
D.2 Room	LAUN.	ENTRY	P. RM.	KIT.	DIN	LIV	PORCH	F. HALL	
D.3 Cooling load (Btuh)	1148	95	502	1036	2814	1606	2254	31	2571
D.4 Room cooling flow rate (D.3 x C.3)	50	4	22	46	124	71	100	2	2
D.5 Heating load (Btuh)	3229	1690	1717	2449	4143	4089	4363	1572	
D.6 Room heating flow rate (D.5 x C.4)	70	37	37	53	90	89	95	35	
D.7 Number of outlets per room	1	1	1	1	3	1	1	1	
D.8 Floor supply air flow rates	SA = 620 RA = 500								

PART D - CONTINUED									
D.1	UPPER FLOOR								
D.2	M. BDRM	BDRM #1	BDRM #2	ATTIC ST.	ATTIC MECH				
D.3	1576	1672	1620	386	654				
D.4	70	74	72	17	29				
D.5	5234	3658	3503	2229	3386				
D.6	114	80	77	49	74				
D.7	2	1	1	1	1				
D.8	SA = 280 RA = 280 + 120 = 400 cfm								

PART E - INLET FLOW RATES					
Floor level (Location)	Basement (50% D.8 Max)	1st floor (Sum of D.8 Min)	2nd floor (Sum of D.8 Min)	Outside air (100% of A.8)	Total = (C.2) (System cfm)
E.1 Floor return air flow rate		500	280	120	
E.2 Minimum number of openings		4.16	2		
E.3 Actual number of openings		4			
E.4 Actual cfm per opening (E.1 ÷ E.3)		125	140	120	

Note: After location of supply outlets and return inlets are determined, produce preliminary drawing.

**Appendix B**  
**House Two**  
**Duct Size Calculations Page 3/6**

PART F - SUMMARY OF TOTAL EFFECTIVE LENGTHS FOR RETURN DUCTS										page 4
Inlet No	Equipment Connection (Group 1)	Trunk To Drop Connection (Group 1)	Trunk Transitions (Group 2)	Trunk Fittings (Group 2)	Duct To Joist (Group 3)	Turbulence Effect	Stud To Joist (Group 4)	Grille Opening To Stud (Group 4)	Measured Length (ft)	Branch Effective Length (ft)
R1	E20	B35	K15	B15 B10+10	—	40	—	—	41	186
R2			K15	B15 B10+10	A25	0	A15	C10	58	213
R3			—	B15	A60	160	F-5 E10		29	344
R4			—		A60	120	A15		37	312
R5			—		A60	80	A15		32	267
R6			—		A60	40	—		12	192
R7	↓	↓	—	↓	A60	0	A15	↓	27	182

PART G - DUCT DESIGN PRESSURE	
G.1	(Return Branch Longest Effective Length <u>344</u> ft).
G.2	<p style="text-align: center;"><b>R/A Plenum Pressure:</b></p> <p>Available Design Pressure (Line C.9) x Return Air Apportioning Factor (Appendix C (C3))</p> <p style="text-align: center;">( <u>.4</u> ) x ( <u>.5</u> ) = <u>.2</u> in. W.C. (Record Line H.8)</p>
G.3	<p style="text-align: center;"><b>S/A Plenum Pressure:</b></p> <p>Available Design pressure (Line C.9) - R/A Plenum Pressure</p> <p style="text-align: center;">( <u>.4</u> ) - ( <u>.2</u> ) = <u>.2</u> in. W.C. (Record Line J.7)</p>

**Appendix B**  
**House Two**  
**Duct Size Calculations Page 4/6**

PART H - SIZING OF RETURN GRILLES, BRANCHES AND MAIN TRUNK DUCTS										page 5
H.1 Trunk Letter/No										
H.2 Inlet Location (Room)	VENT	MAST BDRM	UPPER HALL	LIV	LIV	ATTIC MECH	LIV			
H.3 Inlet No (R)	R1	R2	R3	R4	R5	R6	R7			
H.4 Inlet flow rate (cfm) (Line E.4 adjusted)	120	125	140	125	125	140	125			
H.5 Minimum required inlet free area (sq. in.) (Appendix C8)	43	47	50	47	47	50	47			
H.6 Inlet size (Appendix A)		10x6	10x6	10x6	10x6	10x6	10x6			
H.7 Inlet Pressure Loss (in. W.C.)		.04								
H.8 R/A Plenum pressure (in. W.C.) (Line G.2)	.2	.2								
H.9 Adjusted duct design pressure (H.8 - H.7)		.16								
H.10 Branch effective length (ft) (Part F)		213	344	312	267	192	182			
H.11 Loss/100 ft. of effective length [(H.9 x 100) ÷ H.10]		.07	.04	.05	.06	.08	.09			
H.12 Branch duct size (round) (H.4, H.11) (Appendix C4,5)		6	8	7.5	7.0	7	6.5			
H.13 Branch rectangular equivalent (Appendix C6)		12x3 1/4	7x8	14x3 1/4	14x3 1/4	14x3 1/4	12x3 1/4			
H.14 Joist to trunk opening size (2 x area H.13)		7x7	10x10	9.5x9.5	9x9	9x9	9x9			
H.15 Trunk flow rate (cfm) accumulation of H.4	120	245	385	510	635	775	900			
H.16 Lowest loss/100 ft encountered from duct end.	—	.07	.04							
H.17 Trunk duct size (round) (H.15, H.16) (Append C4,5)		9	11.5	13	14	15	16			
H.18 Trunk rectangular equivalent (Appendix C6)		8x8	11x10	14x10	17x10	19x10	22x10			
H.19 Installed Trunk size (Transitions)		8x10					22x10			
H.20 Trunk velocity (fpm) fpm = [(cfm x 144) ÷ area]										

**Duct Size Calculations Page 5/6**

[illegible]

## Appendix B House Two Supply-Air Flow Measurements

### Supply Airflows Measurements

Measurements Method	Flow Collar In Duct			Hood At Grille			Branch	Design
Space	Pressure		Airflow	Pressure		Airflow		Airflow
	pa	"wc	cfm	pa	"wc	cfm		
Main Floor								
Laundry	could not measure			5	0.02	30.4	S-1	70
Side Entry	could not measure			4.4	0.017	66.5	S-2	74
Kitchen	could not measure			6.2	0.025	33.9	S-3	53
Living Room (1)	7.7	0.03	88.3	19.7	0.079	60.3	S-8	59
Living Room (2)	4.4	0.017	65.5	11.2	0.045	45.5	S-11	60
Living Room (3)	4	0.016	64.5	8.4	0.034	39.5	S-12	60
Parlor	5	0.02	72.1	7.8	0.031	89.8	S-13	95
Front Hall	1.3	0.005	36	3.1	0.012	23.5	S-9	35
Master Bedroom (1)	8.8	0.035	95.4	14.1	0.056	50.8	S-4	57
Master Bedroom (2)	7.2	0.028	85.3	11.7	0.47	46.5	S-5	57
Upper Floor								
Bedroom	4.9	0.019	70.3	6.1	0.024	79	S-7	80
Computer Room	5.9	0.023	77.3	7.8	0.031	89.8	S-6	80
Hall	6.3	0.025	80.6	8.4	0.034	94	S-6a	0
Attic Mech.	4.5	0.018	68.4	12.6	0.05	48	S-10	123

#### Notes:

- \* Measurements were recorded using a digital manometer
- \* Flow collar in duct, 6" dia. saddle style
- \* Hood equipped with 4" or 6" dia. Flow collar
- \* Some measurements not collected, no access to duct
- \* Joints of branch ducts were not sealed

## Appendix B House Two Return-Air Flow Measurements

### Return Airflows Measurements

Measurements Method	Flow Collar In Duct			Hood At Grille			Branch	Design
Space	Pressure		Airflow	Pressure		Airflow		Airflow
	pa	"wc	cfm	pa	"wc	cfm		
Main Floor								
Living Room (1)	could not measure			7.7	0.03	88.3	R-4	125
Living Room (2)	could not measure			4.7	0.018	68.4	R-5	125
Living Room (3)	could not measure			4.7	0.018	68.4	R-7	125
Parlor	could not measure			6.5	0.026	82.2	R	0
Master Bedroom	could not measure			2.4	0.009	48.4	R-2	125
Upper Floor								
Stairwell	could not measure			9.5	0.038	99.4	R-3	140
Attic Mech.	not installed			not installed			R-6	140

Notes:


- \* Measurements were recorded using a digital manometer
- \* Hood equipped with 4" or 6" dia. Flow collar
- \* Some measurements not collected with flow collar, joists were panned




**Appendix B**  
**House Two**  
**Photographs of System 1 of 15**  
**H2, 001**



**Appendix B**  
**House Two**  
**Photographs of System 2 of 15**  
**H2, 002**




**Appendix B**  
**House Two**  
**Photographs of System 3 of 15**  
**H2, 003**





**Appendix B**  
**House Two**  
**Photographs of System 4 of 15**  
**H2, 004**




**Appendix B**  
**House Two**  
**Photographs of System 5 of 15**  
**H2, 005**



**Appendix B**  
**House Two**  
**Photographs of System 6 of 15**  
**H2, 006**




**Appendix B**  
**House Two**  
**Photographs of System 7 of 15**  
**H2, 007**





**Appendix B**  
**House Two**  
**Photographs of System 8 of 15**  
**H2, 008**




**Appendix B**  
**House Two**  
**Photographs of System 9 of 15**  
**H2, 009**



**Appendix B**  
**House Two**  
**Photographs of System 10 of 15**  
**H2, 010**




**Appendix B**  
**House Two**  
**Photographs of System 11 of 15**  
**H2, 011**





**Appendix B**  
**House Two**  
**Photographs of System 12 of 15**  
**H2, 012**



**Appendix B**  
**House Two**  
**Photographs of System 13 of 15**  
**H2, 013**



**Appendix B**  
**House Two**  
**Photographs of System 14 of 15**  
**H2, 014**





**Appendix B**  
**House Two**  
**Photographs of System 15 of 15**  
**H2, 015**



Appendix C  
House Three  
Design Heating / Cooling Load Calculation

Entire House Ventilation air Equip. @ 1.00 RSM Latent cooling	0	2481	40480 10757	17285 1188 18431 5529	900	900	900
TOTALS		2481	60216	23961	900	900	900

Job: 200144  
Print: 2003  
By: R. Clarke

**HRAC**  
Load Short Form  
Entire House  
Client: 001520(R. Clarke, RASD) R. Clarke Designs Ltd.  
23 Walling Court, Orono, ME 04469 Phone: 207-297-3377 Fax: 207-297-3378 Email: rclarke@hrac.com

Project Information

For: CMHC Test House "4"

Design Information

Outside db (°F)	Wb	CG	Infiltration
-11	84	75	F280
Design TD (°F)	72	75	Shelared
Daily range	83	9	Average
Inside humidity (%)	-	M	1.0
Moisture difference (gr/lb)	-	50	
	-	21	

HEATING EQUIPMENT

Make	Trade	Model	Efficiency	Heating input	Heating output	Temperature rise	Actual air flow	Static pressure	Space thermostat
			0 HSPF	0 Btu/h @ 47°F	0 Btu/h	0 Btu/h	900 cfm	0.018 cfm/Btu/h	0.50 in H2O
							0 Btu/h	0 Btu/h	0 Btu/h
							900 cfm	0.052 cfm/Btu/h	0.50 in H2O
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2O	77 %
							0.052 cfm/Btu/h	0.50 in H2	


COOLING EQUIPMENT

Make	Efficiency	Sensible cooling	Latent cooling	Total cooling	Actual air flow	Air flow factor	Static pressure	Load sensible heat ratio
Trade	0 EER	0 Btu/h	0 Btu/h	0 Btu/h	0 Btu/h	900 cfm	0.052 cfm/Btu/h	0.50 in H2O
Model	0 HSPF	0 Btu/h @ 47°F	0 Btu/h	0 Btu/h	0 Btu/h	900 cfm	0.018 cfm/Btu/h	0.50 in H2O

ROOM NAME	Area (ft²)	Htg load (Btu/h)	Cool load (Btu/h)	Htg AVF (cfm)	Cool AVF (cfm)
Front Bdrm	138	2800	1539	59	80
Kitchen	100	2452	1174	45	61
Dining Room	273	5131	4388	93	229
Living Room	273	1079	4267	119	222
Back Entry	58	1079	657	20	34
Laundry	58	1079	657	20	34
Mid Bdrm	112	2452	1174	45	61
Master Bdrm	251	5131	4388	93	229
Basement #1	227	3980	3598	118	193
Basement #2	227	3980	3598	118	193
Basement #3	227	3980	3598	118	193
Basement #4	227	3980	3598	118	193
Basement #5	227	3980	3598	118	193

Printout certified by HRAI to meet all requirements of CAN/CSA-F280-M90


# Appendix C House Three Main Floor Plan Showing Supply & Return Diffusers




MAIN FLOOR PLAN - SHOWING  
SUPPLY & RETURN DIFFUSERS

HOUSE #3

**Appendix C**  
**House Three**  
**Basement Plan Showing Supply & Return Diffusers**




# Appendix C House Three Basement Plan Showing Supply Duct Sizes



HOUSE #3  
BASEMENT PLAN - SHOWING  
SUPPLY DUCT SIZES

Appendix C  
House Three  
Basement Plan Showing Return Duct Sizes



HOUSE #3  
BASEMENT PLAN - SHOWING  
RETURN DUCT SIZES

**Appendix C**  
**House Three**  
**Duct Size Calculations Page 1/6**

PART A - DESIGN LOAD SPECIFICATIONS		page 2
<p>A.1 Sub Total Heat Loss <u>49611</u> Btuh.</p> <p>A.2 Ventilation Heat Loss <u>10757</u> Btuh.</p> <p>A.4 Sub Total Heat Gain <u>22795</u> Btuh.</p> <p>A.5 Ventilation Heat Gain <u>1166</u> Btuh.</p> <p>A.7 Volume of House <u>23901.6</u> cu ft.</p> <p>A.8 Ventilation Flow Rate <u>120</u> cfm.</p>	<p>A.3 Total Heat Loss <u>60368</u> Btuh.. (A.1 + A.2)</p> <p>A.6 Total Heat Gain <u>23961</u> Btuh. (A.4 + A.5)</p>	
PART B - EQUIPMENT SELECTION		
<p>Heating Equipment:</p> <p>Make _____ Model _____</p> <p>Fuel Type: <input type="checkbox"/> Gas <input type="checkbox"/> Oil <input type="checkbox"/> Electricity <input type="checkbox"/> Other _____</p> <p>B.1 Heating Output <u>68260</u> Btuh. ( 100% - 140% of A.3 )</p> <p>B.2 Approved Temperature rise/ range _____ °F</p> <p>B.3 Equipment External Static Pressure <u>.5</u> in. W.C.</p> <p>B.4 Heating Air Flow Rate. <u>900</u> cfm. ( when selected ) _____ RPM/Speed. ( or when single temp rise ) cfm = [ B.1 ÷ ( 1.08 x B.2 ) ]</p>	<p>Cooling Equipment:</p> <p>Make _____ Model _____ ( indoor coil )</p> <p>Cooling Medium: <input type="checkbox"/> DX <input type="checkbox"/> Chilled water <input type="checkbox"/> Other _____</p> <p>B.5 Cooling output <u>24000</u> (Btuh) <u>2</u> Tons. ( 80% - 125% of A.6 )</p> <p>B.6 Manufacturers Flow Rate/Ton <u>450</u> (cfm/ton)</p> <p>B.7 Coil Pressure Drop <u>—</u> in. W.C.</p> <p>B.8 Cooling Air Flow Rate. <u>900</u> cfm. ( when selected ) _____ RPM/Speed. ( or when calculated ) cfm = B.5 (tons) x B.6</p>	
PART C - AIR DISTRIBUTION & PRESSURE		
<p>C.1 Circulation Air Flow Rate. <u>597.5</u> cfm. ( A.7 x .025 )</p> <p>C.2 System Design Air Flow Rate. <u>900</u> cfm. ( highest of B.4, B.8, C.1 )</p> <p>C.3 Cooling Air Flow Proportioning Factor ( B.8 ÷ A.4 ) (calculate to 4 decimal places) <u>.0394</u> cfm/Btuh.</p> <p>C.4 Heating Air Flow Proportioning Factor ( C.2 ÷ A.1 ) (calculate to 4 decimal places) <u>.0381</u> cfm/Btuh.</p>	<p>C.5 Calculated Heating Temperature Rise <u>70</u> °F. [ B.1 ÷ ( B.4 x 1.08 ) ]</p> <p>C.6 Filter Pressure Drop <u>—</u> in. W.C.</p> <p>C.7 Coil Pressure Drop (B.7) <u>—</u> in. W.C.</p> <p>C.8 Total of Pressure Drop (C.6 + C.7) <u>—</u> in. W.C.</p> <p>C.9 Available Design Pressure ( B.3 - C.8 ) <u>.5</u> in. W.C.</p>	

Note: When furnace standard filter is replaced, subtract its pressure drop from the replacement filter and record on line C.6

**Appendix C**  
**House Three**  
**Duct Size Calculations Page 2/6**

PART D - DETERMINING ROOM AND FLOOR DESIGN FLOW RATES								
page 3								
D.1 Floor	MAIN FLOOR							
D.2 Room	F.BD.	KIT	DIN	LIV	B.ENTRY	LAUN.	HALL	MID.BD
D.3 Cooling load (Btuh)	1539	1174	4388	4267	657	23	75	1157
D.4 Room cooling flow rate (D.3 x C.3)	80	61	229	222	34	1	4	60
D.5 Heating load (Btuh)	3611	2459	5146	6553	1081	67	224	2413
D.6 Room heating flow rate (D.5 x C.4)	65	45	93	119	20	1	4	44
D.7 Number of outlets per room	1	1	2	3	1	0	0	1
D.8 Floor supply air flow rates	SA = (H) 527 cfm (C) 900 cfm RA = 900 cfm							

PART D - CONTINUED								
D.1	MAIN FL.	BASEMENT						
D.2	BATH	H.BD.	BASE1	#2	#3	#4	#5	
D.3	270	3696	0	0	0	0	0	
D.4	15	193						
D.5	985	6506	3992	3992	4808	1812	6161	
D.6	18	118	72	72	84	33	112	
D.7	1	2	1	1	1	1	1	
D.8			SA = 373 cfm RA = 373					

PART E - INLET FLOW RATES					
Floor level (Location)	Basement (50% D.8 Max)	1st floor (Sum of D.8 Min)	2nd floor (Sum of D.8 Min)	Outside air (100% of A.8)	Total = (C.2) (System cfm)
E.1 Floor return air flow rate	373	900	/		900
E.2 Minimum number of openings	4	8			
E.3 Actual number of openings	3	9			
E.4 Actual cfm per opening (E.1 ÷ E.3)	124.3	100			

Note: After location of supply outlets and return inlets are determined, produce preliminary drawing.



**Appendix C**  
**House Three**  
**Duct Size Calculations Page 3/6**

PART F - SUMMARY OF TOTAL EFFECTIVE LENGTHS FOR RETURN DUCTS										page 4
Inlet No	Equipment Connection (Group 1)	Trunk To Drop Connection (Group 1)	Trunk Transitions (Group 2)	Trunk Fittings (Group 2)	Duct To Joist (Group 3)	Turbulence Effect	Stud To Joist (Group 4)	Grille Opening To Stud (Group 4)	Measured Length (ft)	Branch Effective Length (ft)
R1	C10	B35	K15+15	A10+10	A1 25	120	—	C10	40.5	290.5
R2					A2 60	80	—		35.5	280.5
R3						40	B25		43.5	273.5
R4						0			29.5	174.5
R5			K15			80			26.5	236.5
R6			-4-			40			20.5	190.5
R7			K15+15		A25 A2 60	40			41.5	251.5
R8			K15		A2 60 A2 60	0			38.5	228.5
R9			—		A2 60	40			17	172
R10			—		A2 60	40			19.5	174.5
R11			K15		A1 25 A2 60	40			37.5	232.5
R12			—		A2 60 A2 60	0			31.5	206.5

PART G - DUCT DESIGN PRESSURE	
G.1	(Return Branch Longest Effective Length <u>290.5</u> ft).
G.2	<b>R/A Plenum Pressure:</b> Available Design Pressure (Line C.9) x Return Air Apportioning Factor (Appendix C (C3)) $(.5) \times (.5) = \underline{0.25}$ in. W.C. (Record Line H.8)
G.3	<b>S/A Plenum Pressure:</b> Available Design pressure (Line C.9) - R/A Plenum Pressure $(.5) - (.25) = \underline{0.25}$ in. W.C. (Record Line I.7)

**Appendix C**  
**House Three**  
**Duct Size Calculations Page 4/6**

PART H - SIZING OF RETURN GRILLES, BRANCHES AND MAIN TRUNK DUCTS														N TRUNK DUCTS				page 5
H.1	Trunk Letter/No	A					B					C						
H.2	Inlet Location (Room)	DIN	RIT	BASET	LIV	BASET	HALL	M.B.D.	HALL	F.B.D	M.D.B.D	M.B.D	BASET					
H.3	Inlet No (R)	R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12					
H.4	Inlet flow rate (cfm) (Line E.4 adjusted)	130	130	124	130	125	130	60	130	70	60	60	124					
H.5	Minimum required inlet free area (sq. in.) (Appendix C8)	47	47	47	47	47	47	36	47	36	36	36	47					
H.6	Inlet size (Appendix A)	6x10						6x8	6x10		6x8		6x10					
H.7	Inlet Pressure Loss (in. W.C.)	.02																
H.8	R/A Plenum pressure (in. W.C.) (Line G.2)	0.25																
H.9	Adjusted duct design pressure (H.8 - H.7)	0.23																
H.10	Branch effective length (ft) (Part F)	290.5	280.5	273.5	174.5	236.5	190.5	251.5	228.5	172	174.5	232.5	206.5					
H.11	Loss/100 ft. of effective length $(H.9 \times 100) \div H.10$	.08	.08	.08	.13	.10	.12	.09	.10	.13	.13	.10	.11					
H.12	Branch duct size (round) (H.4, H.11) (Appendix C4.5)	7	7	7	6.5	6.5	6.5	5	6.5	5	5	5	6.5					
H.13	Branch rectangular equivalent (Appendix C6)	14x3 1/2			12x3 1/2			10x3 1/2	12x3 1/2	10x3 1/2			12x3 1/2					
H.14	Joist to trunk opening size (2 x area H.13)	9.5x9.5			9x9			8x8	9x9	8x8			9x9					
H.15	Trunk flow rate (cfm) accumulation of H.4	130	260	260	390	390	520	580	710	780	840	900	900					
H.16	Lowest loss/100 ft. encountered from duct end.	.08																
H.17	Trunk duct size (round) (H.15, H.16) (Append C4.5)	7	9	9	10	10	12	12	13	13.5	14	14	14					
H.18	Trunk rectangular equivalent (Appendix C6)	5x8	8x8	8x8	11x8	11x8	16x8	16x8	18x8	20x8	22x8	22x8	22x8					
H.19	Installed Trunk size (Transitions)				11x8				20x8				24x8					
H.20	Trunk velocity (fpm) $fpm = [(cfm \times 144) \div area]$				638				639				675					

**Duct Size Calculations Page 5/6**

**page 6**

**Appendix C**  
**House Three**  
**Duct Size Calculations Page 6/6**

PART J - SIZING OF SUPPLY DIFFUSERS, BRANCHES AND MAIN TRUNK DUCTS page 7																			
J.1	Trunk Letter/No	A					B					C							
J.2	Outlet location (Room)	DIN	LIV	BT 3	DIN	BT 2	LIV	LIV	LIV	KIT	BATH	BT 1	M.BD	M.BD	BT 5	BATH	BT 4	F.BD	M.BD
J.3	Outlet No (S)	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108
J.4	Outlet flow rate (cfm) (Line D.6 ÷ D.7)	114	74	84	115	72	74	74	74	61	34	72	96	97	112	16	33	80	65
J.5	Outlet size	4x10								2x10	4x10								
J.6	Outlet pressure loss (in. W.C.)	.03	.01	.01	.03	.01	.01	.01	.01	.01	.005	.01	.02	.02	.03	.005	.005	.01	.01
J.7	S/A Plenum pressure (in. W.C.) (Line G.3)	.25																	
J.8	Adjusted duct design pressure (1.7 - J.6)	.22	.24	.24	.22	.24	.24	.24	.24	.24	.245	.24	.23	.23	.22	.245	.245	.24	.24
J.9	Branch effective length (ft) (Part I)	142	149	166.5	167.5	175.5	176.5	171.5	130.5	130.5	156.5	99	131	182	185	125.5	129.5	110.5	130.5
J.10	Loss/100 ft of effective length ((J.8 x 100) ÷ J.9)	.15	.16	.14	.13	.13	.19	.14	.18	.18	.16	.24	.17	.13	.12	.19	.19	.22	.18
J.11	Branch duct size (round) (J.4, J.10) (Appendix C4.5)	6	5	5 1/2	6	5	5	5	4 1/2	4	4	4 1/2	5 1/2	5 1/2	6	3	4	5	4 1/2
J.12	Branch rectangular equivalent (Appendix C6)	12x3 1/4	10x3 1/4	→	12x3 1/4	10x3 1/4									→	12x3 1/4	10x3 1/4		→
J.13	Trunk flow rate (cfm) accumulation of J.4	114	188	→	188	303	377	451	512	512	546	546	642	739	739	755	755	835	906
J.14	Lowest loss/100 ft encountered from duct end.	.15	.15	.14	.13	.13	.13	.13	.13	.13	.13	.13	.13	.13	.12	.12	.12	.12	.12
J.15	Trunk duct size (round) (J.13, J.14) (Appendix C4.5)	6	7	7	8 1/2	8 1/2	9	10	10	10	10 1/2	10 1/2	11 1/2	12	12	12	12	13	13
J.16	Trunk rectangular equivalent (Appendix C6)	12x3 1/4	14x3 1/4	→	8x8	→	→	11x8	→	→	12x8	→	14x8	16x8	→	→	→	18x8	→
J.17	Installed Trunk size (Transitions)	4				8x8	←				14x8	←							20x8
J.18	Trunk velocity (fpm) fpm = [(cfm x 144) ÷ area]					681					702								810

# **Appendix C** **House Three** **Supply-Air Flow Measurements**

## **Supply Airflows Measurements**

Measurements Method	Flow Collar In Duct			Hood At Grille			Branch	Design
Space	Pressure		Airflow	Pressure		Airflow		Airflow
	pa	"wc	cfm	pa	"wc	cfm		
Main Floor								
Master Bedroom (1)	7.8	0.0312	89.02	3.1	0.0124	56.12	S-11	96
Master Bedroom (2)	10.3	0.0412	102.3	4.1	0.0164	65.54	S-12	97
Mid. Bedroom	17.5	0.07	133.34	2.1	0.0084	46.19	S-17	65
Front Bedroom	6.7	0.0268	82.5	2.6	0.0104	51.39	S-16	80
Kitchen	6.7	0.0268	82.5	2.6	0.0104	51.39	S-8	61
Dining Room (1)	8.2	0.0328	91.27	2.4	0.0096	49.38	S-4	115
Dining Room (2)	9.4	0.0376	97.72	3.4	0.0136	58.77	S-1	114
Back Entry	12.1	0.0484	110.88	3.7	0.0148	61.31	S-9	74
Living Room (1)	8.2	0.0328	91.27	2.8	0.0112	53.33	S-2	74
Living Room (2)	not installed			not installed			S-6	74
Living Room (3)	8.3	0.0332	91.83	3.2	0.0128	57.02	S-7	74
Bathroom (5" dia.)	5.9	0.0236	48.71	1.5	0.006	39.03	S-14	16
Basement								
Basement (1)	6.9	0.0276	83.73	could not measure			S-10	72
Basement (2)	not installed			not installed			S-5	72
Basement (3)	11.5	0.046	108.09	could not measure			S-3	84
Basement (4)	11	0.044	105.71	could not measure			S-13	112
Basement (5)	not installed			not installed			S-15	112

## **Notes:**

- \* Measurements were recorded using a digital manometer
- \* Flow collar in duct, 5" & 6" dia. saddle style
- \* Hood equipped with 6" dia. Flow collar
- \* Some measurements not collected, no ceiling against which to place hood

# **Appendix C** **House Three** **Return-Air Flow Measurements**


## **Return Airflows Measurements**

Measurements Method	Flow Collar In Duct			Hood At Grille			Branch	Design
Space	Pressure		Airflow	Pressure		Airflow		Airflow
	pa	"wc	cfm	pa	"wc	cfm		
Main Floor								
Master Bedroom	0.8	0.0032	28.51	0.6	0.0025	24.69	R-7	60
Master Bedroom	not installed			not installed			R-11	60
Main Hall	could not measure			5.1	0.0204	71.98	R-6	130
Main Hall	not installed			not installed			R-8	130
Mid-Bedroom	could not measure			7.3	0.0292	86.12	R-10	60
Front Bedroom	could not measure			7.9	0.0316	89.59	R-9	70
Kitchen	could not measure			2.1	0.0084	46.19	R-2	130
Dining Room	not installed			not installed			R-1	130
Living Room	could not measure			6.9	0.0276	83.73	R-4	130
Basement								
Basement	not installed			not installed			R-3	124
Basement	not installed			not installed			R-5	125
Basement	not installed			not installed			R-12	124


## **Notes:**

- \* Measurements were recorded using a digital manometer
- \* Flow collar in duct, 6" dia. saddle style
- \* Hood equipped with 4" dia. Flow collar
- \* Some measurements not collected with flow collar, joists were panned
- \* Some measurements not collected, no ceiling against which to place hood

**Appendix C**  
**House Three**  
**Photographs of System 1 of 11**  
**H3,001**




**Appendix C**  
**House Three**  
**Photographs of System 2 of 11**  
**H3,002**






**Appendix C**  
**House Three**  
**Photographs of System 3 of 11**




**H3,003**

**Appendix C**  
**House Three**  
**Photographs of System 4 of 11**



**H3,004**

**Appendix C**  
**House Three**  
**Photographs of System 5 of 11**



**H3,005**

**Appendix C**  
**House Three**  
**Photographs of System 6 of 11**



**H3,006**

**Appendix C**  
**House Three**  
**Photographs of System 7 of 11**  
**H3,007**






**Appendix C**  
**House Three**  
**Photographs of System 8 of 11**  
**H3,008**



**Appendix C**  
**House Three**  
**Photographs of System 9 of 11**  
**H3,009**





**Appendix C**  
**House Three**  
**Photographs of System 10 of 11**  
**H3,010**



**Appendix C**  
**House Three**  
**Photographs of System 11 of 11**  
**H3,011**



**Appendix D**  
**Houses One, Two, and Three**  
**Data Collection Equipment**

**Phillips Comparison Test Report**

**Comparison Test of Airflow Results**  
**Pan with Flow Collar – Versus – Saddle Style Flow Collar**

Bert Phillips, P.Eng., MBA

**Objective**

To answer the question, Why were the indicated airflows measured with a flow collar in a pan significantly different than the airflows measured with a saddle type flow measuring device?

**Approach**

Airflows and static pressures were measured using both methods separately and together in two ducts on a forced air heating system. The impact of the flow collar and pan apparatus on airflow was determined by comparing airflows indicated by the saddle type flow measuring device with the flow collar and pans apparatus placed over the grille to those without it over the grille. In a similar fashion, the impact of the saddle type device was determined by comparing airflows indicated by the flow collar and pan apparatus, with and without the saddle device inserted in the duct. The relative accuracy of the devices was assessed by simultaneously measuring indicated airflows for both devices and comparing these values.

**Test Description and Observations**

The measurements were done in a house with exposed forced air ductwork in the basement. Duct #1 was a straight, six inch diameter duct running about 2 meters laterally from the supply trunk to the supply grille boot. Static pressure was measured at the wall of the duct just upstream of the boot to the supply grille. The insertion point for the saddle device was about the mid way between the take off and the boot.

The data (presented in Table 1-D) indicates that placing a pan with flow collar over a supply air grille measurably increases static pressure (or airflow resistance) and reduces airflow. The four inch flow collar and pan affected airflow at a significant level, while the six inch flow collar and pan had a modest impact on airflows. The saddle type flow measuring device appeared not to affect static pressures or air flows at a significant level. For this duct configuration, there was good agreement between airflow measuring methods (i.e., for a given test condition, the pan with flow collar apparatus indicated similar airflows to the saddle device). The position of the pan over the grille was found to have a modest impact on indicated airflow (the range was less than 10% of measured flow).

Duct #2 had an elbow shortly after the take off from the supply trunk, ran straight for about 3 meters then went through two close coupled elbows and into the supply grille boot. Two flow measuring ports for the saddle type device were installed 15 cm downstream of the elbow near the supply trunk, one in the same plane as the duct run and one perpendicular to the plane of the duct run (i.e., one horizontal and one vertical insertion port). A third port was located at the mid point of the long straight duct and a fourth was located about 10 cm upstream of the two close coupled elbows leading to the supply grille boot. Static pressure was measured at the wall of the duct at these same locations.

The configuration for Duct #2 allowed an assessment of the impact of an elbow on the saddle device. The data for Duct #2 indicated that placing a pan with flow collar over a supply air grille increased static pressure or resistance, reducing airflow through the grille, but that the saddle device did not appear to impact airflow very much. The wide range of indicated airflows for the saddle device (i.e., 18 to 38 L/s) shows the impact of location and orientation on the saddle device and confirms the importance of locating airflow measuring devices well away from the influence elbows, balance dampers, fans, etc. The saddle device indicated the same airflows at the third and fourth measurement ports, and this flow was in close agreement with indicated airflow for the pan with the six inch flow collar, but agreement was not so good for the pan with the four inch flow collar. There was not a measurable difference in static pressures between the third and fourth measurement ports.

During the investigation into compliance with Part 9 ventilation requirements in the 1995 NBC, room by room airflows were measured using a six inch flow collar in a box, similar to the one used in the Clarke study. At that time, tests were run to compared indicated flow through a six inch flow collar against that through a calibrated nozzle. Those measurements indicated good agreement. Those tests did not go the step further to evaluate the impact of the hood on airflows.

Two Air Instrument Resources MP6KD micromanometers resolving to 0.001 in.W.G. were used for pressure measurements during these tests. As part of the quality assurance for the tests, the micromanometers were teed to a pressure source and their relative calibration was checked. The micromanometers were in full agreement within the range of pressures measured during the tests.

## **Conclusions**

In the Clarke study, the saddle type airflow measuring device usually indicated higher airflows than the pan with flow collars attached. This is consistent with the findings that the pan with flow collar device restricts airflow to a measurable degree while the saddle device does not appear to appreciably impact airflow.

In some cases, extreme differences in indicated airflows between the two methods may be the result of placing the saddle device too close to an elbow or other device that causes turbulence or non-symmetrical airflow in the duct.

**Table 1 - D**

	SP in. WG			Indicated Airflow L/s			
	Downstream of elbow		Near Boot	Hood	Saddle at Elbow		Saddle In
	//	L			//	L	Straight
Duct #1							
Initial Condition			0.070	...			...
Saddle Inserted			0.070	...			37.8
Pan with 4" collar			0.092	25.1			...
Pan with 4" collar and saddle			0.092	25.1			28.4
Pan with 6" collar			0.073	37.2			...
Pan with 6" collar and saddle			0.073	37.2			36.5
Duct #2							
Initial Condition	0.066	0.075	0.079	...	...	...	...
Saddle Inserted			0.079	...	18.2	37.8	31.6
Pan with 4" collar			0.090	20.7	...	...	...
Pan with 4" collar and saddle			0.090	20.7	11.9	30.8	25.8
Pan with 6" collar			0.080	29.4	...	...	...
Pan with 6" collar and saddle			0.080	29.4	16.9	37.1	30.0

Hood refers to the pan and flow collar device

"//" refers to horizontal insertion port for saddle probe

"L" refers to vertical insertion port for saddle probe

Airflow for flow measuring devices was calculated using the equation:

$$Q = C \times dP^{0.5}$$

where: Q is in L/s


dP is in inches W.G.

C = 101 for the 4 inch flow collar

C = 240 for the 6 inch flow collar

C = 218 for the saddle type flow measuring device


**Appendix D**  
**Houses One, Two, and Three**  
**Photographs of Data Collection Equipment 1 of 3**  
**H123,007**



The above picture displays a plastic food storage container which has been fitted with weatherstripping around its main rim, and a 4 inch diameter opening in the bottom along with a collar to which a 4" diameter floor collar may be taped. The capture hood measures 12" (L) x 5.5" (W) x 5" (D) and was used to measure air flow from 4" x 10" warm-air supply diffusers.




**Appendix D**  
**Houses One, Two, and Three**  
**Photographs of Data Collection Equipment 2 of 3**  
**H123,011**



The above picture displays a plastic kitty litter tray which has been fitted with weatherstripping around its main rim, and a 6" diameter opening in the bottom along with a collar to which a 6" diameter floor collar may be taped. The capture hood measures 16" (L) x 13" (W) x 5.5" (D) and was used to measure air flow to return-air grilles.



**Appendix D**  
**Houses One, Two, and Three**  
**Photographs of Data Collection Equipment 3 of 3**  
**H123,012**



The above picture displays the digital manometer used to collect air-flow data, and a 6" diameter "saddle" style flow collar used to take pressure readings by inserting the probe into a duct of the same diameter. The metal saddle is equipped with a foam backing which enable the flow collar to maintain a sealed contact with the duct surface as measurements are taken.