



Colisée des Bois-Francs Victoriaville (Québec)

MAJOR RETROFIT

Summary

Potential for substantial heat recovery
from refrigeration system

Extensive integration of refrigeration system with
heating, ventilation and dehumidification system

Short-term heat storage

Variable condensing temperature and pressure
(*Floating head pressure*)

Characteristics of Arena

| | |
|---|---|
| Owner | Municipality |
| Built in | 1978 |
| Rebuilt in | 2001 |
| Rink and bleachers | |
| Surface area (footprint) | 4,140 m ² (44,700 ft ²) |
| Volume | 51,000 m ³ (1,814,000 ft ³) |
| Building (including multipurpose hall) | |
| Surface area (footprint) | 13,000 m ² (140,000 ft ²) |
| Volume | 59,000 m ³ (2,084,000 ft ³) |
| Number of rinks | 1 |
| Seating capacity | 2,100 |
| Months operated / year | 9 |
| Hours open / week | 80 |
| Number of ice resurfacings / week | 50 |
| Heated bleachers | Yes, to 15°C (60°F) |
| Annual energy consumption (98 % electricity, 2% natural gas) | 1,560,000 kWh-eq. (in 2003-2004) 130 kWh-eq / m ² (12 kWh-eq. / ft ²) |
| Contract power | 400 kW |
| Annual energy cost | \$90,000 (in 2003-2004) |

Refrigeration System Installed

| | |
|--|---|
| Equipment type | Factory-built commercial packages (2) |
| Compressors | 4 semi-hermetic screw compressors |
| Condensers | 4 tube and shell condensers |
| Evaporators | 2 direct expansion tube and shell evaporators |
| Heat rejection system | Indirect evaporative fluid cooler |
| Refrigerant | HCFC-22 (174 kg combined total for all equipment) |
| Total cooling capacity | 120 tons |
| Operation of condenser | Floating head pressure |
| Heat transfer fluid in cold secondary loop | Mixture of water and methanol |
| Heat transfer fluid in warm secondary loop | Mixture of water and ethylene glycol |

Energy Efficiency Measures

Design

Heat recovery

| | |
|--|--|
| Bleachers heating | Using condensation heat rejected in the warm secondary loop (water/ethylene glycol) and transferred through a coil in the ventilation duct |
| Players' rooms heating | Same system as for bleachers heating |
| Service rooms heating | No measures |
| Domestic water heating | Domestic water is heated to 55 °C by the means of a heat pump using the warm secondary loop as an energy source |
| Heating resurfacing water | Domestic hot water, heated from 55°C to 80°C with a natural gas boiler |
| Preheating outdoor air | No measures |
| Preheating domestic water | Using heat from warm secondary loop by the means of a plate type heat exchanger |
| Heating under ice rink slab | System in place but not used |
| Heat recovery from waste water | No |
| Use of surplus heat exceeding arena heating requirements | No measures |

Thermal storage

Heat storage

| | |
|------------|--|
| Short term | Reserve of 4,500 litres (1,000 gallons) for domestic hot water at 55°C |
| Seasonal | No |

Cold storage

| | |
|------------|----|
| Short term | No |
| Seasonal | No |

Other measures

| | |
|--|---|
| Dehumidifying of ice rink | Air is dehumidified by a cold loop bypass to a coil in the ventilation duct |
| Melting rink scrapings | No measures |
| Modulation of circulating pumps | Yes, variable speed 25 HP pump |
| Reduction of maximum flow in cold secondary loop | No, 2 passes in secondary fluid circuit in the slab |
| Low-emissivity ceiling | No |
| Building Automation System (BAS) | Yes |
| Efficient lighting | |
| High-intensity discharge (HID) lamps | Metal halide, power 31 kW |
| Lighting intensity varied to suit different activities | 2 light intensity levels |
| Lighting switched off when arena not in use | Yes |

Operation

| | |
|--|---------------------------------|
| Modulation of condensing temperature to suit refrigeration and heating needs, and according to outside temperature | Yes, controlled by BAS |
| Electrical demand control through peak-load shifting | Yes, by BAS |
| Resurfacing water temperature lowered | Ajusted manually |
| Modulation of ice temperature set point | Yes, controlled by BAS |
| Indoor temperature lowered during unoccupied periods | Yes, controlled by BAS |
| Refrigeration system shut down during unoccupied periods | Yes, controlled by BAS |
| Circulating pumps shut down during unoccupied periods | Yes, controlled by BAS |
| Ventilation shut down during unoccupied periods | Yes, controlled by BAS |
| Ice thickness management | Ice thickness adjusted manually |
| Lighting reduced for certain activities | Yes, adjusted manually |
| Ice temperature monitored by infrared sensor | Yes, by BAS |

Project Cost


**Overall cost of work, including engineering
(before financial assistance): \$693,300**

Financial assistance for energy efficiency

Agence de l'efficacité énergétique du Québec (AEE)

CETC-Varennnes (through RAPB)

Simplified System Schematic



Benefits

Building energy consumption 14% electrical energy savings for 50% greater cooling capacity compared with previous system. Savings are all the more impressive because some energy saving measures were already in place before the refrigeration system was retrofitted.

Contract power Comparable to the contract power prior to the retrofit, despite a 50% increase in installed cooling capacity

Note : Savings were calculated based on the energy invoices analysed before and after the retrofit only. No adjustments were made to reflect the increase in cooling capacity, the total ice time used, or weather conditions.

Environmental benefits


Greenhouse gas (GHG) emissions The use of modular package refrigeration units enabled to confine the refrigerant in the mechanical room and to reduce by 70% the required amount of refrigerant per ton of cooling capacity. Potential refrigerant leaks were also reduced by the same amount. Since the new refrigeration system was started up, no refrigerant losses were registered, whereas with the old system the leaks accounted for 120 t eq. CO₂ per year.

Effect of refrigerant on ozone layer Significant reduction in the impact on the ozone layer for the above reasons

Other benefits

Reduction of maintenance costs Insufficient data at this time

Qualitative benefits Good quality ice
System more reliable
Greater comfort for spectators



Rationale

Refrigeration system was obsolete

Original capacity was inadequate for growing needs

Sought improved spectator comfort

Solution considered the most cost effective based on life cycle cost analysis over a period of 20 years

Suppliers and Contractors

| | |
|---|--------------------|
| General contractor | LS Réfrigération |
| Refrigeration contractor | LS Réfrigération |
| Manufacturer of refrigeration equipment | Trane |
| Control system | Johnson Controls |
| Mechanical, electrical and structural engineers | Dessau-Soprin Inc. |



RAPB

The Refrigeration Action Program for Buildings (RAPB) fosters the use of innovative refrigeration practices in order to reduce the greenhouse gas emissions that result from the efficient use of energy and the reduction of refrigerant leaks in supermarkets, ice and curling rinks.

A French version is also available

FOR MORE INFORMATION

CANMET Energy Technology Centre - Varennes / Natural Resources Canada

1615, Lionel-boulet Boulevard, P.O. Box 4800, Varennes, (Québec) J3X 1S6 CANADA

Telephone: (450) 652-4621, Facsimile: (450) 652-5177, Website: <http://cetc-varennes.nrcan.gc.ca>, Email : CTEC-CETC.Varennes@nrcan.gc.ca

© Her Majesty the Queen in Right of Canada, 2005

ISBN: 0-662-42019-5

Catalogue no.: M39-116/2-2005E-PDF

2004-154 (PROMO)