



FIRE RESISTANCE TESTS ON SMALL-SCALE FLOOR ASSEMBLIES

Introduction

In recent years, there have been a number of efforts made in North America to improve acoustic isolation in residential building environments. As a result, Canadian building codes have adopted more stringent acoustic requirements. This has led to the need for changes in traditional construction practices. At the same time, new construction materials have been developed, and many product specifications have changed that may alter the fire resistance of floor assemblies. With these changes, there has been a need to reassess existing fire resistance data for common floor constructions.

The research program set out to measure the acoustic performance of full-scale floor assemblies and the fire performance of small- and full-scale floor assemblies. This was done to reaffirm fire resistance ratings and develop cost-effective floor assemblies on the test results.

This report describes the results of 29 small-scale fire resistance tests conducted at the Institute for Research in Construction (IRC).

Building on a preceding collaboration with CMHC, IRC at NRC developed the research plan and organized a supporting consortium. The consortium members were: Canada Mortgage and Housing Corporation, Forintek Canada, Gypsum Manufacturers of Canada, National Research Council Canada, New Home Warranty programs of Ontario, Alberta, British Columbia and the Yukon, Ontario Ministry of Municipal Affairs and Housing,

Owens Corning Fiberglas Canada Inc., Roxul Inc., and the Canadian Home Builders' Association. These partners both supported the project financially, and sent representatives to meet periodically as a Steering Committee, to select specimens for subsequent study, and to adapt the findings for industry use. Several partners, most notably Forintek, also provided substantial in-kind contributions in the form of materials and material characterization. The measurements and analysis were performed by NRC.

Assemblies and Equipment

It was determined that the parameters needed for a full-scale fire resistance test program were:

- subfloor type (oriented strand board (OSB) and plywood),
- insulation thickness (90 mm (3.54 in.), 180 mm (7.08 in.) and full cavity), and
- insulation type (glass, rock and cellulose fibre).

Twenty-nine small-scale test assemblies were constructed—eight with solid wood joists, seven



with wood-I-joists, seven with wood trusses and seven with C-steel joists. All small-scale assemblies were constructed with or without insulation in the floor cavity and were tested unloaded.

Materials used in the assemblies included:

- Ceiling finish (Type X gypsum board).
- Framing—solid woodjoist, wood I-joist, wood truss and C-steel joist.
- Insulation—glass fibre batts; rock fibre batts; cellulose fibre insulation sprayed wet; and cellulose fibre insulation dry blown full cavity.
- Subfloor—Canadian softwood plywood (CSP) and OSB tongue and groove.
- Resilient channels of galvanized steel.

In all fabrications, gypsum board was attached to resilient channels mounted perpendicular to the joists.

Type K chromel-alumel thermocouples were used for measuring temperatures at a number of locations throughout the assembly and on the unexposed surface. Fire resistance tests were carried out using a propane-fired small-scale furnace.

Test Conditions and Procedures

The test assemblies were exposed to heat in such a way that the average temperature of the furnace followed the CAN/ULC-S IOI-M89 standard time-temperature curve as closely as possible.

The temperatures of the furnace and assemblies were recorded at one minute intervals. Average temperatures for the various assemblies with a single layer of gypsum board were measured at the following locations:

- Surface between the gypsum board and joists or trusses.
- Gypsum board surface facing the cavity.
- Joist or truss mid-height.

- Subfloor surface facing the cavity.
- Surface between the subfloor and joist or truss.

An assembly was considered to have failed if one of the following failure criteria occurred:

- 1 . A single point temperature reading measured by one of the five thermocouples under the insulation rose 180°C above the ambient temperature.
2. The average temperature measured by the five thermocouples under insulating pads on the unexposed surface rose 140°C above the ambient temperature.
- 3 . There was passage of flames or gases hot enough to ignite cotton waste at the unexposed surface.

Research Results

The results of the 29 small-scale floor tests are summarized in the following page.

Based on these results, the following conclusions* can be drawn:

- The effect of the subfloor type (OSB and plywood) on the fire resistance of all small-scale assemblies is insignificant.
- For small-scale assemblies with either solid wood or C-steel joists, the effect of glass fibre insulation is insignificant. However, the effect of insulation thickness is significant for assemblies with wood I-joists or wood trusses.
- The installation of either rock or cellulose fibre insulation (90 mm thick) in the floor cavity increases the fire resistance compared to a non-insulated assembly.
- Glass fibre insulation (90 mm thick) in the floor cavity increases the fire resistance for small-scale assemblies with either solid wood joists, wood I-joists or C-steel joists compared to a non-insulated assembly. However, glass fibre insulation reduces the fire resistance in an assembly with

Table I. Small Scale Floor Assembly Parameters and Fire Resistance Test Results

Assembly	Joist			Ceiling Finish			Subfloor		Cavity Insulation			Resilient Channels		Point	Average
Number	Type	Depth	Spacing	Type	Thick	Layers	Type	Thick	Type	Thick	Location	Orient.	Spacing	Failure*	Failure*
		(mm)	(mm)		(mm)			(mm)		(mm)			(mm)	(min)	(min)
SF-01	WJ	235	400	X	15.9	I	OSB	15.9	***	***	***	Per	400	60	56
SF-02	WJ	235	400	X	15.9	I	PLY	15.9	***	***	***	Per	400	54	55
SF-03	WJ	235	400	X	15.9	I	OSB	15.9	GI	90	B	Per	400	65	66
SF-04	WJ	235	400	X	15.9	I	OSB	15.9	GI	180	B	Per	400	66	71
SF-05	WJ	235	400	X	15.9	I	OSB	15.9	GI	270	full	Per	400	63	***
SF-06	WJ	235	400	X	15.9	I	OSB	15.9	CI	125	T	Per	400	80	81
SF-07	WJ	235	400	X	15.9	I	OSB	15.9	RI	90	B	Per	400	76	74
SF-08	WJ	235	400	X	15.9	I	OSB	15.9	CI*	180	B	Per	400	87	***
SF-09	WIJ	240	400	X	15.9	I	OSB	15.9	***	***	***	Per	400	42	41
SF-10	WIJ	240	400	X	15.9	I	PLY	15.9	***	***	***	Per	400	42	43
SF-11	WIJ	240	400	X	15.9	I	OSB	15.9	GI	90	B	Per	400	51	***
SF-12	WIJ	240	400	X	15.9	I	OSB	15.9	GI	180	B	Per	400	51	***
SF-13	WIJ	240	400	X	15.9	I	OSB	15.9	GI	270	full	Per	400	61	***
SF-14	WIJ	240	400	X	15.9	I	OSB	15.9	CI	122	T	Per	400	87	87
SF-15	WIJ	240	400	X	15.9	I	OSB	15.9	RI	90	B	Per	400	81	78
SF-16	WT	305	400	X	15.9	I	OSB	15.9	***	***	***	Per	400	47	47
SF-17	WT	305	400	X	15.9	I	PLY	15.9	***	***	***	Per	400	46	***
SF-18	WT	305	400	X	15.9	I	OSB	15.9	GI	90	B	Per	400	38	40
SF-19	WT	305	400	X	15.9	I	OSB	15.9	GI	180	B	Per	400	47	***
SF-20	WT	305	400	X	15.9	I	OSB	15.9	GI	270	full	Per	400	50	***
SF-21	WT	305	400	X	15.9	I	OSB	15.9	CI	120	T	Per	400	72	***
SF-22	WT	305	400	X	15.9	I	OSB	15.9	RI	90	B	Per	400	82	80
SF-23	SJ	203	400	X	15.9	I	OSB	15.9	***	***	***	Per	400	47	49
SF-24	SJ	203	400	X	15.9	I	PLY	15.9	***	***	***	Per	400	47	47
SF-25	SJ	203	400	X	15.9	I	OSB	15.9	GI	90	B	Per	400	49	***
SF-26	SJ	203	400	X	15.9	I	OSB	15.9	GI	180	B	Per	400	42	42
SF-27	SJ	203	400	X	15.9	I	OSB	15.9	GI	270	full	Per	400	47	***
SF-28	SJ	203	400	X	15.9	I	OSB	15.9	CI	90	T	Per	400	61	***
SF-29	SJ	203	400	X	15.9	I	OSB	15.9	RI	90	B	Per	400	64	64

WJ - Solid wood joist

WIJ - Wood I-joist

WT - Wood truss

SJ - Steel joists (16 ga/18 ga)

X - Type X

CI - Cellulosic fibre insulation (wet

sprayed)

CI* - Cellulosic fibre insulation (dry)

GI - Glass fibre insulation batts

RI - Rock fibre insulation batts

B - Bottom of floor cavity

T - Top of floor cavity

Ply - Plywood

OSB - Oriented strandboard

Per - Perpendicular to joists

*** - Null value

* Fire resistance is in **bold italic** number

wood trusses when compared to a non-insulated assembly.

- For small-scale assemblies with solid wood joists, the assembly with full cavity dry blown cellulose fibre insulation provides more fire resistance than an assembly with full cavity glass fibre insulation.

* These conclusions should not be applied to full-scale floor assemblies.

Project Manager: Jacques Rousseau

Research Reports: *Fire Resistance Tests On Small-Scale Floor Assemblies*

Research Consultants: M.A. Sultan, Y.P. Séguin, P. Leroux and R.C. Monette

A full report on this project is available from the Canadian Housing Information Centre at the address below.

Housing Research at CMHC

Under Part IX of the *National Housing Act*, the Government of Canada provides funds to CMHC to conduct research into the social, economic and technical aspects of housing and related fields, and to undertake the publishing and distribution of the results of this research.

This fact sheet is one of a series intended to inform you of the nature and scope of CMHC's research.

This **Research Highlights** fact sheet is one of a wide variety of housing-related publications produced by CMHC.

For a complete list of **Research Highlights**, or for more information on CMHC housing research and information, please contact:

The Canadian Housing Information Centre
Canada Mortgage and Housing Corporation
700 Montreal Road
Ottawa, ON K1A 0P7

Telephone: 1 800 668-2642
Fax: 1 800 245-9274

OUR WEB SITE ADDRESS: www.cmhc-schl.gc.ca/Research