



Government
of Canada

Gouvernement
du Canada

Canadian General
Standards Board

Office des normes
générales du Canada

CAN/CGSB-3.22-2012

Supersedes CAN/CGSB-3.22-2002

Reaffirmed

September 2017

National Standard of Canada

Wide-Cut Type Aviation Turbine Fuel (Grade JET B)

Canadian General Standards Board 



Standards Council of Canada
Conseil canadien des normes

Canada 

Experience and excellence
Expérience et excellence

CGSB
ONGC

The CANADIAN GENERAL STANDARDS BOARD (CGSB), under whose auspices this standard has been developed, is a government agency within Public Services and Procurement Canada. CGSB is engaged in the production of voluntary standards in a wide range of subject areas through the media of standards committees and the consensus process. The standards committees are composed of representatives of relevant interests including producers, consumers and other users, retailers, governments, educational institutions, technical, professional and trade societies, and research and testing organizations. Any given standard is developed on the consensus of views expressed by such representatives.

CGSB has been accredited by the Standards Council of Canada as a national standards-development organization. The standards that it develops and offers as National Standards of Canada conform to the criteria and procedures established for this purpose by the Standards Council of Canada. In addition to standards it publishes as National Standards of Canada, CGSB produces standards to meet particular needs, in response to requests from a variety of sources in both the public and private sectors. Both CGSB standards and CGSB national standards are developed in conformance with the policies described in the CGSB Policy and Procedures Manual for the Development and Maintenance of Standards.

CGSB standards are subject to review and revision to ensure that they keep abreast of technological progress. CGSB will initiate the review of this standard within five years of the date of publication. Suggestions for their improvement, which are always welcome, should be brought to the notice of the standards committees concerned. Changes to standards are issued either as separate amendment sheets or in new editions of standards.

An up-to-date listing of CGSB standards, including details on latest issues and amendments, and ordering instructions, is found in the CGSB Catalogue at our Web site — www.tpsgc-pwgsc.gc.ca/ongc-cgsb/index-eng.html along with more information about CGSB products and services.

Although the intended primary application of this standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

The testing and evaluation of a product against this standard may require the use of materials and/or equipment that could be hazardous. This document does not purport to address all the safety aspects associated with its use. Anyone using this standard has the responsibility to consult the appropriate authorities and to establish appropriate health and safety practices in conjunction with any applicable regulatory requirements prior to its use. CGSB neither assumes nor accepts any responsibility for any injury or damage that may occur during or as the result of tests, wherever performed.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. CGSB shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Language

In this Standard, “shall” states a mandatory requirement, “should” expresses a recommendation and “may” is used to express an option or that which is permissible within the limits of this Standard. Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material. Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

Further information on CGSB and its services and standards may be obtained from:

The Manager
Standards Division
Canadian General Standards Board
Gatineau, Canada
K1A 1G6

A National Standard of Canada is a standard developed by an SCC-accredited Standards Development Organization (SDO), and approved by the Standards Council of Canada (SCC), in accordance with SCC's: *Requirements and Guidance-Accreditation for Standards Development Organizations, and Requirements and Guidance-Approval of National Standards of Canada Designation*. More information on National Standard requirements can be found at www.scc.ca.

An SCC-approved standard reflects the consensus of a number of experts whose collective interests provide, to the greatest practicable extent, a balance of representation of affected stakeholders. National Standards of Canada are intended to make a significant and timely contribution to the Canadian interest.

SCC is a Crown corporation within the portfolio of Industry Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts. Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Users should always obtain the latest edition of a National Standard of Canada from the standards development organization responsible for its publication, as these documents are subject to periodic review.

The responsibility for approving standards as NSCs rests with:

Standards Council of Canada
55 Metcalfe Street, Suite 600
Ottawa, Ontario K1P 6L5, CANADA

How to order CGSB Publications:

by telephone — 819-956-0425 *or*
— 1-800-665-2472

by fax — 819-956-5740

by mail — CGSB Sales Centre
Gatineau, Canada
K1A 1G6

in person — Place du Portage
Phase III, 6B1
11 Laurier Street
Gatineau, Quebec

by email — ncr.cgsb-ongc@tpsgc-pwgsc.gc.ca

on the Web — www.tpsgc-pwgsc.gc.ca/ongc-cgsb/index-eng.html

NATIONAL STANDARD OF CANADA

CAN/CGSB-3.22-2012

Supersedes CAN/CGSB-3.22-2002

Reaffirmed
September 2017

Wide-Cut Type Aviation Turbine Fuel (Grade JET B)

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS
FRANÇAISE ET ANGLAISE.

ICS 75.160.20

Published September 2012 by the
Canadian General Standards Board
Gatineau, Canada K1A 1G6

© HER MAJESTY THE QUEEN IN RIGHT OF CANADA,
as represented by the Minister of Public Works and Government Services,
the Minister responsible for the Canadian General Standards Board (2012).

No part of this publication may be reproduced in any form without the prior permission of the publisher.

CANADIAN GENERAL STANDARDS BOARD
Committee on Aviation Fuels
(Voting membership at date of reaffirmation)

Chair

Poitras, P.

National Defence (User)

General interest category

Hanganu, A.
MacLean, G.
Johnston, J.
Levesque, P.
Pama, M.
Pickard, A. L.
Porter, S.
Tharby, R. D.
Wispinski, D.
Zakarian, J.

Inspectorate — A Bureau Veritas Group Company
Intertek Cargo and Analytical Assessment
InnoTech Alberta
SGS
Certispec Services Inc.
Consultant
Biofuels Consulting Canada
Tharby Technology, Consultants
VUV Analytics
Anton Paar

Producer category

Allain, T.
Burgazli, J.
Camp, K.
Conn, A.
Geoffroy, L.
Hillmer, A.
Hiscock, R.
Gropp, R.
Macagnone, M.
Mitchell, K.
Munroe, D.

Irving Oil Ltd.
 Innospec Inc.
 Imperial Oil Ltd.
 Ethyl Corporation
 Valero Energy Inc.
 Consumers' Co-operative Refineries Limited
 NARL Refining LP
 GE Water and Process Technologies
 BASF
 Shell Canada Products
 Suncor Energy Products Partnership

Regulator category

Bilcock, D.

Transport Canada

User category

Ardiles, C.
Brar, C.
Day, T.
Howse, J.
Hutchison, N.
MacLeod, B.
Waddleton, D.

Government of the Northwest Territories
Air Canada
WestJet Airlines Ltd.
FSM Management Group
Government of Nunavut
Public Services and Procurement Canada
Pratt & Whitney Canada Corporation

Secretary (non-voting)

Schuessler, M.

Canadian General Standards Board

Acknowledgment is made for the translation of this National Standard of Canada by the Translation Bureau of Public Services and Procurement Canada.

CAN/CGSB-3.22-2012

Supersedes CAN/CGSB-3.22-2002

Reaffirmed

September 2017

Preface to the National Standard of Canada

This National Standard of Canada has been reaffirmed by the CGSB Committee on Aviation Fuels. An editorial change has been made by the correction of the following paragraph:

7.9.1 The publications referred to in par. 2.1.1 and 7.8.1 may be obtained from ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, U.S.A., telephone 610-832-9585, fax 610-832-9555, or from IHS Markit, 200-1331 MacLeod Trail SE, Calgary, Alberta T2G 0K3, telephone 613-237-4250 or 1-800-267-8220, fax 613-237-4251, Web site www.global.ihs.com.

NOTE ASTM International Standards are not available in French. Titles of the ASTM International Standards may have changed, but all were active standards at the time of the reaffirmation.

CANADIAN GENERAL STANDARDS BOARD

WIDE-CUT TYPE AVIATION TURBINE FUEL (GRADE JET B)

1. SCOPE

- 1.1 This standard applies to JET B wide-cut type aviation turbine fuel, consisting of hydrocarbons, and naturally occurring non-hydrocarbons derived from petroleum, and additives as specified herein. Wide-cut type aviation fuels are low flash, volatile naphtha and kerosene blends, having a wide boiling range and a low-freezing point.

Note: Volatility is not controlled by flash point but rather by a maximum vapour pressure limit.

- 1.2 Grade JET B fuel is normally used in civil aviation operations in aircraft that have been approved to use this fuel.

- 1.3 **Limitations for Use** — Aircraft operators should consult their aircraft manuals for the type of fuel, fuel additives and other limitations.

- 1.4 The testing and evaluation of a product against this standard may require the use of materials and/or equipment that could be hazardous. This document does not purport to address all the safety aspects associated with its use. Anyone using this standard has the responsibility to consult the appropriate authorities and to establish appropriate health and safety practices in conjunction with any applicable regulatory requirements prior to its use.

2. REFERENCED PUBLICATIONS

- 2.1 The following publications are referenced in this standard:

- 2.1.1 ASTM International

Annual Book of ASTM Standards (Appendix A).

- 2.1.2 U.S. Department of Defense

MIL-PRF-25017 — Inhibitor, Corrosion/Lubricity Improver, Fuel Soluble

QPL-25017 — Qualified Products List of Products Qualified Under Performance Specification MIL-PRF-25017 Inhibitor, Corrosion/Lubricity Improver, Fuel Soluble.

- 2.2 A dated reference in this standard is to the issue specified. An undated reference in this standard is to the latest issue, unless otherwise specified by the authority applying this standard. The sources are given in the Notes section.

3. GENERAL REQUIREMENTS

- 3.1 Hydrocarbons shall include products derived from crude oil, including crude from oil sands.
- 3.2 The fuel shall be visually clear and free from undissolved water and particulate matter.
- 3.3 The odour of the fuel should not be nauseating or irritating.

4. DETAILED REQUIREMENTS

- 4.1 The detailed requirements shall apply to the fuel unless otherwise specified herein.

- 4.2 The fuel shall comply with the detailed requirements specified in par. 4.4 to 4.13 using the test methods indicated. The specified limiting values shall not be changed. This precludes any allowances for the test method precision and adding or subtracting digits.
- 4.3 To determine conformance with the specified limiting values, an observed value or a calculated value shall be “rounded off to the nearest unit” in the last right-hand digit used in expressing the specified limiting value, in accordance with the rounding-off method of ASTM E29.
- 4.3.1 Where test values differ between two parties, a resolution shall be in accordance with ASTM D3244 in order to determine conformance with the specified limiting values, with the criticality of the limits set at $P = 0.5$.

Specified Limiting Values

	Property	JET B		Test Method
		Min.	Max.	ASTM
4.4	Composition			
4.4.1	Acidity, total, mg KOH/g	—	0.10	D3242
4.4.2	Aromatics, % by volume	—	25	D1319 ¹ or
		—	26.5	D6379
4.4.3	Sulphur, total, % by mass	—	0.30	D4294 ¹ , D5453 or D7039 (par. 4.14)
4.4.4	Sulphur, ² mercaptan, % by mass	—	0.003	D3227
4.5	Volatility			
4.5.1	Distillation temperature, °C			D86 ³
	a. Initial boiling point	Report		
	b. 10% recovered	Report		
	c. 20% recovered	90	145	
	d. 50% recovered	110	190	
	e. 90% recovered	Report		
	f. Final boiling point	—	270	
4.5.2	Residue, % by volume	—	1.5	D86
4.5.3	Loss, % by volume	—	1.5	D86
4.5.4	Vapour pressure, kPa	—	21	D5191
4.6	Fluidity			
4.6.1	Freezing point, °C	—	-50	D2386 or D5972 ^{1, 4}

¹ In the event of a dispute, this method shall be the referee method.

² The mercaptan sulphur determination may be waived if the fuel is considered “sweet”, and receives a negative result by the doctor test described in ASTM D4952.

³ The test values shall be reported to the nearest 0.5 °C.

⁴ ASTM D5972 may produce a higher (warmer) result than D2386 on wide-cut fuels such as JET B.

	Property	JET B		Test Method
		Min.	Max.	ASTM
4.7	Combustion			
4.7.1	Smoke point, mm or	25	—	D1322
4.7.2	Smoke point, mm and Naphthalene, % by volume	18 —	— 3.0	D1322 D1840
4.7.3	Net heat of combustion, lower heating value, MJ/kg	42.8	—	D4529, D3338 or D4809 ¹
4.8	Corrosion			
4.8.1	Copper strip, 2 h at 100°C	—	No. 1	D130
4.9	Thermal Stability			
4.9.1	Filter pressure drop, 260°C minimum heater-tube- controlled temperature, mm Hg	—	25 ⁵	D3241
4.9.2	Tube deposit	Less than 3		D3241
4.9.3	Visual examination, on the heater tube, darkest deposits	No peacock (rainbow) or abnormal colour deposits		D3241
4.10	Contaminants (par. 7.7)			
4.10.1	Particulate matter at time of delivery to			D2276 or D5452 ⁶
	a. Purchaser's storage, mg/L	—	2.2	
	b. Aircraft and refuellers, mg/L	—	0.44	
4.10.2	Micro-separometer, ⁷ rating (par. 7.5)			D3948
	a. Without static dissipator additive, or	85	—	
	b. With static dissipator additive	70	—	
4.11	Conductivity			
4.11.1	Electrical conductivity, at point, time and temperature of delivery (par. 5.2), pS/m	50	600	D2624
4.12	Additives (par. 7.6)			

⁵ The SI unit equivalent for the pressure differential maximum is approximately 3.3 kPa, however, the exact maximum is given in mm Hg for compatibility with the instrumentation specified in ASTM D3241.

⁶ ASTM D2276 and D5452 refer to different sampling procedures. In some situations it may not be practical to sample according to D2276; however, when results are obtained by both methods, D2276 shall be considered the referee method.

⁷ The minimum micro-separometer (MSEP) rating applies up to the point immediately before the fuel enters dedicated transportation to airport storage. When the fuel enters dedicated transportation to airport storage, or when the fuel is already in airport storage, the MSEP rating requirement shall not apply. When a fuel system icing inhibitor (par. 5.5) or a corrosion inhibitor/lubricity improver (par. 5.6) is added, the MSEP limits apply before its addition.

	Property	JET B		Test Method
		Min.	Max.	ASTM
4.12.1	Static dissipator additive (par. 5.2), mg/L			
	a. Original addition	—	3	
	b. Cumulative	—	5	
4.12.2	Antioxidant (par. 5.3), mg/L	Optional		
		—	24	
4.12.3	Metal deactivator (par. 5.4), mg/L	Optional		
	a. Original addition	—	2.0	
	b. Cumulative	—	5.7	
4.12.4	Fuel system icing inhibitor (par. 5.5), % by volume	Optional		D5006
		0.10	0.15	
4.12.5	Corrosion inhibitor/ lubricity improver (par. 5.6)	Optional		
4.12.6	Leak detection additive (par. 5.7), mg/kg	Optional		
		—	1	
4.13	Density			
4.13.1	Density at 15°C, kg/m ³	751	802	D1298 ¹ or D4052
4.14	Sulphur — The precision and bias of sulphur determinations using ASTM D7039 on diluted samples have not been determined. The accuracy of this method for jet fuel beyond 2000 mg/kg sulphur has not been validated by an interlaboratory study. Users are cautioned to conduct their own validation when using this test method for fuel containing more than 2000 mg/kg sulphur.			
5.	ADDITIVE REQUIREMENTS			
5.1	Only the additives listed in par. 5.2 to 5.7 may be added to the fuel. Refer to par. 4.12 for specified limiting values and test method for each property. When additives are added to the fuel, the supplier shall record the amount and names of the additive.			
5.1.1	The amount of each additive used in the fuel shall be determined by the test method (par. 4.12) or by volume reconciliation. Procedures for volume reconciliation should include recording the volume of additive introduced to the fuel and the volume of fuel additized, in appropriate units.			
5.2	Static Dissipator Additive (SDA) — Static dissipator additive Stadis® 450 ⁸ shall be added to the fuel to meet the electrical conductivity requirements specified in par. 4.11.1. The original concentration of the SDA shall not exceed 3 mg/L.			
5.2.1	When additive depletion is evident by a conductivity loss, further addition of the SDA is permitted as follows:			
	— If the original concentration of the SDA is not known, an original addition of 3 mg/L is assumed and further addition of SDA shall not exceed 2 mg/L.			
	— The cumulative concentration of the SDA shall not exceed 5 mg/L.			

⁸ Stadis® 450, a registered trademark of Innospec Fuel Specialties LLC, is distributed globally by Innospec Fuel Specialties LLC.

5.2.2 Electrical conductivity varies with temperature. A typical relationship follows:

$$\log k_t = a(t - t_1) + \log k_{t_1}$$

where:

k_t = electrical conductivity at temperature t , °C

k_{t_1} = electrical conductivity at temperature t_1 , °C

a = a factor that depends on fuel composition but normally within the range 0.013 to 0.018 for wide-cut type aviation turbine fuels

5.2.2.1 The temperature-conductivity factor, a , increases at or below an approximate temperature of -10°C. For conductivity at very low temperatures, it is recommended that a separate factor be determined based on actual measurements at the lowest temperatures likely to be encountered. For more information on how low temperature affects conductivity, see ASTM D2624.

5.3 **Antioxidants** — Only the following antioxidants may be added separately or in combination to the fuel. The total concentration (not including mass of solvent) shall not exceed 24 mg/L.

- a. 2,6-di-*tert*-butylphenol
- b. 2,6-di-*tert*-butyl-4-methylphenol
- c. 2-*tert*-butyl-4,6-dimethylphenol (2,4-dimethyl-6-tertiary butylphenol)
- d. 75% minimum, 2,6-di-*tert*-butylphenol
25% maximum mixture of *tert*- and tri-*tert*-butylphenols
- e. 55% minimum, 2-*tert*-butyl-4,6-dimethylphenol (2,4-dimethyl-6-tertiary butylphenol)
15% minimum, 2,6-di-*tert*-butyl-4-methylphenol
Remainder as methyl and dimethyl *tert*-butylphenols
- f. 72% minimum, 2-*tert*-butyl-4,6-dimethylphenol (2,4-dimethyl-6-tertiary butylphenol)
28% maximum, methyl and dimethyl *tert*-butylphenols.

Note: The names of the antioxidants conform to the International Union of Pure and Applied Chemistry (IUPAC) naming convention. In some cases, the common name of the antioxidant has been included in brackets after the IUPAC name.

5.4 **Metal Deactivator** — Only N,N'-disalicylidene-1,2-propane-diamine may be added as a metal deactivator at a concentration not exceeding 2.0 mg/L (not including mass of solvent) on the initial fuel manufactured at the refinery. Higher concentrations are permitted in circumstances where copper contamination is suspected to have occurred during distribution. Cumulative concentration of metal deactivator when re-treating the fuel shall not exceed 5.7 mg/L (par. 7.3).

5.5 **Fuel System Icing Inhibitor** — When specified by the purchaser (par. 7.1) and agreed by the supplier and the purchaser, a fuel system icing inhibitor conforming to ASTM D4171 (Type III [DIEGME]) shall be added to the fuel (par. 4.12.4).

5.6 **Corrosion Inhibitors/Lubricity Improvers** — When specified by the purchaser (par. 7.1) and agreed by the supplier and the purchaser, a corrosion inhibitor/lubricity improver shall be added to the fuel (par. 7.2).

5.6.1 Only a corrosion inhibitor/lubricity improver qualified to U.S. Military Specification MIL-PRF-25017 and listed in the associated Qualified Product List (QPL) 25017 shall be added to the fuel. The concentration of the additive in the fuel shall be as specified in the QPL, and its introduction into the fuel shall be separate from the addition of other additives.

- 5.7 **Leak Detection Additive**⁹ — Only Tracer A (LDTA-A®)¹⁰ may be added as a leak detection additive. The maximum concentration is 1 mg/kg.
6. **INSPECTION**
- 6.1 **Sampling** — Samples for testing shall be obtained in accordance with ASTM D4057. For automatic sampling ASTM D4177 shall be used. Sampling for volatility measurement shall be done in accordance with ASTM D5842.
7. **NOTES**
- 7.1 **Options** — The following options may be specified in the application of this standard:
- a. Fuel system icing inhibitor (par. 5.5)
 - b. Corrosion inhibitor/lubricity (par. 5.6).
- 7.2 **Lubricity Information Statement**
- 7.2.1 Lubricity, which is the ability of jet fuel to act as a lubricant for certain aircraft fuel-wetted components, can vary considerably. It depends on the design, materials used and the intrinsic lubricity of the fuel. There have been a few isolated cases of engine hardware failures directly attributed to low-lubricity fuel.
- 7.2.2 ASTM D5001 may be used to identify low-lubricity fuel since this standard does not address the measurement of fuel lubricity. Hydrogen-processing¹¹ usually produces fuels with lower lubricity. Blending or commingling with non-hydrogen-processed fuels will improve lubricity, and the use of lubricity-improver additives (corrosion inhibitors) may offer a solution.
- 7.2.3 Problems are more likely to occur when aircraft operations are confined to a single refinery source where fuel is severely hydrogen-processed¹² and where there is no commingling with fuels from other sources during distribution between refinery and the aircraft.
- 7.3 **Copper Information Statement**
- 7.3.1 The contamination of jet fuel can occur during manufacture or during the distribution in marine vessels with copper coils, and from the copper-alloy components and fittings in sampling points.
- 7.3.2 Trace levels of copper, in the parts per billion range, can be sufficient to degrade the ASTM D3241 Jet Fuel Thermal Oxidation Tester test result. Where the possibility of copper pickup is suspected, an approved metal deactivator as specified in par. 5.4 may be added to preserve or restore the thermal stability of the fuel, or both. Note that ASTM D6732 can be used to measure the concentration of copper in jet fuel.
- 7.4 **Colour Information Statement** — While this standard does not have a colour requirement, colour can be a useful indicator of fuel quality or contamination. Normally fuel colour ranges from water white (colourless) to a pale straw yellow. Other fuel colours can be the result of crude oil characteristics or refining processes. Darkening of fuel or a change in fuel colour can be the result of product contamination and can indicate that the fuel is off-specification, which could render it unfit and not acceptable for aircraft or engine use, or both. Fuel having various shades of colour, that is, pink, red, green, blue, or a change in colour from the supply source should be investigated to determine the cause of the colour change to ensure suitability for aircraft or engine use, or both.

⁹ *The Tracer Tight methodology to detect and locate leaks in ground-based fuel storage, delivery and dispensing systems does not form part of this standard. Refer to the additive supplier for this information. Praxair Services, Inc. can be contacted at 3755 N. Business Center Drive, Tucson, AZ 85705, U.S.A., telephone 1-800-989-9929, Web site www.praxair.com.*

¹⁰ *Tracer A (LDTA-A®) is a registered trademark of Praxair Services, Inc.*

¹¹ *Hydrogen-processing is any petroleum refining process that uses hydrogen in the presence of a catalyst such as hydrotreating, hydrofining or hydrocracking.*

¹² *Severely hydrogen-processed fuels are those that have been subjected to a hydrogen partial pressure of greater than 7 MPa (70 bar or 1015 psi) during manufacture.*

- 7.5 **Water Separation Characteristic Information Statement** — The ease of coalescence of water from fuels as influenced by surface-active agents (surfactants) may be assessed by ASTM D3948. A high water separation characteristic rating suggests a fuel free of surfactants, whereas a low rating indicates the presence of surfactants. Surfactants can disarm coalescers, thus allowing water to pass through coalescer-filters and remain in the fuel. Surfactants can be introduced into the fuel downstream from a refinery distribution system, in storage facilities or deliberately introduced through the addition of specific approved additives. In light of the factors that can degrade water separation characteristics, options such as supplying higher water separation characteristics than the minimum specification should be considered at the point of origin depending upon the means of distribution.
- 7.6 **Refinery Processing Additive Information Statement** — Additives used in refinery processes, such as corrosion inhibitors, can be carried over in trace quantities into aviation fuel. In a few isolated cases this has resulted in operational problems in aircraft fuel systems. Moreover, the tests and requirements specified in this standard may not be sufficient for detecting trace levels of refinery processing additives. It is therefore recommended that adequate quality assurance and management of change procedures, such as formal risk assessments, be in place to ensure that any relevant refinery processing additive use is well defined and controlled in order to maintain the quality of the finished product.
- 7.7 **Biodiesel Esters Information Statement** — Biodiesel Esters (Fatty Acid Methyl Esters – FAME) materials are not acceptable components in aviation turbine fuels. Increasing use of FAME has raised concerns about fuel contamination, particularly in non-dedicated distribution systems. Therefore producers, distributors and users need to take appropriate precautions to avoid contamination. Contact Transport Canada for the latest information regarding FAME contamination. Relevant Transport Canada Service Difficulty Advisories and Service Difficulty Alerts should be consulted. These can be accessed via the Transport Canada Web site at <http://www.tc.gc.ca/civilaviation/certification/continuing/menu.htm>, and enquiries can be sent to Transport Canada at cawwebfeedback@tc.gc.ca.
- 7.8 **Related Publications**
- 7.8.1 ASTM International
- D5001 — Standard Test Method for Measurement of Lubricity of Aviation Turbine Fuels by the Ball-on-Cylinder Lubricity Evaluator (BOCLE)
- D6732 — Standard Test Method for Determination of Copper in Jet Fuels by Graphite Furnace Atomic Absorption Spectrometry.
- 7.9 **Sources of Referenced Publications**
- The following addresses were valid at the date of publication.*
- 7.9.1 The publications referred to in par. 2.1.1 and 7.8.1 may be obtained from ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, U.S.A., telephone 610-832-9585, fax 610-832-9555, Web site www.astm.org, or from IHS Canada, 1 Antares Drive, Suite 200, Ottawa, Ontario K2E 8C4, telephone 613-237-4250 or 1-800-267-8220, fax 613-237-4251, gic@ihscanada.ca, Web site www.ihs.com.
- 7.9.2 The publications referred to in par. 2.1.2 may be obtained from the Document Automation and Production Service, 700 Robbins Avenue, Building 4/D, Philadelphia, PA 19111-5094, U.S.A. Fax 215-697-1462. Web site <https://assist.daps.dla.mil/quicksearch>.

(This appendix forms a mandatory part of the standard.)

REFERENCED ASTM PUBLICATIONS (par. 2.1.1)

Annual Book of ASTM Standards

D86	Standard Test Method for Distillation of Petroleum Products at Atmospheric Pressure
D130	Standard Test Method for Corrosiveness to Copper from Petroleum Products by Copper Strip Test
D1298	Standard Test Method for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method
D1319	Standard Test Method for Hydrocarbon Types in Liquid Petroleum Products by Fluorescent Indicator Adsorption
D1322	Standard Test Method for Smoke Point of Kerosine and Aviation Turbine Fuel
D1840	Standard Test Method for Naphthalene Hydrocarbons in Aviation Turbine Fuels by Ultraviolet Spectrophotometry
D2276	Standard Test Method for Particulate Contaminant in Aviation Fuel by Line Sampling
D2386	Standard Test Method for Freezing Point of Aviation Fuels
D2624	Standard Test Methods for Electrical Conductivity of Aviation and Distillate Fuels
D3227	Standard Test Method for (Thiol Mercaptan) Sulfur in Gasoline, Kerosine, Aviation Turbine, and Distillate Fuels (Potentiometric Method)
D3241	Standard Test Method for Thermal Oxidation Stability of Aviation Turbine Fuels
D3242	Standard Test Method for Acidity in Aviation Turbine Fuel
D3244	Standard Practice for Utilization of Test Data to Determine Conformance with Specifications
D3338	Standard Test Method for Estimation of Net Heat of Combustion of Aviation Fuels
D3948	Standard Test Method for Determining Water Separation Characteristics of Aviation Turbine Fuels by Portable Separometer
D4052	Standard Test Method for Density, Relative Density, and API Gravity of Liquids by Digital Density Meter
D4057	Standard Practice for Manual Sampling of Petroleum and Petroleum Products
D4171	Standard Specification for Fuel System Icing Inhibitors
D4177	Standard Practice for Automatic Sampling of Petroleum and Petroleum Products
D4294	Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy Dispersive X-Ray Fluorescence Spectroscopy
D4529	Standard Test Method for Estimation of Net Heat of Combustion of Aviation Fuels
D4809	Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter (Precision Method)
D4952	Standard Test Method for Qualitative Analysis for Active Sulfur Species in Fuels and Solvents (Doctor Test)
D5006	Standard Test Method for Measurement of Fuel System Icing Inhibitors (Ether Type) in Aviation Fuels

D5191	Standard Test Method for Vapor Pressure of Petroleum Products (Mini Method)
D5452	Standard Test Method for Particulate Contamination in Aviation Fuels by Laboratory Filtration
D5453	Standard Test Method for Determination of Total Sulfur in Light Hydrocarbons, Spark Ignition Engine Fuel, Diesel Engine Fuel, and Engine Oil by Ultraviolet Fluorescence
D5842	Standard Practice for Sampling and Handling of Fuels for Volatility Measurement
D5972	Standard Test Method for Freezing Point of Aviation Fuels (Automatic Phase Transition Method)
D6379	Standard Test Method for Determination of Aromatic Hydrocarbon Types in Aviation Fuels and Petroleum Distillates — High Performance Liquid Chromatography Method with Refractive Index Detection
D7039	Standard Test Method for Sulfur in Gasoline and Diesel Fuel by Monochromatic Wavelength Dispersive X-ray Fluorescence Spectrometry
E29	Standard Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications.