



Government
of Canada

Gouvernement
du Canada

Canadian General Standards Board Office des normes
générales du Canada

CAN/CGSB-3.0

No./N° 20.9-2005

Reaffirmed October 2013/Confirmée octobre 2013

ICS 71.040.40

WITHDRAWAL

December 2018

Methods of testing petroleum and associated products CGSB Cetane Index of diesel fuels

This National Standard of Canada is hereby withdrawn due to limited use and support for its revision.

The Standards Council of Canada requires that accredited Standards Development Organizations, such as the CGSB, regularly review a consensus Standard to determine whether to re-approve, revise or withdraw. The review cycle is normally five years from the publication date of the latest edition of the Standard. CGSB retains the right to develop new editions.

The information contained in the Standard was originally developed pursuant to a voluntary standards development initiative of the CGSB. The information contained therein may no longer represent the most current, reliable, and/or available information on this subject. CGSB hereby disclaims any and all claims, representation or warranty of scientific validity, or technical accuracy implied or expressed respecting the information therein contained. The CGSB shall not take responsibility nor be held liable for any errors, omissions, inaccuracies or any other liabilities that may arise from the provision or subsequent use

RETRAIT

Décembre 2018

Méthodes d'essai des produits pétroliers et produits connexes Indice de cétane ONGC des combustibles diesels

Cette Norme nationale du Canada est retirée par le présent avis en raison de son utilisation limitée et du manque de support pour sa révision.

Le Conseil canadien des normes exige que les organismes accrédités d'élaboration de normes, tel que l'ONGC, effectue régulièrement un examen des normes consensuelles afin de déterminer s'il y a lieu d'en renouveler l'approbation, de les réviser ou de les retirer. Le cycle d'examen d'une norme est généralement de cinq ans à partir de la date de publication de la dernière édition de celle-ci. L'ONGC se réserve le droit d'élaborer de nouvelles éditions.

L'information contenue dans la norme a été élaborée initialement en vertu d'une initiative volontaire d'élaboration de normes de l'ONGC. Elle peut ne plus représenter l'information disponible et/ou l'information la plus actuelle ou la plus fiable à ce sujet. L'ONGC décline par la présente toute responsabilité à l'égard de toute affirmation, déclaration ou garantie de validité scientifique ou d'exactitude technique implicite ou explicite relative à l'information contenue dans la norme. L'ONGC n'assumera aucune responsabilité et ne sera pas tenu responsable quant à toute erreur, omission, inexactitude ou autre

of such information.

Copies of withdrawn standards are available from the CGSB Sales Centre by telephone at 819-956-0425 or 1-800-665-2472, by fax at 819-956-5740, by Internet at www.tpsgc-pwgsc.gc.ca/ongc-cgsb/index-eng.html, by e-mail at ncr.CGSB-ONGC@tpsgc-pwgsc.gc.ca or by mail at Sales Centre, Canadian General Standards Board, 11 Laurier Street, Gatineau, Canada K1A 1G6.

conséquence pouvant découler de la fourniture ou de l'utilisation subséquente de cette information.

Des copies des normes retirées peuvent être obtenues auprès du Centre des ventes de l'ONGC. Il suffit d'en faire la demande par téléphone au 819-956-0425 ou 1-800-665-2472, par télécopieur au 819-956-5740, par Internet à : www.tpsgc-pwgsc.gc.ca/ongc-cgsb/index-fra.html, par courriel à ncr.CGSB-ONGC@tpsgc-pwgsc.gc.ca, ou par courrier adressé au Centre des ventes, Office des normes générales du Canada, 11, rue Laurier, Gatineau, Canada K1A 1G6.



Government
of Canada

Gouvernement
du Canada

Canadian General
Standards Board

Office des normes
générales du Canada

CAN/CGSB-3.0 **No. 20.9-2005**

Supersedes CAN/CGSB-3.0

No. 20.9-95

Reaffirmed

October 2013

Incorporating Corrigendum No. 1

Methods of testing petroleum and associated products

CGSB Cetane Index of diesel fuels

ICS 71.040.40



Standards Council of Canada
Conseil canadien des normes

National Standard of Canada

Canada

Experience and excellence

Expérience et excellence



The CANADIAN GENERAL STANDARDS BOARD (CGSB), under whose auspices this standard has been developed, is a government agency within Public Works and Government Services Canada. CGSB is engaged in the production of voluntary standards in a wide range of subject areas through the media of standards committees and the consensus process. The standards committees are composed of representatives of relevant interests including producers, consumers and other users, retailers, governments, educational institutions, technical, professional and trade societies, and research and testing organizations. Any given standard is developed on the consensus of views expressed by such representatives.

CGSB has been accredited by the Standards Council of Canada as a national standards-development organization. The standards that it develops and offers as National Standards of Canada conform to the criteria and procedures established for this purpose by the Standards Council of Canada. In addition to standards it publishes as National Standards of Canada, CGSB produces standards to meet particular needs, in response to requests from a variety of sources in both the public and private sectors. Both CGSB standards and CGSB national standards are developed in conformance with the policies described in the CGSB Policy and Procedures Manual for the Development and Maintenance of Standards.

CGSB standards are subject to review and revision to ensure that they keep abreast of technological progress. CGSB will initiate the review of this standard within five years of the date of publication. Suggestions for their improvement, which are always welcome, should be brought to the notice of the standards committees concerned. Changes to standards are issued either as separate amendment sheets or in new editions of standards.

An up-to-date listing of CGSB standards, including details on latest issues and amendments, and ordering instructions, is found in the CGSB Catalogue at our Web site — www.tpsgc-pwgsc.gc.ca/ongc-cgsb along with more information about CGSB products and services.

Although the intended primary application of this standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

The testing and evaluation of a product against this standard may require the use of materials and/or equipment that could be hazardous. This document does not purport to address all the safety aspects associated with its use. Anyone using this standard has the responsibility to consult the appropriate authorities and to establish appropriate health and safety practices in conjunction with any applicable regulatory requirements prior to its use. CGSB neither assumes nor accepts any responsibility for any injury or damage that may occur during or as the result of tests, wherever performed.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. CGSB shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Further information on CGSB and its services and standards may be obtained from:

The Manager
Standards Division
Canadian General Standards Board
Gatineau, Canada
K1A 1G6

The Standards Council of Canada (SCC) is the coordinating body of the Canadian standardization network, which is composed of people and organizations involved in the development, promotion and implementation of standards. Through the collaborative efforts of Canadian standardization network members, standardization is helping to advance the social and economic well-being of Canada and to safeguard the health and safety of Canadians. The network's efforts are overseen by SCC. The principal objectives of SCC are to foster and promote voluntary standardization as a means of advancing the national economy, supporting sustainable development, benefiting the health, safety and welfare of workers and the public, assisting and protecting the consumer, facilitating domestic and international trade, and furthering international cooperation in relation to standardization.

An important facet of the Canadian standards development system is the use of the following principles: consensus; equal access and effective participation by concerned interests; respect for diverse interests and identification of those who should be afforded access to provide the needed balance of interests; mechanism for dispute resolution; openness and transparency; open access by interested parties to the procedures guiding the standards development process; clarity with respect to the processes; and Canadian interest consideration as the initial basis for the development of standards. A National Standard of Canada (NSC) is a standard prepared or reviewed by an SCC-accredited SDO and approved by the SCC according to NSC approval requirements. Approval does not refer to the technical content of the standard, as this remains the responsibility of the SDO. An NSC reflects a consensus of a number of capable individuals whose collective interests provide, to the greatest practicable extent, a balance of representation of general interests, producers, regulators, users (including consumers) and others with relevant interests, as may be appropriate to the subject at hand. NSCs are intended to make a significant and timely contribution to the Canadian interest.

Those who have a need to apply standards are encouraged to use NSCs. These standards are subject to periodic review. Users of NSCs are cautioned to obtain the latest edition from the SDO that publishes the standard.

The responsibility for approving standards as NSCs rests with:

Standards Council of Canada
270 Albert Street, Suite 200
Ottawa, Ontario K1P 6N7, CANADA

How to order **CGSB** Publications:

by telephone — 819-956-0425 or
— 1-800-665-2472

by fax — 819-956-5740

by mail — CGSB Sales Centre
Gatineau, Canada
K1A 1G6

in person — Place du Portage
Phase III, 6B1
11 Laurier Street
Gatineau, Quebec

by email — ncr.cgsb-ongc@tpsgc-pwgsc.gc.ca

on the Web — www.tpsgc-pwgsc.gc.ca/ongc-cgsb

Supersedes CAN/CGSB-3.0
No. 20.9-95
Reaffirmed
October 2013
Incorporating Corrigendum No. 1

Methods of testing petroleum and associated products

CGSB Cetane Index of diesel fuels

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS
FRANÇAISE ET ANGLAISE.

Prepared by the
Canadian General Standards Board 

Approved by the



Standards Council of Canada
Conseil canadien des normes

Published July 2005 by the
Canadian General Standards Board
Gatineau, Canada K1A 1G6

© HER MAJESTY THE QUEEN IN RIGHT OF CANADA,
as represented by the Minister of Public Works and Government Services,
the Minister responsible for the Canadian General Standards Board (2005).

No part of this publication may be reproduced in any form without the prior permission of the publisher.


Supersedes CAN/CGSB-3.0
No. 20.9-95
Reaffirmed
October 2013
Incorporating Corrigendum No. 1

Preface to the National Standard of Canada

This National Standard of Canada has been reaffirmed by the CGSB Committee on Petroleum Test Methods and incorporates Corrigendum No. 1. Editorial changes have been made by the correction of the following paragraph:

- 9.3.1 The publications referred to in par. 2.1.1 and 9.2 may be obtained from ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, U.S.A., Web site www.astm.org, or from IHS Global Canada Ltd., 200-1331 MacLeod Trail SE, Calgary, Alberta T2G 0K3, telephone 613-237-4250 or 1-800-267-8220, fax 613-237-4251. Web site www.global.ihs.com.

Withdrawn

| | | |
|--|---|----------------------|
|  Gatineau Canada K1A 1G6 | METHODS OF TESTING PETROLEUM AND ASSOCIATED PRODUCTS | CAN/CGSB-3.0 |
| | CGSB Cetane Index of Diesel Fuels | No. 20.9-2005 |

Supersedes CAN/CGSB-3.0

No. 20.9-95

Reaffirmed

October 2013

Incorporating Corrigendum No. 1

1. SCOPE

- 1.1 This method describes a means for calculating the cetane index of diesel fuels (without cetane improvers) from the aniline point, distillation, density and viscosity. The index, as computed from the prescribed formula, is termed the CGSB Cetane Index (CI).
- 1.2 A suggested procedure is also outlined in Appendix A to estimate the cetane index, additized (CIA), based on the calculated cetane index for diesel fuels containing diesel ignition improver (DII). This procedure can be used to estimate the combustion quality when CI and DII are used, and a cetane engine test is not performed. The Appendix A does not form a mandatory part of this method.
- 1.3 The testing and evaluation of a product against this method may require the use of materials and/or equipment that could be hazardous. This document does not purport to address all the safety aspects associated with its use. Anyone using this method has the responsibility to consult the appropriate authorities and to establish appropriate health and safety practices in conjunction with any applicable regulatory requirements prior to its use.

2. REFERENCED PUBLICATIONS

- 2.1 The following publications are referenced in this method:
 - 2.1.1 ASTM International
 - D 86 — Standard Test Method for Distillation of Petroleum Products at Atmospheric Pressure
 - D 445 — Standard Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and the Calculation of Dynamic Viscosity)
 - D 611 — Standard Test Methods for Aniline Point and Mixed Aniline Point of Petroleum Products and Hydrocarbon Solvents
 - D 613 — Standard Test Method for Cetane Number of Diesel Fuel Oil
 - D 976 — Standard Test Methods for Calculated Cetane Index of Distillate Fuels
 - D 1298 — Standard Test Method for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method
 - D 4052 — Standard Test Method for Density and Relative Density of Liquids by Digital Density Meter
 - E 29 — Standard Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications.
- 2.2 A dated reference in this method is to the issue specified. An undated reference in this method is to the latest issue, unless otherwise specified by the authority applying this method. The sources are given in the Notes section.

3. SUMMARY OF METHOD

- 3.1 The aniline point, the 10%, 50% and 90% distillation points, the density at 15°C, and the viscosity at 40°C are determined, and the CGSB Cetane Index (CI) is calculated.

4. SIGNIFICANCE AND USE

- 4.1 The CGSB Cetane Index is useful for estimating the ASTM cetane number of diesel fuels from properties often routinely determined on the fuels.
- 4.1.1 This method is more suitable for estimating the cetane number of Canadian fuels, particularly those of oil sands origin. In the range below 40 cetane number, this method is preferable to that of ASTM D 976 for estimating the ASTM cetane number.

Note: The CGSB Cetane Index is not a replacement for the ASTM cetane number as determined by ASTM D 613.

- 4.2 **Correlation with Cetane Number** — Based on a series of 260 Canadian diesel fuels ranging from 28 to 63 cetane number, the expected correlation of the calculated cetane index with the ASTM cetane number will be less than ± 1.5 cetane numbers for 66% of the fuels evaluated.

5. PROCEDURE

- 5.1 **Aniline Point** — Determine the aniline point of the fuel in accordance with ASTM D 611.
- 5.2 **10%, 50% and 90% Distillation Recovery Temperatures** — Determine the 10%, 50% and 90% distillation temperatures of the fuel corrected for barometric pressure, based on percentage recovery, in accordance with ASTM D 86.
- 5.3 **Density** — Determine the density of the fuel at 15°C in accordance with ASTM D 1298 or D 4052.
- 5.4 **Viscosity** — Determine the viscosity of the fuel at 40°C in accordance with ASTM D 445.

6. CALCULATION

- 6.1 Calculate the CGSB Cetane Index by means of the following equation:

$$CI = 77.7628 + 0.1765 A + 0.003867 A^2 - 11.6150 B + 0.5844 B^2 - 0.6350 V$$

where:

A = aniline point, °C

$$B = \frac{(10\% + 50\% + 90\% + 820)}{D^2} \times 5000$$

V = viscosity at 40°C, mm²/s (cSt)¹

10%, 50%, 90% = distillation recovery points, °C (corrected for barometric pressure)

D = density at 15°C, kg/m³

7. REPORT

- 7.1 Report the result to one decimal place as CGSB Cetane Index.

¹ The SI unit for kinematic viscosity is the square metre per second. The preferred multiple for fluids in this viscosity range is the square millimetre per second, which is equivalent to a centistokes (i.e., 1 mm²/s = 1 cSt).

8. PRECISION

- 8.1 The calculation of the CGSB Cetane Index from the aniline point, distillation points, density and viscosity is exact, and no precision limits can be assigned to the calculation itself.
- 8.2 The precision of the CGSB Cetane Index is dependent only on the precisions of the original four tests.
- 8.3 Assuming that test results from the four tests complied with their respective precisions, the following precision statements apply to the calculation of the CGSB Cetane Index.
- 8.3.1 **Repeatability** — The difference between two results obtained by the same operator with the same apparatus under constant operating conditions on identical test material would, in the long term, in the normal and correct operation of the test methods, exceed 0.2 only in one case in twenty.
- 8.3.2 **Reproducibility** — The difference between two single and independent results obtained by different operators working in different laboratories on identical test material would, in the long term, in the normal and correct operations of the test methods, exceed 0.5 only in one case in twenty.

9. NOTES

- 9.1 **Reference** — This method was developed by a Task Force of the Diesel Fuel Panel of the CGSB Middle Distillate Fuels Committee. A report providing details of the development program has been published as SAE Paper No. 841344, Development of the Canadian General Standards Board (CGSB) Cetane Index.

9.2 Related Publication

ASTM D 4737 — Standard Test Method for Calculated Cetane Index by Four Variable Equation.

9.3 Sources of Referenced Publications

The following addresses were valid at the date of publication.

- 9.3.1 The publications referred to in par. 2.1.1 and 9.2 may be obtained from ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, U.S.A., telephone (610) 832-9585, fax (610) 832-9555, Web site www.astm.org, or from IHS Canada, 1 Antares Drive, Suite 200, Ottawa, Ontario K2E 8C4, telephone (613) 237-4250 or 1-800-854-7179, fax (613) 237-4251, e-mail gic@ihscanada.ca, Web site www.ihscanada.ca.
- 9.3.2 The publication referred to in par. 9.1 may be obtained from SAE International, 400 Commonwealth Drive, Warrendale, PA 15096-0001, U.S.A. Telephone (877) 606-7323 (Canada and U.S. only) or (724) 776-4970 (outside Canada and U.S.). Fax (724) 776-0790. Web site www.sae.org.

(This appendix forms a mandatory part of the method.)

CETANE INDEX, ADDITIZED (CIA)

Note: The cetane index in this appendix refers to the cetane index as measured by CAN/CGSB-3.0 No. 20.9.

- A1.** The following steps are required to estimate the cetane index, additized (CIA), of diesel fuels:
- For a given blend of diesel components, develop the correlation of cetane index to the cetane number (ASTM D 613) (i.e., a particular blend of diesel components may require a cetane index of 43 to ensure that a cetane number of 40.0 is attained).
 - For a given blend of diesel components, develop a response curve of added diesel ignition improver (DII) to ‘cetane units’ (i.e. increase in the cetane quality).
 - Determine the cetane index (CI) of a particular blend of diesel fuel. If the cetane index is below the required level to assure a cetane number of 40.0, some DII must be added to bring the batch to specification.
 - Determine the number of ‘cetane units’ (ΔCU) that must be added to the blend in the form of DII to meet the specification requirement. The DII response curve will indicate the treat rate of DII.
- A1.1** Calculate the cetane index, additized (CIA), as follows:
- $$CIA = CI + \Delta CU$$
- A2.** When the amount of DII required for a diesel blend is calculated from the cetane indexes of individual components, each individual blending component requires a correlation of cetane index to cetane number, and a DII response curve. The estimated cetane quality of the final blend with the DII is the sum of the individual CIA's for each component.
- A2.1** Calculate the cetane index, additized (CIA), as follows:
- $$CIA = \sum [X_i (CIA)_i]$$
- where:
- X_i = the decimal fraction of component “i” in the blend
- $(CIA)_i$ = cetane index, additized, for component “i”
- or
- $$CIA = \sum [X_i (CI_i + \Delta CU_i)]$$
- for “i” components.
- A3.** Report the result as Cetane Index, Additized (or CIA), rounded to the nearest whole number according to ASTM E 29.