



Government
of Canada

Gouvernement
du Canada

Canadian General
Standards Board

Office des normes
générales du Canada

CAN/CGSB-3.517-2015

Supersedes CAN/CGSB-3.517-2013

Diesel fuel


ICS 75.160.20



Standards Council of Canada
Conseil canadien des normes

National Standard of Canada

Canada 

Experience and excellence 
Expérience et excellence

The CANADIAN GENERAL STANDARDS BOARD (CGSB), under whose auspices this standard has been developed, is a government agency within Public Works and Government Services Canada. CGSB is engaged in the production of voluntary standards in a wide range of subject areas through the media of standards committees and the consensus process. The standards committees are composed of representatives of relevant interests including producers, consumers and other users, retailers, governments, educational institutions, technical, professional and trade societies, and research and testing organizations. Any given standard is developed on the consensus of views expressed by such representatives.

CGSB has been accredited by the Standards Council of Canada as a national standards-development organization. The standards that it develops and offers as National Standards of Canada conform to the criteria and procedures established for this purpose by the Standards Council of Canada. In addition to standards it publishes as National Standards of Canada, CGSB produces standards to meet particular needs, in response to requests from a variety of sources in both the public and private sectors. Both CGSB standards and CGSB national standards are developed in conformance with the policies described in the CGSB Policy and Procedures Manual for the Development and Maintenance of Standards.

CGSB standards are subject to review and revision to ensure that they keep abreast of technological progress. CGSB will initiate the review of this standard within five years of the date of publication. Suggestions for their improvement, which are always welcome, should be brought to the notice of the standards committees concerned. Changes to standards are issued either as separate amendment sheets or in new editions of standards.

An up-to-date listing of CGSB standards, including details on latest issues and amendments, and ordering instructions, is found in the CGSB Catalogue at our Web site — www.tpsgc-pwgsc.gc.ca/ongc-cgsb along with more information about CGSB products and services.

Although the intended primary application of this standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

The testing and evaluation of a product against this standard may require the use of materials and/or equipment that could be hazardous. This document does not purport to address all the safety aspects associated with its use. Anyone using this standard has the responsibility to consult the appropriate authorities and to establish appropriate health and safety practices in conjunction with any applicable regulatory requirements prior to its use. CGSB neither assumes nor accepts any responsibility for any injury or damage that may occur during or as the result of tests, wherever performed.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. CGSB shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Language

In this Standard, “shall” states a mandatory requirement, “should” expresses a recommendation and “may” is used to express an option or that which is permissible within the limits of this Standard. Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material. Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

Further information on CGSB and its services and standards may be obtained from:

The Manager
Standards Division
Canadian General Standards Board
Gatineau, Canada
K1A 1G6

The Standards Council of Canada (SCC) is the coordinating body of the Canadian standardization network, which is composed of people and organizations involved in the development, promotion and implementation of standards. Through the collaborative efforts of Canadian standardization network members, standardization is helping to advance the social and economic well-being of Canada and to safeguard the health and safety of Canadians. The network’s efforts are overseen by SCC. The principal objectives of SCC are to foster and promote voluntary standardization as a means of advancing the national economy, supporting sustainable development, benefiting the health, safety and welfare of workers and the public, assisting and protecting the consumer, facilitating domestic and international trade, and furthering international cooperation in relation to standardization.

An important facet of the Canadian standards development system is the use of the following principles: consensus; equal access and effective participation by concerned interests; respect for diverse interests and identification of those who should be afforded access to provide the needed balance of interests; mechanism for dispute resolution; openness and transparency; open access by interested parties to the procedures guiding the standards development process; clarity with respect to the processes; and Canadian interest consideration as the initial basis for the development of standards. A National Standard of Canada (NSC) is a standard prepared or reviewed by an SCC-accredited SDO and approved by the SCC according to NSC approval requirements. Approval does not refer to the technical content of the standard, as this remains the responsibility of the SDO. An NSC reflects a consensus of a number of capable individuals whose collective interests provide, to the greatest practicable extent, a balance of representation of general interests, producers, regulators, users (including consumers) and others with relevant interests, as may be appropriate to the subject at hand. NSCs are intended to make a significant and timely contribution to the Canadian interest.

Those who have a need to apply standards are encouraged to use NSCs. These standards are subject to periodic review. Users of NSCs are cautioned to obtain the latest edition from the SDO that publishes the standard.

The responsibility for approving standards as NSCs rests with:

Standards Council of Canada
270 Albert Street, Suite 200
Ottawa, Ontario K1P 6N7, CANADA

How to order **CGSB** Publications:

- by telephone — 819-956-0425 *or*
— 1-800-665-2472
- by fax — 819-956-5740
- by mail — CGSB Sales Centre
Gatineau, Canada
K1A 1G6
- in person — Place du Portage
Phase III, 6B1
11 Laurier Street
Gatineau, Quebec
- by email — ncr.cgsb-ongc@tpsgc-pwgsc.gc.ca
- on the Web — www.tpsgc-pwgsc.gc.ca/ongc-cgsb

Diesel fuel

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS
FRANÇAISE ET ANGLAISE.

Prepared by the
Canadian General Standards Board 

Approved by the
 **Standards Council of Canada**
Conseil canadien des normes

Published May 2015 by the
Canadian General Standards Board
Gatineau, Canada K1A 1G6

© HER MAJESTY THE QUEEN IN RIGHT OF CANADA,
as represented by the Minister of Public Works and Government Services,
the Minister responsible for the Canadian General Standards Board (2015).

No part of this publication may be reproduced in any form without the prior permission of the publisher.

CANADIAN GENERAL STANDARDS BOARD

Committee on Middle Distillate Fuels

(Voting membership at date of approval)

Chair (Voting)

Mitchell, K.¹ Shell Canada

General interest category

Ekstrom, N.	Natural Resources Canada
Hanganu, A.	Inspectorate Canada
Hérsant, G.	Oleotek Inc.
Jääskeläinen, H.	Consultant
Jacula, T.	Maxxam Analytics Inc.
MacLean, G.	Intertek Commodities Division
Menard, L.	Advanced Engine Technology Ltd.
Moser, P.	Saskatchewan Research Council
Pickard, A.L.	Consultant
Tharby, R.D.	Tharby Technology, Consultants
Vidian-Jones, C.	Certispec Services Inc.
Wispiński, D.	Alberta Innovates – Technology Futures

Producer category

Boulton, L.	Husky Energy
Campbell, S.	Canadian Canola Growers Association
Cosentino, J.	Afton Chemical Corporation
Geoffroy, L.	Valero Energy Inc.
Gropp, R.	GE Water and Process Technologies
McKnight, A.	Innospec Inc.
Morel, G.	Canadian Fuels Association
Munroe, D.	Suncor Energy Products Partnership
Norton, K.	Biox Corporation
Paszti, M.	Rothsay
Payne, J.P.	Infineum Canada Ltd.
Pierceall, R.	Archer Daniels Midland
Porter, S.	Canadian Renewable Fuels Association
Saeed, A.	Imperial Oil Ltd.
Taracha, J.	The Lubrizol Corporation
Tetreault, D.	Baker Hughes
Titus, J.	Irving Oil Ltd.
White, M.	North Atlantic

¹ Producer

Regulator category

Archambault, R.	Gouvernement du Québec, ministère de l'Énergie et des Ressources naturelles
Parsons, R.	Government of Manitoba, Innovation, Energy and Mines
Rensing, M.J.	Government of British Columbia, Ministry of Energy, Mines and Natural Gas

User category

Bryksaw, G.	General Motors of Canada Ltd.
Cowan, B.	Government of Ontario, Ministry of Transportation
Eveleigh, S.	Government of the Northwest Territories, Public Works and Services
Kilso, R.	Finning Canada
MacLeod, B.	Public Works and Government Services Canada
Poitras, P.	National Defence
Sateana, A.	Government of Nunavut
Satsangi, T.	Canadian Coast Guard
Wilson, S.	Canadian Oil Heat Association

Secretary (non-voting)

Schuessler, M.	Canadian General Standards Board
----------------	----------------------------------

Acknowledgment is made for the translation of this National Standard of Canada by the Translation Bureau of Public Works and Government Services Canada.

Contents		Page
1	Scope.....	1
2	Normative references.....	1
3	Terms and definitions	2
4	Classification	3
5	General requirements	3
6	Detailed requirements.....	3
7	Inspection.....	6
8	Options	6
9	Precautions	7
	Annex A (normative) Referenced ASTM International publications	9
	Annex B (informative) Federal, provincial and other regulations applicable to diesel fuels	11
	Annex C (informative) Significance of requirements for diesel fuels	15

Diesel fuel

1 Scope

This standard applies to two types of diesel fuel, **Type A** and **Type B**, suitable for use in high-speed diesel engine powered equipment for on-road and off-road applications and in select equipment powered by medium speed diesel engines.

Type A is intended for use in selected applications such as urban buses and underground mining or when ambient temperatures require better low-temperature properties than Type B.

Fuel meeting this standard may be used for underground mining applications that were formerly covered by CAN/CGSB-3.16 (See footnote a and Annex B for notes related to the flashpoint).

The testing and evaluation of a product against this standard may require the use of materials and/or equipment that could be hazardous. This document does not purport to address all the safety aspects associated with its use. Anyone using this standard has the responsibility to consult the appropriate authorities and to establish appropriate health and safety practices in conjunction with any applicable regulatory requirements prior to its use.

2 Normative references

The following normative documents contain provisions that, through reference in this text, constitute provisions of this National Standard of Canada. The referenced documents may be obtained from the sources noted below.

NOTE The addresses provided below were valid at the date of publication of this standard.

An undated reference is to the latest edition or revision of the reference or document in question, unless otherwise specified by the authority applying this standard. A dated reference is to the specified revision or edition of the reference or document in question.

2.1 Canadian General Standards Board (CGSB)

CAN/CGSB 3.0 — *Methods of testing petroleum and associated products:*

No. 20.9 — *CGSB Cetane index of diesel fuel*

No. 28.8 — *Visual haze rating of distillate fuel oils*

No. 140.1 — *Low temperature flow test (LTFT) for diesel fuels*

CAN/CGSB-3.2 — *Heating fuel oil*

CAN/CGSB-3.520 — *Diesel fuel containing low levels of biodiesel (B1–B5)*

CAN/CGSB-3.522 — *Diesel fuel containing biodiesel (B6–B20).*

2.1.1 Source

The above may be obtained from the Canadian General Standards Board, Sales Centre, Gatineau, Canada K1A 1G6. Telephone 819-956-0425 or 1-800-665-2472. Fax 819-956-5740. E-mail ncr.cgsb-ongc@tpsgc-pwgsc.gc.ca. Web site www.tpsgc-pwgsc.gc.ca/ongc-cgsb.

2.2 Canadian Fuels Association

Weather Data.

2.2.1 Source

<http://canadianfuels.ca/en/fuel-quality>.

2.3 ASTM International

Annual book of ASTM standards (see Annex A).

2.3.1 Source

The above may be obtained from ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, U.S.A., telephone 610-832-9585, fax 610-832-9555, Web site www.astm.org, or from IHS Global Canada Ltd, 200-1331 MacLeod Trail SE, Calgary, Alberta T2G 0K3, telephone 613-237-4250 or 1-800-267-8220, fax 613-237-4251, Web site www.global.ihs.com.

2.4 SAE International

SAE Paper 952370 — *The lubricity of winter diesel fuels*

SAE Paper 961180 — *The lubricity of winter diesel fuels — Part 2: pump rig test results*

SAE Paper 981363 — *Continued evaluation of diesel fuel lubricity by Pump Rig Tests.*

2.4.1 Source

The above may be obtained from SAE International, 400 Commonwealth Drive, Warrendale, PA 15096-0001, U.S.A., telephone 877-606-7323, fax 724-776-0790, Web site www.sae.org/servlets/index.

3 Terms and definitions

For the purposes of this National Standard of Canada, the following terms and definitions apply.

3.1

2.5% low-end design temperature

the 2.5 percentile design value is the temperature at or below which 2.5% of the hourly outside air temperatures are observed to occur for an indicated half month. The 2.5% Low-End Design Temperature for most weather stations in Canada by half month period is available on the Canadian Fuels Association Web site (see 2.2). This data is based upon an analysis of hourly weather readings from weather stations across Canada.

3.2

diesel fuel

middle distillate fuel composed of hydrocarbons and naturally occurring, petroleum-derived non-hydrocarbons that boils in the range of 130°–400°C and that is intended for use as a fuel in compression-ignition engines.

3.3

representative fuel

sample of finished fuel with inspection properties that are typical of the fuel as commercially supplied.

4 Classification

4.1 The distillate fuel shall be supplied in the following types, as specified (see 8.1):

4.1.1 Types

Type A

Type B

5 General requirements

5.1 The fuels specified shall be hydrocarbons that may contain additives designed to improve their properties or performance, for example, diesel ignition quality, low-temperature flow properties and electrical conductivity. Fatty Acid Alkyl Esters are not allowed in this standard except at concentrations below 1%. For diesel fuel containing above 1% Fatty Acid Alkyl Esters (FAAE), use CAN/CGSB-3.520 or CAN/CGSB-3.522.

5.2 The fuel shall be a stable homogeneous liquid free from foreign matter that is likely to clog filters or nozzles, or to damage equipment.

5.3 There shall be no intentional additions of used lubricating oils, extraneous fluids, unconverted triglycerides (such as raw vegetable oils, animal fats, fish oils or used cooking oils), which are not suitable components for use in diesel fuel.

6 Detailed requirements

For an explanation of the significance of tests and the methods used, see Annex C.

6.1 Low-temperature flow properties

6.1.1 Low-temperature flow properties of the fuel shall be designed (see 8.1) to give satisfactory performance at the temperatures indicated by the 2.5% low-end design temperature data for the period and location of intended use. However, when the 2.5% low-end design temperature is colder than -48°C , a fuel meeting a -48°C operability limit may be provided.

6.1.2 The following shall be reported:

- a. The 2.5% low-end temperature to which the fuel is designed.
- b. The test method used to determine the operability temperature:
 - i. Cloud point (ASTM D2500, D5771, D5772 or D5773. In the event of a dispute, ASTM D5773 shall be the referee method.) or
 - ii. Low-temperature flow test (LTFT) for diesel fuels (CAN/CGSB-3.0 No. 140.1 or ASTM D4539. In the event of a dispute, CAN/CGSB-3.0 No. 140.1 shall be the referee method).
- c. The test method result.

6.2 Specified limiting values

6.2.1 The diesel fuel shall comply with the specified limiting values. The specified limiting values shall not be changed. This precludes any allowances for the test method precision and adding or subtracting digits.

6.2.2 For purposes of determining conformance with the specified limiting values, an observed value or a calculated value shall be rounded off “to the nearest unit” in the last right-hand digit used in expressing the specified limiting value, in accordance with the rounding-off method of ASTM E29. There is one exception (see 6.4 and 6.17).

6.2.3 Where test values differ between two parties, a resolution shall be in accordance with ASTM D3244 in order to determine conformance with the specified limiting values, with the criticality of the limits set at $P = 0.5$.

6.3 Test methods

6.3.1 Test methods other than those referenced in this standard may be used only if they have been validated in accordance with ASTM D3764 or D6708.

6.3.2 Validated test methods shall correlate with methods referenced in the standard. Differences in precision, sensitivity and bias between methods referenced in the standard and the validated methods shall be noted when using results from validated methods.

6.3.3 Validated test methods shall only be used within the bounds of the data covered in their validation.

6.3.4 In the event of a dispute, the procedures given in 6.2 shall be used.

6.3.5 If parties in a dispute cannot agree on an analytical method to resolve the dispute, the referee method listed in the standard shall be used.

	Property	Specified limiting values				Test method
		Type A		Type B		
		Min.	Max.	Min.	Max.	
6.4	Flash point ^a , °C (see 6.17 and 8.2)	40.0	—	40.0	—	D93 ^b or D3828
6.5	Kinematic viscosity at 40°C, mm ² /s (cSt) ^c (see 6.18)	1.30	3.60	1.70 ^d	4.10	D445 ^b or D7042
6.6	Distillation, 90% recovered, °C (see 6.19)	—	290.0	—	360.0	D86 ^b or D2887
6.7	Water and sediment, % by volume (see 6.20)	—	0.02	—	0.02	D1796 (modified) ^b or D2709
6.8	Acid number, mg KOH/g	—	0.10	—	0.10	D664 or D974 ^b
6.9	Sulphur ^e , mg/kg	—	15	—	15	D2622, D5453 ^b or D7039
6.10	Copper strip corrosion, 3 h at 50°C	—	No. 1	—	No. 1	D130
6.11	Carbon residue on 10% bottoms, % by mass	—	0.1	—	0.2	D524 or D4530 ^b
6.12	Ash, % by mass	—	0.010	—	0.010	D482
6.13	Ignition quality, cetane number (see 6.21 and 8.2)	40.0	—	40.0	—	D613 ^b , D6890 or D7170

	Property	Specified limiting values				Test method
		Type A		Type B		
		Min.	Max.	Min.	Max.	
6.14	Electrical conductivity, at point, time and temperature of delivery to purchaser, pS/m (see 9.1)	25	—	25	—	D2624
6.15	Low-temperature flow properties (see 8.1)	(see 6.1)		(see 6.1)		
6.16	Lubricity (see 9.2)	(see 6.22 and 6.23)		(see 6.22 and 6.23)		
<p>^a A higher flash point may be specified in special applications such as marine on-board use. For underground mining applications, the authority having jurisdiction may specify a different flash point requirement. (Annex B1 and B2).</p> <p>^b The referee method to be used in the event of a dispute.</p> <p>^c The SI unit for kinematic viscosity is the square metre per second. The preferred multiple for fluids in the viscosity range is the square millimetre per second, which is equivalent to centiStokes (i.e. 1 mm²/s = 1 cSt).</p> <p>^d If the fuel is designed for an operability temperature of -10°C or colder, then the minimum viscosity shall be 1.50 cSt. If the fuel is designed for an operability temperature of -20°C or colder, then the minimum viscosity shall be 1.30 cSt.</p> <p>^e Maximum limit may be higher for some applications when allowed by federal regulation (see Annex B1).</p>						

6.17 Flash point

The test values shall be reported to the nearest 0.5°C in accordance with ASTM D93 or D3828, Method B (see 8.2).

6.18 Kinematic viscosity

Only bias-corrected values from ASTM D7042 may be used as an alternate to ASTM D445.

6.19 Distillation

Testing shall be in accordance with ASTM D86 or D2887. When testing in accordance with ASTM D2887, use the method in the appendix to convert the results to estimates of ASTM D86. In the event of a dispute, the automatic test method of D86 shall be selected as the referee test method.

6.20 Water and sediment

Testing shall be conducted in accordance with ASTM D1796 (modified) or D2709. The test in ASTM D1796 shall be modified by substituting the centrifuge tube specified in ASTM D2273 for that in ASTM D1796. In the event of a dispute, ASTM D1796 (modified) shall be the referee test method.

6.21 Ignition quality

Testing shall be conducted in accordance with ASTM D613, D6890, or D7170. The calculated cetane index according to ASTM D976 or D4737, CAN/CGSB-3.0 No. 20.9 or other calculation techniques that approximate cetane number by ASTM D613, may be used for control purposes. The user should refer to the appropriate test method. Calculation techniques should not be used for determining the ignition quality of field fuel samples if they are suspected of containing cetane improver additives. In the event of a dispute, ASTM D613 shall be the referee test method.

6.22 Lubricity

A lubricity additive shall be incorporated (see 9.2).

6.23 Lubricity additive requirements

The lubricity additive and its dosage shall be shown to provide acceptable performance in a representative fuel (see 3.3) and to give **acceptable** performance in accordance with **any one** of the following criteria:

6.23.1 Pump wear with a representative fuel in a distributor-type diesel fuel injection pump in a vehicle field test

The required vehicle field test methodology is described in SAE Paper 952370. An acceptable pump-wear result is defined as an Overall Pump Rating of 4.0 or less using the rating method described in SAE Paper 961180.

6.23.2 Pump wear with a representative fuel in a distributor-type diesel fuel injection pump rig test

The required pump rig test methodology is described in SAE Paper 981363. SAE Papers 961180 and 952370 provide additional background information. An acceptable pump-wear result is defined as an Overall Pump Rating of 4.0 or less using the rating method described in these SAE Papers.

6.23.3 Lab bench test results with a representative fuel using the high frequency reciprocating rig test

The required high frequency reciprocating rig test is described in ASTM D6079 and D7688 and shall be run at 60°C. An acceptable test result is defined as a wear scar diameter of less than or equal to 460 µm at 60°C. In the event of a dispute, ASTM D7688 shall be the referee test method for this criterion.

7 Inspection

7.1 Sampling

7.1.1 Sample equipment and procedures shall be designed and used to obtain representative samples of a product. Sample lines, hoses, etc. should be adequately flushed prior to taking a sample. Samples should be stored in a cool, dark place. Procedures shall be in accordance with ASTM D4057, D4177 or D5854.

7.1.2 Sample volume should be consistent with the requirement of the testing laboratory or the authority having jurisdiction or both. Unless otherwise specified (see 8.2), a sample of at least 2.7 L shall be collected.

8 Options

8.1 The following options shall be specified in the application of this standard:

- a. Type of fuel (see 4.1)
- b. Low-temperature design requirements for period and location of intended use (see 6.1.1)

8.2 The following options may be specified if the requirements are more stringent than those stipulated in this standard:

- a. Flash point (see 6.4)
- b. Cetane number (see 6.13)²
- c. Sample size (see 7.1.2).

² Fuel having a higher cetane number may be necessary for some engines. Conditions of operation may also dictate the specification of a higher cetane number.

9 Precautions

9.1 Conductivity depletion

Due to the normal depletion of fuel conductivity during commingling, storage, and distribution, or at low temperatures, the fuel should be sufficiently treated with conductivity-improver additive to ensure that the electrical conductivity requirement in 6.14 is met. The temperature at the point of use and the method of distribution could require a substantially higher conductivity level than 25 pS/m at the point of additive treatment. For more information on this subject, see ASTM D4865 and D2624.

9.2 Fuel lubricity

Processes used to desulphurize diesel fuel reduce the natural lubricating qualities of diesel fuel. Since engines require diesel fuel to act as a lubricant for their injection systems, diesel fuel must have sufficient lubricity to give adequate protection against excessive injection system wear. Additives are used to improve diesel fuel lubricity. Lubricity additives can have unwanted side effects particularly when used at excessive concentrations or in combination with other additives or contaminants.

9.3 Heating oil application

At times diesel fuel can be used in a heating oil application. In these cases, refer to CAN/CGSB-3.2 for detailed requirements.

9.4 Manufacturing processes

Contamination from manufacturing processes or treatments can be carried over in trace quantities into the fuel and cause unexpected problems. Moreover, these contaminants might not be detected by the requirements listed in this standard. It is recommended that adequate quality assurance procedures be put in place to ensure that manufacturing processes capable of such contamination are identified and controlled. Sodium, calcium, chlorides, sulphates, clay, sand, acids, caustics, soaps, and amine process additives are examples of possible contaminants or potential precipitates.

9.5 Visual haze

The solubility of water in fuel is a function of temperature. When fuel is exposed to low ambient temperatures, water can separate causing a haze or cloudy appearance. It has been a common industry practice to perform the visual haze test at 4°C for fuel destined for use in winter and at 15°C for fuel destined for use in summer. Experience has indicated that fuel passing these requirements has been acceptable in the appropriate season. For further information on the visual haze test, refer to CAN/CGSB-3.0 No. 28.8 or ASTM D4176, Procedure 2.

9.6 Fuel flammability

A number of properties must be considered in assessing the overall flammability hazard of a fuel. Flash point is the minimum fuel temperature at which a mixture of air and fuel vapour can form and be ignited by a spark or flame under specified laboratory conditions. However, the flash point is only an indication of the potential flammability risk of a fuel. Oxygen concentration in the atmosphere is an additional factor affecting flammability. Investigation of fuel-related fires in marine vessel engine rooms and underground mining applications has shown that these fires are generally initiated through direct contact of a fuel spray or spill with hot surfaces having a temperature exceeding the auto-ignition temperature of the fuel. The flash point of the fuel has little bearing on the probability of such fires occurring. Similarly, fires in fuel tanks are typically initiated as a result of hot work (e.g., welding) on the exterior surface of the tank causing fuel adhering to the interior tank wall surface to evaporate and spontaneously ignite after having exceeded its auto-ignition temperature.

9.7 Fuel colour

Although this standard does not have a colour requirement, colour can be a useful indicator of fuel quality or contamination. Normally fuel colour ranges from water white (colourless) to an amber or light brownish colour depending on crude oil type or refinery processes. Fuel in long term storage can darken owing to oxidation of trace components, but this will not affect its performance. If the darkening is accompanied by the formation of sediment, however, the fuel could be rendered not acceptable for use. Fuels having unusual shades of colour should be investigated to determine fitness for use.

9.8 Hydrogen sulphide

Hydrogen sulphide (H_2S) can occasionally be found in limited concentration in the vapour phase above diesel fuels. H_2S is toxic at low concentrations in air. Additives are available that can react with H_2S in the liquid phase and reduce the concentration of H_2S both in the fuel and in the vapour phase.

Annex A

(normative)

Referenced ASTM International publications (see 2.3)

Annual Book of ASTM Standards

- D86 Standard Test Method for Distillation of Petroleum Products at Atmospheric Pressure
- D93 Standard Test Methods for Flash Point by Pensky-Martens Closed Cup Tester
- D130 Standard Test Method for Corrosiveness to Copper from Petroleum Products by Copper Strip Test
- D445 Standard Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and Calculation of Dynamic Viscosity)
- D482 Standard Test Method for Ash from Petroleum Products
- D524 Standard Test Method for Ramsbottom Carbon Residue of Petroleum Products
- D613 Standard Test Method for Cetane Number of Diesel Fuel Oil
- D664 Standard Test Method for Acid Number of Petroleum Products by Potentiometric Titration
- D974 Standard Test Method for Acid and Base Number by Color-Indicator Titration
- D976 Standard Test Methods for Calculated Cetane Index of Distillate Fuels
- D1796 Standard Test Method for Water and Sediment in Fuel Oils by the Centrifuge Method (Laboratory Procedure)
- D2273 Standard Test Method for Trace Sediment in Lubricating Oils
- D2500 Standard Test Method for Cloud Point of Petroleum Products
- D2622 Standard Test Method for Sulfur in Petroleum Products by Wavelength Dispersive X-ray Fluorescence Spectrometry
- D2624 Standard Test Methods for Electrical Conductivity of Aviation and Distillate Fuels
- D2709 Standard Test Method for Water and Sediment in Middle Distillate Fuels by Centrifuge
- D2887 Standard Test Method for Boiling Range Distribution of Petroleum Fractions by Gas Chromatography
- D3244 Standard Practice for Utilization of Test Data to Determine Conformance with Specifications
- D3764 Standard Practice for Validation of Process Stream Analyzer Systems
- D3828 Standard Test Methods for Flash Point by Small Scale Closed Cup Tester
- D4057 Standard Practice for Manual Sampling of Petroleum and Petroleum Products
- D4176 Standard Test Method for Free Water and Particulate Contamination in Distillate Fuels (Visual Inspection Procedure)

- D4177 Standard Practice for Automatic Sampling of Petroleum and Petroleum Products
- D4530 Standard Test Method for Determination of Carbon Residue (Micro Method)
- D4539 Standard Test Method for Filterability of Diesel Fuels by Low-Temperature Flow Test (LTFT)
- D4737 Standard Test Method for Calculated Cetane Index by Four Variable Equation
- D4865 Standard Guide for Generation and Dissipation of Static Electricity in Petroleum Fuel Systems
- D5453 Standard Test Method for Determination of Total Sulfur in Light Hydrocarbons, Spark Ignition Engine Fuel, Diesel Engine Fuel, and Engine Oil by Ultraviolet Fluorescence
- D5771 Standard Test Method for Cloud Point of Petroleum Products (Optical Detection Stepped Cooling Method)
- D5772 Standard Test Method for Cloud Point of Petroleum Products (Linear Cooling Rate Method)
- D5773 Standard Test Method for Cloud Point of Petroleum Products (Constant Cooling Rate Method)
- D5854 Standard Practice for Mixing and Handling of Liquid Samples of Petroleum and Petroleum Products
- D6079 Standard Test Method for Evaluating Lubricity of Diesel Fuels by the High-Frequency Reciprocating Rig (HFRR)
- D6708 Standard Practice for Statistical Assessment and Improvement of Expected Agreement Between Two Test Methods that Purport to Measure the Same Property of a Material
- D6890 Standard Test Method for Determination of Ignition Delay and Derived Cetane Number (DCN) of Diesel Fuel Oils by Combustion in a Constant Volume Chamber
- D7039 Standard Test Method for Sulfur in Gasoline, Diesel Fuel, Jet Fuel, Kerosine, Biodiesel, Biodiesel Blends, and Gasoline-Ethanol Blends by Monochromatic Wavelength Dispersive X-ray Fluorescence Spectrometry
- D7042 Standard Test Method for Dynamic Viscosity and Density of Liquids by Stabinger Viscometer (and the Calculation of Kinematic Viscosity)
- D7170 Standard Test Method for Determination of Derived Cetane Number (DCN) of Diesel Fuel Oils – Fixed Range Injection Period, Constant Volume Combustion Chamber Method
- D7688 Standards Test Methods for Evaluating Lubricity of Diesel Fuels by the High-Frequency Reciprocating Rig (HFRR) by Visual Observation
- E29 Standard Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications.

Annex B (informative)

Federal, provincial and other regulations applicable to diesel fuels³ and⁴

B.1 Federal regulations

B.1.1 Canadian environmental protection act

The following federal regulations have been enacted under the *Canadian Environmental Protection Act, 1999*.

B.1.1.1 Fuels information regulations, No. 1 (C.R.C. c. 407 amended by SOR/DORS/79-280, 80-138 and 2000-104)

These regulations require producers and importers to submit information on sulphur and additive contents (other than lead).

B.1.1.2 Contaminated fuel regulations (SOR/DORS/91-486)

These regulations prohibit the importation of fuels that have been contaminated with hazardous wastes.

B.1.1.3 Sulphur in diesel fuel regulations (SOR/DORS/2002-254)

These regulations define the sulphur limits for fuels for use in diesel engines.

B.1.1.4 Renewable fuels regulations (SOR/DORS/2010-189)

These regulations define the renewable fuel content requirements for gasoline, diesel and heating oil.

B.1.2 The following federal regulations also apply to fuels meeting this standard:

B.1.2.1 Marine machinery regulations (SOR 90/264)

These regulations, enacted under the *Canada Shipping Act, 2001*, specify details related to the construction, installation and inspection of marine machinery. Safety requirements for diesel fuels used in marine applications are also specified.

B.1.2.2 Transportation of dangerous goods regulations (SOR/DORS/2001-286)

These regulations, enacted under the *Transportation of Dangerous Goods Act, 1992*, give detailed packaging, labelling and documentation requirements for transporting fuels in Canada.

B.2 Provincial and territorial regulations

B.2.1 Alberta

³ The regulations listed are subject to revision by the relevant authority. The user should consult the relevant authority to confirm the current regulations. The information provided about the regulations is for information only. In case of conflict, the text of the regulation takes precedence.

⁴ The requirements in jurisdictions other than those listed above will be added, as information becomes available in future revisions and amendments to this standard.

B.2.1.1 Renewable fuels standard regulation (Alta. reg. 29/2010)

This regulation, enacted under the *Climate Change and Emissions Management Act*, defines the requirements for renewable fuels in Alberta.

B.2.1.2 Mines safety regulation (Alta. reg. 292/1995)

This regulation, enacted under the *Occupational Health and Safety Act*, specifies diesel fuel requirements for underground mining applications.

B.2.2 British Columbia

B.2.2.1 Renewable and low carbon fuel requirements regulation (B.C. reg. 394/2008)

This regulation, enacted under the *Greenhouse Gas Reduction (Renewable and Low Carbon Fuel Requirements) Act*, defines the requirements for renewable fuels in British Columbia.

B.2.2.2 Occupational health and safety regulation (B.C. reg. 296/97)

This regulation, enacted under the *Workers Compensation Act*, specifies diesel fuel requirements for underground mining applications.

B.2.3 Manitoba

B.2.3.1 Storage and handling of petroleum products and allied products regulation (Man. reg. 188/2001)

This regulation, enacted under the *Dangerous Goods Handling and Transportation Act*, specifies requirements for fuel intended for sale in Manitoba for use in internal combustion engines.

B.2.3.2 Operation of mines regulation (Man. reg. 228/94)

This regulation, enacted under the *Workplace Safety and Health Act*, specifies diesel fuel requirements for underground mining applications.

B.2.4 New Brunswick

B.2.4.1 Underground mine regulation (N.B. reg. 96-105)

This regulation, enacted under the *Occupational Health and Safety Act*, specifies diesel fuel requirements for underground mining applications.

B.2.5 Newfoundland and Labrador

B.2.5.1 Mines safety of workers regulations (C.N.L.R. 1145/96)

These regulations, enacted under the *Occupational Health and Safety Act*, specify diesel fuel requirements for underground mining applications.

B.2.6 Northwest Territories

B.2.6.1 Mine health and safety regulations (N.W.T. reg. 125-95)

These regulations, enacted under the *Mine Health and Safety Act*, specify diesel fuel requirements for underground mining applications.

B.2.7 Nova Scotia

B.2.7.1 Underground mining regulations (N.S. reg. 153/2003)

These regulations, enacted under the *Occupational Health and Safety Act*, specify diesel fuel requirements for underground mining applications.

B.2.8 Nunavut

B.2.8.1 Mine health and safety regulations (N.W.T. (Nu.) reg. 125-95)

These regulations, enacted under the *Mine Health and Safety Act*, specify diesel fuel requirements for underground mining applications.

B.2.9 Ontario

B.2.9.1 Liquid fuels handling code, 2007

This code, published by the *Technical Standards and Safety Authority* and adopted by reference under the *Technical Standards and Safety Act, 2000*, specifies safety related requirements for handling liquid fuels.

B.2.9.2 Mines and mining plants (R.R.O. 1990, reg. 854)

This regulation, enacted under the *Occupational Health and Safety Act*, specifies diesel fuel requirements for underground mining applications.

B.2.9.3 Greener diesel — Renewable fuel content requirements for petroleum diesel fuel (Ontario regulation 97/14)

This regulation, enacted under the *Environmental Protection Act*, defines the requirements for renewable fuels in Ontario.

B.2.10 Quebec

B.2.10.1 General requirements

The general requirements are controlled under the latest version of the *Loi sur les produits pétroliers*, L.R.Q., c. P-30.1. *Règlement sur les produits pétroliers*, D.226-2007, 2007 G.O. 2, 1668B, or *Petroleum Products Act*, R.S.Q., c. P-30.1. *Petroleum Products Regulation*, O.C. 226-2007, 2007 G.O. 2, 1244B⁵. In this regulation, Quebec quality requirements are listed for aviation gasolines, aviation turbine fuels, automotive gasolines, gasolines containing denatured fuel ethanol for use in automotive spark ignition fuels, diesel fuels, diesel fuels containing biodiesel (B100) for blending in middle distillate fuels, fuel oils Types 0, 1 and 2, and fuel oils Types 4, 5 and 6. Amendments and editions published apply only 90 days after the last day of the month that the French text of the amendments or editions was published. The Direction générale des hydrocarbures et des biocombustibles of the ministère de l'Énergie et des Ressources naturelles is responsible for the application and revision of this regulation. Web site www.mrn.gouv.qc.ca/english/energy/index.jsp.

B.2.10.2 Regulation respecting occupational health and safety in mines (R.R.Q., c. S-2.1, r. 14)

This regulation, also known as *Règlement sur la santé et la sécurité du travail dans les mines*, was enacted under *An Act respecting Occupational health and safety (Loi sur la santé et la sécurité du travail)* and specifies diesel fuel requirements for underground mining applications.

⁵ Available from Les Publications du Québec. Telephone 1-800-463-2100 or 418-643-5150. Fax 1-800-561-3479 or 418-643-6177. Also available on-line at www2.publicationsduquebec.gouv.qc.ca/home.php.

B.2.11 Saskatchewan

B.2.11.1 Mines regulations, 2003 (R.R.S. c. O-1.1 reg. 2)

These regulations, enacted under the *Occupational Health and Safety Act, 1993*, specify diesel fuel requirements for underground mining applications.

B.2.12 Yukon

B.2.12.1 Mine safety regulations (Y.O.I.C. 1986B/164)

These regulations, enacted under the *Occupational Health and Safety Act*, specify diesel fuel requirements for underground mining applications.

Annex C (informative)

Significance of requirements for diesel fuels

C.1 Introduction

The properties of commercial diesel fuels depend on the refining practices employed and the nature of the crude oils from which they are produced. For example, diesel fuel produced within the boiling range of 130° to 400°C may have many possible combinations of various properties such as volatility, ignition quality and viscosity.

C.2 Types of diesel fuel

C.2.1 CAN/CGSB-3.517 is intended as a statement of permissible limits of significant fuel properties used for specifying the wide variety of commercially available diesel fuels meeting regulated sulphur requirements. Limiting values of significant properties are prescribed for two types of diesel fuel. These types and their general applicability for use in diesel engines are broadly indicated as follows.

C.2.2 Type B is seasonally adjusted to meet the low temperature operability requirements for the period and location of intended use for most locations in Canada. This adjustment affects the other properties of the fuel.

C.2.3 Type A diesel fuel is applicable for use where the low temperature operability of Type B is insufficient.

C.3 Selection of a particular grade

The selection of a particular diesel fuel from one of these two types for use in a given engine requires consideration of the following factors:

- a. Legal requirements
- b. Expected ambient temperatures at location and time of use
- c. Availability
- d. Maintenance frequency and requirements
- e. Engine size and design
- f. Speed and load changes
- g. Engine manufacturer's recommendations and fuel specifications.

Some of these factors may influence the required fuel properties outlined as follows.

C.4 Flash point

The flash point as specified is not directly related to engine performance. It is, however, of importance in connection with legal requirements (such as the *Transportation of Dangerous Goods (TDG) Regulations*) and safety precautions involved in fuel handling and storage. It is normally specified to meet insurance and fire regulations.

C.5 Ignition quality: Cetane number and calculated cetane index

C.5.1 Cetane number and derived cetane number are measures of the ignition quality of the fuel and influence combustion characteristics. The cetane number requirements depend on engine design and size, nature of speed and load variations, and starting and atmospheric conditions. Higher cetane number fuels generally give better performance in aspects such as emissions, noise, cold-starting and white smoke generation.

C.5.2 The calculated cetane index is a useful technique for approximating the cetane number of fuels that do not contain a cetane-improver additive.

C.6 Viscosity and lubricity

C.6.1 A minimum viscosity is specified to minimize power loss due to injection pump and injector leakage and ensure sufficient hydrodynamic lubrication of fuel system components. Maximum viscosity is limited to ensure fuel pumpability and proper functioning of the injection system.

C.6.2 For some engines, diesel fuel is a lubricant for the injection system; therefore, it must have sufficient lubricity to ensure fuel system durability and hence emission durability requirements. Diesel fuel lubricity can be defined as the ability of a fuel to prevent or minimize wear in diesel fuel injection equipment.

C.7 Distillation

Fuel volatility requirements also depend on engine design and size, nature of speed and load variations, as well as starting and atmospheric conditions. More volatile fuels can provide better startability and reduced white smoke under cold engine operation.

C.8 Carbon residue

Carbon residue gives a measure of the carbon-depositing tendencies of a diesel fuel after evaporation and pyrolysis under prescribed conditions. While not directly correlating with engine deposits, this property is considered a guide.

C.9 Sulphur

The use of sulphur levels higher than 15 mg/kg will contribute to the weight of particulates in the exhaust and will have a deleterious effect on catalytic after-treatment systems. Diesel fuel with a maximum sulphur level of 15 mg/kg is required to ensure compatibility with exhaust after-treatment technology of modern diesel-powered equipment.

C.10 Low-temperature operability

C.10.1 Low-temperature operability of diesel fuels may be defined by either the cloud point or the low-temperature flow test or some combination thereof.

C.10.2 Cloud point defines the temperature at which the smallest observable cluster of hydrocarbon crystals first appears in a fuel upon cooling under prescribed test conditions. It is the most common measure of low-temperature operability.

C.10.3 The low-temperature flow test was developed in order to predict low-temperature operability of fuels to which a flow improver has been added. A cloud point test on such additized fuels might not accurately predict the operability limit of the fuel due to the use of these additives.

C.10.4 The viscosity of a fuel blend will increase under cold ambient temperatures. In some situations the fuel's viscosity can be the limiting low temperature operability factor as opposed to wax formation in the fuel.

C.11 Ash

Ash-forming materials can be present in diesel fuels as abrasive solids and soluble metallic soaps. Abrasive solids contribute to injector, fuel pump, piston and ring wear, and also to engine deposits. Soluble metallic soaps have little effect on wear but may contribute to engine deposits.

C.12 Acidity

There is directional evidence that acidic fuels can have poorer stability, may cause increased corrosion of mild steel, and could cause deposit formation in some types of fuel injection equipment.

C.13 Copper strip corrosion

This test serves as a measure of possible corrosion of copper, brass or bronze parts in the fuel system.

C.14 Electrical conductivity

The ability of a fuel to dissipate electric charge that has been generated during pumping and filtering operations is controlled by its conductivity. If a fuel's conductivity is sufficiently high, the static electric charge dissipates fast enough to prevent its accumulation and dangerously high electrical potentials are avoided.

C.15 Recommended practices for the storage and handling of diesel fuels

Diesel fuels should be stored under cool, clean and dry conditions. Free water should regularly be drained from storage tanks and filter housings. Diesel fuels that are to be kept in storage may require the addition of a biocide to minimize potential microbial contamination and related degradation in fuel quality (should free water be present). Organic sediment may appear in diesel fuels in long-term storage. Primary filtration of these fuels is recommended prior to use. Where long-term storage of diesel fuels is contemplated, use of stability additives (e.g. anti-oxidants, metal deactivators and dispersants) should be considered and the fuel supplier should be consulted. Fuel storage containers and tanks should be opaque. Some translucent (plastic) tanks exposed to light have proven to be unsatisfactory for the storage of diesel fuels.

C.16 Used lubricating oils or fluids

Used lubricating oils or fluids are not suitable components for use in diesel fuels. The addition of used lubricating oils or fluids to diesel fuels may increase exhaust emissions, increase wear of engine components such as injectors, increase deposits in the engine, and cause premature fuel filter plugging.

C.17 Thermal stability

C.17.1 Heat transfer is a design function of diesel fuels in many modern diesel engines. Only a portion of the fuel that is circulated and pressurized by the fuel injection system is actually combusted. The remainder of the fuel is recycled back to the fuel tank. The bulk fuel temperature can be well above ambient levels. Inadequate high-temperature stability of a diesel fuel can result in the formation of insoluble degradation products that may then cause filter plugging.

C.17.2 ASTM D6468⁶ may be used to measure diesel fuel thermal stability. A higher percentage reflectance rating in this test indicates better thermal stability and a reduced tendency to cause filter plugging.

⁶ ASTM D6468 — Standard Test Method for High Temperature Stability of Distillate Fuels.

C.18 Density

While density is not a requirement of this standard, the density of a batch of diesel fuel should be measured and reported on the Certificate of Analysis for quality control purposes and to allow calculation of the mass of a given volume of fuel. Knowledge of the original density of a batch of fuel is useful to someone receiving the fuel. If the density of the fuel as received is significantly different from its original density measurement, it indicates possible contamination and is cause for further product quality investigation. Density can be measured in diesel using ASTM D1298⁷ or D4052⁸.

Better fuel economy is generally obtained with higher density fuels because of their higher energy content per unit volume.

⁷ ASTM D1298 — Standard Test Method for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method.

⁸ ASTM D4052 — Standard Test Method for Density, Relative Density, and API Gravity of Liquids by Digital Density Meter.