

C. C. I. W.  
LIBRARY

ANALYSIS OF THE SAVINGS IN  
HYDRO COMSUMPTION WITH THE ADDITION  
OF THERMOSTATS TO GAUGEHOUSES IN  
SOUTHERN ONTARIO  
(Summary Report)

WATER RESOURCES BRANCH  
ONTARIO REGION  
INLAND WATERS DIRECTORATE

ENVIRONMENT CANADA

1981

Prepared by: Peter Beranek

## TABLE OF CONTENTS

	<u>PAGE</u>
Introduction .....	1
Energy Consumption at Stations without Thermostat Control .....	2
The Savings in Hydro Consumption with the Addition of Thermostats to Gaugehouses in Southern Ontario .....	3
Conclusions .....	5
Recommendations .....	5
Appendices	

## INTRODUCTION

The Water Resources Branch, Ontario Region, operates and maintains about 365 hydrometric gauging stations. One part of the operating and maintenance budget is that of Hydro power used in the gaugehouses. It amounts to approximately 1/7th of the total O&M budget (salaries are not included). This is not a negligible expense and it represents quite a significant amount of electric energy being used every year.

Basically, most of the electric energy is used when heating cables, baseboard heaters and/or heating lamps are in operation. There are also other electrical appliances in the gaugehouses whose energy consumption is not substantial, such as light bulbs, electric clocks, and battery chargers. Up to 1978 heating cables and heat lamps were usually left in operation throughout the "cold" season without interruption or any regulation. The time of switching on and off (or rather plugging in and out) of the cables and lamps was determined by field staff according to the weather conditions at the beginning and at the end of the winter season.

To keep the overall operation and maintenance budget to a minimum and also to conserve energy, it makes good sense to try to reduce hydro consumption to a minimum at each station. This can be achieved with the aid of thermostats.

The purpose of this short study was to analyse how the energy consumption changed after the introduction of thermostats at some 25 gauging stations in Southern Ontario. It must be stressed that this report is of a rather preliminary nature, since data on yearly energy consumption with thermostats is limited. Results will be updated as more data and experience is obtained.

ENERGY CONSUMPTION AT STATIONS WITHOUT THERMOSTAT CONTROL:

The main reason for a heating cable and/or heating lamp installation in the stilling well of a gauge is to prevent intake pipes and/or in some cases the well itself from freezing up during winter.

The standard heating cable, code-named "EASY", has been used routinely in most installations in Ontario. This is a regular 120V/750 Watt, 95 feet long, pipe heating cable (see Appendix 1).

The following are examples of yearly hydro consumptions in some gauging stations in Southern Ontario, before installation of thermostats:

SCHNEIDER CREEK at KITCHENER

<u>Period</u>	<u>Consumption (kWh)</u>
June '73 - June '74	- 1570
" '74 - " '75	- 1910
" '75 - " '76	- 1290
" '76 - " '77	- 1000
" '77 - " '78	- 1450

BEAVERTON RIVER near BEAVERTON

<u>Period</u>	<u>Consumption (kWh)</u>
June '73 - June '74	- 3130
" '74 - " '75	- 4920
" '75 - " '76	- 2890
" '76 - " '77	- 2430
" '77 - " '78	- 3290
" '78 - " '79	- 3060

EAST CANAGAGIGUE CREEK near FLORADALE

<u>Period</u>	<u>Consumption (kWh)</u>
June '73 - June '74	- 1880
" '74 - " '75	- 2440
" '75 - " '76	- 2100
" '76 - " '77	- 1110
" '77 - " '78	- 1520
" '78 - " '79	- 2200

The approximate averages of yearly hydro consumption from a sample of about 25 hydrometric stations in Southern Ontario ranged from 1,500 to 4,500 kilowatt hours for the years 1973 to 1977.

Since 1978 thermostats have been systematically installed in the majority of the stations with heating cables. Sixteen stations were equipped with thermostats in 1978, an additional 51 in 1979 and 7 in 1980. Now all newly built shelters have thermostats installed during construction.

The typical cost involved in the installation of a Type 4688 thermostat (see Appendix 1) is around \$100.00. This consists of about \$50.00 for materials and travel and another \$50.00 for salaries.

#### SAVINGS IN HYDRO CONSUMPTION WITH ADDITION OF THERMOSTATS TO GAUGEHOUSES IN SOUTHERN ONTARIO

Analysis was completed on the savings in hydro consumption that resulted from the installation of thermostats in gaugehouses in the Ontario Region. A total of 25 gauging stations were included in the analysis sample from which 5 stations had thermostats installed for the past three years and 20 stations had thermostats for two years (see Appendix 2).

In summary, the analysis has shown that:

1. In 21 cases there have been substantial savings in hydro consumption ranging from 50% to 85%.
2. In 2 cases the savings were close to 50%.
3. In two other cases the savings in hydro consumption after thermostat installation were 17% only.

The following are some examples of electric power savings:

1. Patterson Creek near Simcoe (Account #1966006)

<u>Period</u>	<u>Consumption (kWh)</u>
July '73 - July '74	- 4980
" '74 - " '75	- 3610
" '75 - " '76	- 2710
" '76 - " '77	- 3080
" '77 - " '78	- 2560
" '78 - " '79	- 3660
" '79 - " '80	- 320
" '80 - " '81	- 730

Thermostat installed July 13, 1979.

2. Lynn River at Simcoe (Account #20-0089)

<u>Period</u>	<u>Consumption (kWh)</u>
July '74 - July '75	- 3840
" '75 - " '76	- 2800
" '76 - " '77	- 2570
" '77 - " '78	- 2960
" '78 - " '79	- 3440
" '79 - " '80	- 330
" '80 - " '81	- 1440

Thermostat installed July 12, 1979.

3. Schneider Creek at Kitchener (Account #1106-0192-09)

<u>Period</u>	<u>Consumption (kWh)</u>
June '73 - June '74	- 1570
" '74 - " '75	- 1910
" '75 - " '76	- 1290
" '76 - " '77	- 1000
" '77 - " '78	- 1450
" '78 - " '79	- 330
" '79 - " '80	- 180
" '80 - " '81	- 300

Thermostat installed May 9, 1978.

The foregoing illustrates that thermostats, IF PROPERLY SET, are very good energy and money savers. But again it must be stressed that proper setting of thermostats on  $\neq 3^{\circ}\text{C}$  and higher only if the site conditions necessitate, is the key condition to maximizing the savings. The thermostat settings and also connections to heating cables should be checked annually before the winter season's arrival.

#### CONCLUSIONS:

The analysis of hydro usage at hydrometric stations has shown that after introduction of thermostats to control the heating devices, hydro consumption has dropped in average by 64% for the 25 stations selected.

The initial moderate expense for the installation of thermostats (approximately \$100.00 each) is in most cases quickly recouped, usually during the first season of winter operation.

#### RECOMMENDATIONS:

It is recommended that thermostats be set on  $\neq 3^{\circ}\text{C}$  and that connections of all heating devices be inspected before winter season's arrival.

It is recommended that heating elements in ALL Water Resources Branch field installations be controlled by thermostats.

It is recommended that hydro consumption recording procedure be reviewed and improved.


Finally it is recommended to update the hydro consumption analysis as shown in Appendix 2, annually and also to perform similar analysis on all the rest of Ontario Region hydrometric stations, where applicable.

## APPENDICES



TABLE II — STANDARD HEATING CABLE UNITS

Code Name	Design	Length in ft.	120 VOLTS		208 VOLTS		240 VOLTS	
			Watts	Unit Recommended for *	Watts	Unit Recommended for *	Watts	Unit Recommended for *
FOX	A	108	200	P	650	F,P,E	900	P,E
BAKER	A	72	300	F,P	1000	P,E	1300	
TEAR	A	177	400	P	1200	P,E	1600	P,E
GOLF	A	54	450	F,P,E	1300		1700	
HOTEL	A	68	500	P,E	1500		2000	
UNCLE	A	264	550	F,P	1650	F,P,E	2100	P,E
INDIA	A	40	550	P,E	1650		Not Recommended	
EASY	A	95	750	F,P,E	2300			
VICE	A	177	600	P,E	2400	P	3200	E
MOM	A	132	1100	P,E	3300		4300	
NAN	A	264	1100	F,P	3300	P,E	4300	P,E

**Type 4688 Thermostat:**


Used to control pipe and tank temperatures up to 120°F, and slab temperatures such as floor warming and animal pens.

Remote bulb type with temperature range 30-120°F. Temperature differential 3½°F, ambient compensated. Electrical rating 30 amps on 115 or 230 V.A.C. 10 foot copper capillary, moisture and dust-resistant enclosure. S.P.S.T. contacts open on temperature rise. Also available as 4688-P with nylon coated capillary.



# Installation Recommendation No. 535

March, 1980



## Installation of 4688P, 4688WP and 4395W Thermostats

### Specification Reference 4688P Series Thermostats

Type: Remote bulb;  
 Temperature Set Range: 0°C to 50°C  
 Maximum Permissible Temperature at Bulb: 68°C  
 Rating: 30 amps on 125 or 250 VAC  
 Description: 10 ft. copper capillary with HDPE jacket; contacts open on temperature rise, SPST, ambient compensated. Sensing bulb is 3/8" diameter X 5-3/4" long.

ALSO AVAILABLE AS 4688WP.

### Specification Reference 4395W Thermostat

Type: Remote bulb; weathertight case  
 Temperature Set Range: 0°C to 120° C  
 Maximum Permissible Temperature at Bulb: 176°C  
 Rating: 30 amps on 125 or 250 volts  
 Description: 10 ft. copper capillary; contacts open on temperature rise, SPST, ambient compensated. Sensing bulb is 1/4" diameter x 5-1/2" long.

### Case

#### (REFERENCE 4688P)

Case is moisture and dust resistant with external temperature adjustment knob and red indicating lamp; 6-9/16" x 4" x 2-5/8" deep. Two 1/2" knockouts.

#### (REFERENCE 4688WP & 4395W)

Case is cast aluminum weathertight box, suitable for direct exposure to weather but NOT FOR UNDERGROUND BURIAL; 6" x 5-3/4" x 3-1/2" deep. Two 1/2" NPT ENTRIES.

### Installation

After a suitable location has been chosen, surface-mount the box in a vertical position with the capillary tube emerging from the bottom.

The switch mechanism of remote bulb types may be mounted at any convenient point away from the controlled area within the length of the capillary. The bulb should be located against the heated medium with the least amount of capillary in the controlled area. Excessive capillary should be coiled and secured in some convenient location close to the switch mechanism.

**CAUTION: PROTECT THE CAPILLARY FROM KINKS, SHARP BENDS (OF LESS THAN 1/2 INCH IN RADIUS) AND UNNECESSARY HANDLING.**

Install wiring as per approved method (Refer to wiring diagram).

### Testing


The bulb may be inserted in a liquid, heated to the temperature to be maintained. Turn the shaft until a 'CLICK' is heard. This indicates that the contacts are making and breaking and will ensure that the setting corresponds to the guide scale.

### Wiring

All wiring should be in accordance with the local and national codes.

Note: The connection diagrams below refer to installations where the supply voltage is 250 volts or less. For higher voltages a contactor must be used with a separate supply for the contactor coil-thermostat circuit of 250 volts or less.

### Connection Diagrams



Pyrotenax of Canada Limited, Trenton, Ontario

ANALYSIS OF HYDRO CONSUMPTION AT SOME ONTARIO HYDROMETRIC  
STATIONS (IN KWH)

HYDROMETRIC STATION	HYDRO USAGE DURING YEAR -												THERMOSTAT INSTALLED	AVERAGE w/o THERMOSTAT	AVERAGE WITH THERMOSTAT	[%] REDUCTION
	73/74	74/75	75/76	76/77	77/78	78/79	79/80	80/81	81/82	82/83						
Schomberg R. nr. Schomberg	4 800	?	4 220	4 580	?	1 170	740	1 200					Apr. 78	4 530	1 040	77
Schneider Crk. at Kitchener	1 570	1 910	1 290	1 000	1 450	330	180	300					May 78	1 440	270	81
Lutteral Crk. nr. Dugate	3 310	5 200	4 970	3 890	2 980	1 390	1 560	1 660					Apr. 78	4 070	1 540	62
Twenty Mi. Crk. at Ball's Falls	1 632	2 388	1 680	1 610	1 472	270	170	730					Oct. 78	1 760	390	78
Alder Crk. nr. New Dundee	3 120	2 110	1 760	1 250	1 470	770	660	680					Mar. 78	1 940	670	65
Collins Crk. nr. Kingston	3 450	?	-	-	2 700	3 130	820	640					Aug. 79	3 090	730	76
S/Maitland at Summer-Rise	3 070	3 130	3 390	3 710	3 010	1 390	1 530	1 380					Oct. 79	2 950	1 455	51
Beaverton R. nr. Beaverton	3 130	4 920	2 890	2 430	3 290	3 060	730	860					Aug. 79	3 290	795	76
Sydenham R. nr. Owen Sound	2 080	3 005	?	1 951	2 076	2 230	322	1 040					Oct. 79	2 270	680	70
N/Saugeen R. nr. Paisley	2 680	3 729	3 418	4 799	4 615	2 713	3 030	1 200					Oct. 79	3 850	2 115	45
Maitland R. bel. Wingham	2 859	3 700	3 641	3 164	?	?	1 320	888					Oct. 79	3 340	1 105	67
Sauble R. at Sauble Falls	3 270	3 502	4 203	3 370	3 584	?	914	600					Oct. 79	3 585	760	79
Castor Cr. at Russell	2 910	1 080	1 810	3 280	4 180	5 030	1 250	1 420					May 79	3 050	1 335	56
E/Cawagagigue Crk. nr. Flor.	1 880	2 440	2 100	1 110	1 520	2 200	410	490					May 79	1 875	450	76
Bronde Crk. nr. Zimmerman	3 090	2 680	4 080	2 380	2 969	?	630	720					May 79	2 450	675	72
Ganaraska R. nr. Deaca	3 453	4 300	3 415	2 242	?	4 850	730	1 350					May 79	2 960	1 040	65
Patterson Crk. nr. Simcoe	4 980	3 610	2 710	3 080	2 560	3 660	320	730					Jul. 79	3 430	525	85
Lynn R. at Simcoe	?	3 840	2 800	2 570	2 960	3 440	330	1 440					Jul. 79	3 120	885	72
Nendicore Crk. at Nandic.	5 350	4 000	4 100	2 360	?	3 640	1 600	2 230					Jul. 79	3 890	1 915	51
L/Otter Crk. nr. Strathford	2 390	?	1 370	1 490	1 110	1 580	610	1 020					Jul. 79	1 590	1 325	17
S/Par-Rill Crk. nr. Par-R.	?	2 873	2 910	3 314	2 500	3 343	1 534	?					Jul. 79	2 990	1 530	49
Trent R. at Heeley Falls	?	2 070	2 500	5 580	?	1 850	810	1 420					Aug. 79	3 000	1 115	63
Cold Crk. nr. Bolton	2 827	5 663	4 016	6 377	3 483	5 383	1 400	?					Oct. 79	4 620	1 400	70
Fisk Crk. nr. Prosp. Hill	1 760	2 738	3 042	1 193	2 394	3 660	530	?					May 79	2 465	530	78
Sheller Valley Brk. nr. Grafton	1 770	1 720	1 600	2 240	1 390	1 450	1 200	1 700					Apr. 78	1 745	1 450	17