




Environmental Protection Series



National Incinerator Testing
and Evaluation Program:
The Environmental
Characterization of
Refuse-derived Fuel (RDF)
Combustion Technology

Mid-Connecticut Facility
Hartford, Connecticut

Summary Report

Report EPS 3/UP/7
Report EPA-600/R-94-140
December 1994

Canada
United States



Environnement
Canada




Environmental
Protection Agency

TD
172
C28
no.3
UP7

ENVIRONMENTAL PROTECTION SERIES

Sample Number:



Categories

- 1 Regulations/Guidelines/Codes of Practice
- 2 Problem Assessments and Control Options
- 3 Research and Technology Development
- 4 Literature Reviews
- 5 Surveys
- 6 Social, Economic and Environmental Impact Assessments
- 7 Surveillance
- 8 Policy Proposals and Statements
- 9 Manuals

Subject Areas

- | | |
|------------|------------------------------------|
| AG | Agriculture |
| AN | Anaerobic Technology |
| AP | Airborne Pollutants |
| AT | Aquatic Toxicity |
| CC | Commercial Chemicals |
| CE | Consumers and the Environment |
| CI | Chemical Industries |
| FA | Federal Activities |
| FP | Food Processing |
| HA | Hazardous Wastes |
| IC | Inorganic Chemicals |
| MA | Marine Pollutants |
| MM | Mining and Ore Processing |
| NR | Northern and Rural Regions |
| PF | Paper and Fibres |
| PG | Power Generation |
| PN | Petroleum and Natural Gas |
| RA | Refrigeration and Air Conditioning |
| RM | Reference Methods |
| SF | Surface Finishing |
| SP | Oil and Chemical Spills |
| SRM | Standard Reference Methods |
| TS | Transportation Systems |
| TX | Textiles |
| UP | Urban Pollution |
| WP | Wood Protection/Preservation |

New subject areas and codes are introduced as they become necessary. A list of EPS reports may be obtained from Environmental Protection Publications, Environmental Protection Service, Environment Canada, Ottawa, Ontario, Canada, K1A 0H3.

Printed on
recycled paper



Imprimé sur du
papier recyclé



36 001 377

REF
EPS
3/UP/7

National Incinerator Testing and Evaluation Program: The Environmental Characterization of Refuse-derived Fuel (RDF) Combustion Technology

Mid-Connecticut Facility
Hartford, Connecticut

Summary Report

Environment Canada
Solid Waste Management Division

and

United States Environmental Protection Agency
Air and Energy Engineering Research Laboratory

TD	The National Incinerator
172	Testing and Evaluation Program
C28	: the environmental
no.3	characterization of Refuse-
UP7	Derived Fuel (RDF) combustion

refuse-derived fuel

Report EPS 3/UP/7
Report EPA-600/R-94-140
December 1994

9704

2038

CANADIAN CATALOGUING IN PUBLICATION DATA

Main entry under title:

The National Incinerator Testing and Evaluation Program : the environmental characterization of refuse-derived fuel (RDF) combustion technology: Mid-Connecticut facility, Hartford, Connecticut

(Report ; EPS 3/UP/7)

Issued also in French under title: Le Programme d'essai et d'évaluation national des incinérateurs, caractérisation environnementale d'une technologie de brûlage de combustibles dérivés des déchets (CDD): installation Mid-Connecticut, Hartford (Connecticut). Sponsored by Environment Canada, National Incinerator Testing and Evaluation Program (NITEP) ; United States Environmental Protection Agency, Municipal Waste Combustion Program.

ISBN 0-662-20541-3

DSS cat. no. En49-8/3-7E

1. Incinerators -- Environmental aspects.
2. Refuse as fuel -- Environmental aspects.
3. Waste products as fuel -- Environmental aspects.
- I. Canada. Environment Canada.
- II. Municipal Waste Combustion Program (U.S.)
- III. Title: The environmental characterization of refuse-derived fuel (RDF) combustion technology.
- IV. Series: Report (Canada. Environment Canada) ; EPS 3/UP/7.

TD796.2N37 1994 362.72'85 C93-099548-1

Readers' Comments

Any comments on the contents of this report should be addressed to:

Solid Waste Management Division
Office of Waste Management
Conservation and Protection
Environment Canada
Ottawa, Ontario
K1A 0H3

Air and Energy Engineering
Research Laboratory
U.S. Environmental Protection Agency
Research Triangle Park,
North Carolina 27711

Cette publication est aussi disponible en français sous le titre *Le Programme d'essai et d'évaluation national des incinérateurs : caractérisation environnementale d'une technologie de brûlage de combustibles dérivés de déchets (CDD)*, à l'adresse ci-dessous.

Additional copies of this report are available from:

Environmental Protection
Publications
Technology Development
Directorate
Conservation and Protection
Environment Canada
Ottawa, Ontario
K1A 0H3
Telephone: (613) 953-5921

National Technical Information Service
5285 Port Royal Road
Springfield, VA. 22161
Telephone: (703) 487-4650

Review Notice

This report has been reviewed and approved for publication by the Office of Waste Management of Environment Canada. This approval does not necessarily mean that the contents of this report reflect the views and policies of Environment Canada. Mention of trade names or commercial products does not constitute endorsement for use.

Abstract

The environmental characterization of refuse-derived fuel (RDF) semi-suspension burning technology was undertaken jointly by Environment Canada and the U.S. Environmental Protection Agency (U.S. EPA) as part of ongoing programs of both agencies that assess municipal solid waste combustion technologies. The facility tested is located in Hartford, Connecticut and represents a "state-of-the-art" technology, including a spray dryer/fabric filter air pollution control (APC) system for each unit.

Results were obtained for a variety of steam production rates, combustion conditions, flue gas temperatures, and acid gas removal efficiencies. All incoming wastes and each ash residue stream were weighed, sampled, and analyzed. Key incinerator and APC system operating variables were monitored on a "real time" basis. A wide range of analyses for acid gases, trace organics, and heavy metals was carried out on gas emissions and all the ash discharges.

Very low concentrations were observed of trace organics, heavy metals, and acid gases in stack emissions. High removal efficiencies were attained by the APC system for trace organics and metals in the flue gas. Trace organic contaminants in the ashes were not soluble in water, while only very small amounts of most trace metals present in the ashes were soluble in water. A significant reduction in metal mobility was achieved for fabric filter ash that was solidified using cement and waste pozzolanic materials. Multi-variate correlations were found between trace organics at the furnace exit and indicators of combustion conditions, such as operating variables and easily monitored combustion gases. These parameters could potentially be used to control incinerator operating conditions to ensure minimal trace organics in the flue gas entering the APC system.

Résumé

Environnement Canada et l'Environmental Protection Agency (EPA) des États-Unis ont entrepris conjointement un programme de caractérisation environnementale d'une technologie d'incinération de combustible dérivé de déchets (CDD) en semi-suspension, dans le cadre de leurs activités permanentes d'évaluation de technologies de combustion de déchets solides urbains. L'installation soumise aux essais est située à Hartford (Connecticut) et est à la fine pointe de la technologie, chacune de ses unités étant dotée d'un système antipollution comprenant un séchoir à pulvérisation et des filtres à sacs.

On a obtenu des résultats pour un certain nombre de débits de production de vapeur, de conditions de combustion, de températures des gaz de combustion et de rendements d'élimination des gaz acides. Tous les déchets à brûler et toutes les cendres ont été pesés, échantillonnés et analysés. Les variables de base du fonctionnement de l'incinérateur et du système antipollution ont fait l'objet d'une surveillance en temps réel. De nombreuses analyses ont été effectuées sur les émissions gazeuses et sur toutes les cendres, pour y doser les gaz acides, les composés organiques traces et les métaux lourds.

De très faibles concentrations de composés organiques traces, de métaux lourds et de gaz acides ont été observées dans les gaz de combustion; le système antipollution a eu un rendement d'élimination élevé pour les composés organiques traces et pour les métaux qui étaient présents dans ces gaz. Dans les cendres, les composés organiques traces n'étaient pas solubles dans l'eau, tandis que de très faibles quantités de la plupart des métaux traces l'étaient. On a obtenu une importante réduction de la mobilité des métaux dans les cendres des filtres à sacs qui ont été solidifiées à l'aide de ciment et de matières pouzzolaniques résiduelles. On a trouvé des corrélations multidimensionnelles significatives entre les concentrations de composés organiques traces à la sortie du foyer et des indicateurs des conditions de combustion, tels que des variables de fonctionnement et des concentrations de gaz de combustion faciles à surveiller. Ces variables pourraient servir de paramètres pour la régulation des conditions de fonctionnement de l'incinérateur, en vue de minimiser les quantités de composés organiques traces dans les gaz de combustion qui entrent dans le système antipollution.

Table of Contents

Abstract	v
Résumé	vi
List of Figures	x
List of Tables	xiii
Summary	xvi
Acknowledgements	xix
 <i>Section 1</i>	
Introduction	1
1.1 Program Background	1
1.2 Program Objectives	2
1.3 Refuse-derived Fuel (RDF) Test Site	2
1.4 Project Reports	2
1.5 Structure of this Report	3
 <i>Section 2</i>	
Description of Facility	4
2.1 Site Overview	4
2.2 Process Description	4
2.2.1 Refuse-derived Fuel Preparation/Handling System	4
2.2.2 Steam Generating System	6
2.2.3 Air Pollution Control System	7
 <i>Section 3</i>	
Program Description	9
3.1 Approach to Testing	9
3.2 Site Selection	9
3.3 Selection and Preparation of Sampling Locations	9
3.3.1 Feed Streams	9
3.3.2 Ash Streams	10
3.3.3 Flue Gas Streams	11
3.4 Characterization Test Series	12
3.4.1 Objectives	12
3.4.2 Overview	12
3.4.3 Process Conditions of Characterization	
Test Program	14
3.4.4 Summary of Characterization Test Results	14
3.5 Performance Test Series	17
3.5.1 Objectives	17
3.5.2 Process Conditions of Performance	
Test Program	17
 <i>Section 4</i>	
Sampling and Analytical Protocols	21

4.1	Overview	21
4.2	Process Stream Sampling	21
4.3	Flue Gas Sampling	22
4.4	Process Parameter Measurements	24
4.5	Data Acquisition System (DAS)	27
4.6	Laboratory Analytical Procedures	28
4.6.1	General	28
4.6.2	Analytical Protocols	29
4.7	Statistical Data Analysis	31
4.8	Quality Assurance/Quality Control (QA/QC)	33

Section 5

Performance Test Series for Combustion System		36
5.1	Overview	36
5.2	Summary by Performance Test Run	37
5.3	Summary by Performance Test Condition	37
5.3.1	Process Data	41
5.3.2	Continuous Emissions Monitoring (CEM) Data	41
5.3.3	Trace Organic Concentrations	41
5.3.4	Particulate/Metal Concentrations	44
5.3.5	Analysis of Refuse-derived Fuel (RDF)	44
5.3.6	Ash Analysis	44
5.4	Organics: Input/output Analysis	44
5.5	Formation of Nitrogen Oxides (NO _x)	49
5.6	Furnace Formation of PCDD/PCDF	52
5.6.1	Good Combustion - Effects of Entrained Particulate Matter	53
5.6.2	Poor Combustion - Effects of Carbon Monoxide Emissions	53
5.7	“Downstream” or Low Temperature Formation of PCDD/PCDF	57
5.8	Effects of Carbon in Ash on PCDD/PCDF Concentrations	57
5.9	Parameters Affecting Emissions of Carbon Monoxide	59
5.10	Multiple Regression Analysis - Combustion System	60
5.10.1	Overview	60
5.10.2	Dioxin Models	61
5.10.3	Furan Models	61
5.10.4	Models for Other Trace Organics	61

Section 6

Performance Test Series for Air Pollution Control System		65
6.1	Overview	65
6.2	Summary by Performance Test Run	65

6.3	Summary by Performance Test Condition	65
6.3.1	Air Pollution Control Process Data	65
6.3.2	Continuous Emissions Monitoring (CEM) Data	69
6.3.3	Trace Organic Concentrations	70
6.3.4	Particulate/Metal Concentrations	73
6.4	Multiple Regression Analysis - Air Pollution Control System	74
6.4.1	Air Pollution Control Operating Variables for Regression Analysis	74
6.4.2	Correlations for Removal of Sulphur Dioxide	75
6.4.3	Correlations for Removal of Hydrogen Chloride	77
6.4.4	Correlations for Removal of Trace Organics	77
6.4.5	Correlations for Removal of Mercury	79

Section 7

Ash Characterization Results	81
7.1 Overview	81
7.2 Chemical Composition Analyses	81
7.3 Acid Neutralization Capacity	82
7.4 Leachability	82
7.4.1 Organic Contaminants	82
7.4.2 Inorganic Contaminants	84
7.5 Evaluation of Solidified Fabric Filter Ash	87

Section 8

Conclusions	88
8.1 Overview	88
8.2 General	88
8.3 Ash Results	89
8.4 Correlations	90

Section 9

Recommendations	92
References	94

Appendix A

Combustion and Air Pollution Control System Test Results	97
---	-----------

Appendix B

Combustion System Summary by Performance Test Condition	113
--	------------

Appendix C

Air Pollution Control System Summary by Performance Test Condition	121
---	------------

Appendix D

Symbols and Abbreviations	131
--	------------

List of Figures

1	Mid-Connecticut Facility Design	5
2	Refuse-derived Fuel Incinerator Schematic	6
3	Process Schematic Showing Sampling Locations	10
4	Sampling Parameters for Characterization Test	13
5	Characterization Test Operating Conditions for Combustion System Test Series	15
6	Characterization Test Operating Conditions for Air Pollution Control System Test Series	16
7	Performance Test Operating Conditions for Combustion System Test Series	18
8	Performance Test Operating Conditions for Air Pollution Control System Test Series	19
9	Performance Test Sampling Parameters	20
10	Schematic of Sampling Trains	25
11	Volatile Organic Sampling Train Schematic	26
12	Performance Test Key Operating Parameters for Combustion System Test Series	38
13	Input/Output Analysis for PCDD and PCDF	50
14	Carbon Monoxide versus Nitrogen Oxides in Flue Gas at Spray Dryer Inlet	51
15	Test Average Carbon Monoxide versus Nitrogen Oxides	52
16	PCDD/PCDF versus Particulate at Spray Dryer Inlet for Good Combustion Conditions	53
17	PCDD/PCDF versus Particulate at Spray Dryer Inlet for all Tests	54
18	PCDD/PCDF versus Carbon Monoxide at Spray Dryer Inlet	55
19	PCDD/PCDF versus Total Hydrocarbon at Spray Dryer Inlet	55

20	PCDD/PCDF at Spray Dryer Inlet versus Percent of Time Carbon Monoxide is Greater than 400 ppm	56
21	PCDD/PCDF Levels Across Air Preheater	58
22	PCDD/PCDF at Spray Dryer Inlet versus Loss-on-Ignition of Economizer Ash	59
23	Calculated PCDD versus Measured PCDD at Spray Dryer Inlet - Prediction Model	62
24	Calculated PCDF versus Measured PCDF at Spray Dryer Inlet - Prediction Model	64
25	Performance Test Key Operating Parameters for Air Pollution Control System Test Series	66
26	Sulphur Dioxide Removal Efficiency per Performance Test Run	71
27	Hydrogen Chloride Removal Efficiency per Performance Test Run	71
28	Sulphur Dioxide Removal by Air Pollution Control System versus Overall Stoichiometric Ratio (OSR), One Variable Model	76
29	Measured versus Calculated Overall Sulphur Dioxide Removal, Two Variable Model (Overall Stoichiometric Ratio and Fabric Filter Outlet Temperature)	76
30	Sulphur Dioxide Removal by Spray Dryer versus Hydrogen Chloride at Spray Dryer Inlet	77
31	Overall Hydrogen Chloride Removal by Air Pollution Control System versus Overall Stoichiometric Ratio	78
32	Measured versus Calculated Overall Hydrogen Chloride Removal - Two Variable Model (Reduced Stoichiometric Ratio and Spray Dryer Outlet Temperature)	78
33	Overall Mercury Removal versus Overall Stoichiometric Ratio	80
34	Overall Mercury Removal versus Fabric Filter Outlet Temperature	80

35	Average Acid Neutralization Capacity Results	83
36	Average Cumulative Total Fraction of Solids Dissolved during the Sequential Batch Extraction Procedure	84
37	Sequential Chemical Extraction Results for Lead from the Bottom Ash/Grate Siftings and Fabric Filter Ash	86

List of Tables

1	Continuous Emissions Monitoring Locations/Parameters/Instruments	23
2	Major Process and Emission Parameters Monitored . .	26
3	Analytical Responsibilities and Methods - Performance and Characterization Testing	30
4	Trace Metals	30
5	Target Semivolatile Organic Analytes	32
6	Volatile Organics	33
7	External and Internal Quality Assurance/Quality Control Responsibilities	35
8	Key Process Data for Combustion System per Performance Test Run	39
9	Key Data for Combustion Gas Composition per Performance Test Run	40
10	Key Process Data for Combustion System per Performance Test Condition	42
11	Continuous Emissions Monitoring Data for Combustion System per Performance Test Condition	42
12	Trace Organic Concentrations for Combustion System per Performance Test Condition	43
13	Trace Organic Concentrations Before Air Pollution Control for Good Operation versus Poor Operation	44
14	Particulate and Trace Metals Concentration for Combustion System per Performance Test Condition	45
15	Refuse-derived Fuel Analysis (Dry Basis) per Performance Test Condition	46
16	Trace Organics in Ash per Performance Test Condition	47

17	Trace Metals in Ash per Performance Test Condition	48
18	Destruction of Organics by Combustion	49
19	Multiple Regression for PCDD at Spray Dryer Inlet - Prediction Models	62
20	Multiple Regression for PCDD at Spray Dryer Inlet - Control Models	63
21	Key Process Data for Air Pollution Control System per Performance Test Run	67
22	Key Concentration Data for Air Pollution Control System per Performance Test Run	68
23	Key Process Data for Air Pollution Control System per Performance Test Condition	69
24	Continuous Emissions Monitoring Data for Air Pollution Control System per Performance Test Condition	70
25	Concentrations of Trace Organics for Air Pollution Control System per Performance Test Condition	72
26	Range of Concentrations for Particulate and Trace Metals	74
27	Summary of Average Concentrations ($\mu\text{g/g}$) of Trace Metals in Ash	82
28	Maximum Detected Concentration of Trace Organics in Leachates	83
29	Summary of Descriptions and Interpretations for the Sequential Chemical Extraction Procedure . . .	85
A-1	Performance Test Summary Data: Process Parameters	98
A-2	Test Summary Data: Continuous Emissions Monitors	100
A-3	Performance Test Summary Data: RDF Feed Organics/Metals	101
A-4	Performance Test Summary Data: Ash Organic/ Metals	102

A-5	Performance Test Summary Data: Flue Gas Organics	108
A-6	Performance Test Summary Data: Flue Gas Metals	110

Summary

The environmental characterization of refuse-derived fuel (RDF) semi-suspension burning technology was undertaken jointly by Environment Canada and the U.S. Environmental Protection Agency (U.S. EPA) as part of ongoing programs of both agencies that assess municipal solid waste combustion technologies. The main objective of this program is to define optimum design and operating conditions in order to minimize emissions of concern. The facility tested is located in Hartford, Connecticut and represents a "state-of-the-art" technology, including a spray dryer/fabric filter air pollution control (APC) system for each unit.

The selected RDF combustion system was tested extensively in 1989 over a two-month period. Based on 28 characterization tests, a series of 13 performance tests (PT) was successfully completed. The 13 PT runs provide results at 4 different steam production rates, for a variety of combustion conditions deliberately set to range from good to very poor. The PT runs were grouped into 7 discrete test conditions for the combustion system and 9 test conditions for the APC system. Operating conditions for the APC system included 3 different flue gas temperatures and a range of acid gas removal efficiencies deliberately varied from low to high.

All incoming wastes and each ash residue stream were weighed, sampled, and analyzed. Key incinerator and APC system operating variables, such as refuse feed rate, temperatures, undergrate/overfire air distribution, and other process parameters, were monitored by an extensive computer network system on a "real time" basis. A wide range of analyses was carried out on gas emissions and all the ash discharges, including analyses for polychlorinated dibenzo-p-dioxins (PCDDs), polychlorinated dibenzofurans (PCDFs), polychlorinated biphenyls (PCBs), chlorophenols (CPs), chlorobenzenes (CBs), polycyclic aromatic hydrocarbons (PAHs), over 30 heavy metals, and acid gases.

The following are some of the key conclusions of the test program.

- Very low concentrations were observed of trace organics, heavy metals, and acid gases in stack emissions, under all tested operating conditions. For example, total PCDD/PCDF emissions were less than 1.5 ng/Sm³ in all tests.*

- *High removal efficiencies were attained by the APC system for trace organics in the flue gas during all tests. For example, PCDD and PCDF removal efficiencies exceeded 99%.*
- *Removal efficiencies by the APC system typically exceeded 98% for all metals in the flue gas, except mercury, for which the removal efficiencies ranged from 96 to 99%.*
- *RDF spreader stoker combustors can be operated with low carbon monoxide (CO) concentrations under steady state conditions. Average CO concentrations below 100 ppm were attained in a number of the 5-to-6 hour tests completed.*
- *Based on an input/output comparison, the estimated average net destruction efficiencies for trace organic compounds were 96% for good combustion conditions and 90% for poor combustion conditions.*
- *Concentrations of PCDD/PCDF in the bottom ash and grate siftings were at or below the detection limit. Over 99% of the total PCDD/PCDF associated with the residues was measured in the fabric filter ash.*
- *Trace organic contaminants in the ashes, including PCDD, PCDF, CB, and PAH, were not soluble in water.*
- *Only very small amounts (typically less than 10%) of most trace metals present in the ashes were soluble in water.*
- *Results from different leach tests indicate that a significant reduction in metal mobility was achieved through both physical encapsulation and chemical fixation for fabric filter ash that was solidified using cement and waste pozzolanic materials.*
- *Significant multi-variate correlations were found between a number of trace organics (e.g., dioxins) at the furnace exit (i.e., before APC system) and operating variables, such as combustion air distribution, that are good indicators of combustion conditions. These variables were identified as potential parameters that could be used to control incinerator operating conditions to ensure minimal trace organics in the flue gas entering the APC system.*
- *Significant multi-variate correlations were identified between trace organic emissions from the furnace and easily monitored*

variables, such as carbon monoxide, total hydrocarbons, nitrogen oxides, flue gas moisture, and furnace temperature. These variables could be used as early warning signals of high trace organic emissions to the APC system.

- *The removal of acid gases and trace organic compounds by the APC system correlated best with increased sorbent-to-acid-gas ratio (stoichiometric ratio).*

Acknowledgements

Program direction was provided by David J. Hay, Abe Finkelstein, and Raymond Klicius of Environment Canada; by Theodore G. Brna and James D. Kilgroe of the U.S. Environmental Protection Agency (U.S. EPA); and by Edward Peduto of Alliance Technologies Corporation. We would like to thank everyone involved in the Mid-Connecticut refuse-derived fuel incinerator emissions testing program.

The program was co-funded by Environment Canada, Energy Mines and Resources Canada, and the U.S. EPA; and was conducted by Alliance Technologies Corporation. In addition, the California Air Resources Board funded the particle sizing and hexavalent chromium portions of the program, and contributed to other ash and gas sample analyses. Special thanks is extended to Mr. G.A. Gross from the Connecticut Resources Recovery Authority, Messrs. R.M. Hartman and G. Boley from Combustion Engineering (now ABB Resource Recovery Systems), and the plant operators for their cooperation and assistance.

In addition, more than 40 engineers, chemists, and technicians were involved on-site as well as dozens of others who provided laboratory support. Without their efforts and dedication, this test program would not have been a success.

While it would be impossible to mention all the individual program participants, special acknowledgement is made to the following organizations.

Main Contractor: Alliance Technologies Corporation

*Subcontractors: MacLaren Plansearch, a division of Lavalin
IMET, Inc.
CH2M HILL, Ltd.*

Government Agencies: Environment Canada
- Urban Activities Division
- Pollution Measurement Division
- Analytical Services Division
- Wastewater Technology Centre

U.S. Environmental Protection Agency
- AEERL

Ontario Ministry of the Environment

California Air Resources Board

Connecticut Department of Environmental Protection

Others:

Entropy Environmentalists, Inc.

D. Stevens Consulting Services

Energy and Environmental Research Corporation

Radian Corporation

Concord Scientific

University of Connecticut

Stanley Industrial Consultants Ltd.

Section 1

Introduction

1.1 Program Background

The incineration of municipal solid waste (MSW) offers not only a practical option for waste management but also a means of energy recovery. However, emissions from MSW incinerators and their environmental impacts have become issues of major concern in both the United States and Canada. The release of previously undetected metals and trace organics from poorly designed, controlled, and/or operated incinerators has caused negative public perception of MSW incineration.

Recognizing these concerns, regulatory agencies in Canada and the United States have undertaken comprehensive programs to gather and analyze data on MSW combustion.

As part of its evaluation of incinerator technology, Environment Canada initiated the National Incinerator Testing and Evaluation Program (NITEP). This program provides data for determining how incinerator design, combustion characteristics, methods of operation, and air pollution control systems affect the release of pollutants to the environment. Using criteria established in Phase 1 of NITEP, Environment Canada has examined incinerators representing the following three generic designs:

- two-stage combustion (modular technology), Parkdale, P.E.I. (Summary Report, 1985);
- waterwall moving grate mass-burning system, Quebec City, Quebec, (Summary Report, 1988); and
- refuse-derived fuel (RDF) semi-suspension burning system, Hartford, Connecticut (Summary Report, 1993).

These designs, as well as fluidized bed combustion and others, encompass projected future trends in incineration technology.

The U.S. EPA, through the Municipal Waste Combustion Program, has conducted performance tests on a number of incinerators (e.g., in Marion County, Oregon; Biddeford, Maine; Millbury, Massachusetts; Hartford, Connecticut; and Montgomery County, Ohio). This information has been used in the revision of air quality regulations for new sources and guidelines for existing sources. It has also been applied to the identification of the mechanisms by which pollutants, such as trace organics and heavy metals, are produced in, destroyed in, or removed from waste combustion systems and flue gas cleaning systems.

This summary report outlines an extensive test program carried out at the Mid-Connecticut Hartford Project in Hartford, Connecticut, under the joint direction of Environment Canada and the U.S. EPA. Alliance Technologies Corporation of Lowell, Maine conducted the tests under contract.

1.2 Program Objectives

The following were the overall objectives of this joint Environment Canada/U.S. EPA project.

Environment Canada -

- Define optimal design and operating characteristics.
- Relate operating conditions to emissions.
- Identify best practical control options.
- Investigate design and operating guidelines for future applications.
- Incorporate accepted dioxin/furan sampling and analysis protocols.
- Investigate dioxin surrogates.
- Facilitate construction of new incinerators.

U.S. EPA -

- Establish baseline emissions from a RDF-fired combustion source.
- Compare performance and emissions from the various types of municipal waste combustion systems.
- Evaluate design and operating parameters.
- Evaluate add-on pollution control devices.
- Establish design and operating criteria for combustion and flue gas cleaning systems.

Pollutants considered in this program included tetra- through octa- chlorinated dibenzo-*p*-dioxins and chlorinated dibenzofurans (PCDDs/PCDFs), chlorobenzenes (CBs), chlorophenols (CPs),

polychlorinated biphenyls (PCBs), polycyclic aromatic hydrocarbons (PAHs), metals, acid gases, combustion gases, and particulate matter. Although concerns about trace organics have focused on PCDDs/PCDFs, these other pollutants have been examined for their prevalence in emissions from MSW incinerators to ensure that strategies for controlling trace organics will control all major organic pollutants.

1.3 Refuse-derived Fuel (RDF) Test Site

This project was conducted on Unit No.11 at the Mid-Connecticut Resources Recovery facility in Hartford, Connecticut. This facility is owned by the Connecticut Resources Recovery Authority (CRRA). The RDF unit was designed and is operated by ABB Resource Recovery Systems (ABB/RRS). The unit is designed to handle a full steam load of 105 000 kg/h (231 000 lb/hour). Emissions are controlled with a lime spray dryer absorber followed by a fabric filter system. The facility is described in detail in Section 2. Unit No. 11 was specifically selected for use in this project because of its availability and the presence of additional process monitoring equipment.

1.4 Project Reports

This Summary Report describes the most significant results of the Mid-Connecticut RDF incinerator test program. More detailed information on the data and conclusions generated by the program is presented in the following volumes (Environment Canada, 1991):

Volume II - Test Program and Results, provides an in-depth discussion of the results and

rationale for the various tests conducted at the site. Detailed data analyses and the conclusions drawn from these tests are also provided.

Volume III - Sampling and Analytical Procedures, provides the details of the sampling and analytical methodologies used for the testing program. This volume discusses any modifications made to standard reference procedures to overcome any inherent limitations or difficulties encountered during the program.

Volume IV - Project Data, contains all detailed data as well as summary sheets and graphical representations. This volume provides further backup to the data and conclusions contained in Volume II. In addition, the data are organized into different formats to facilitate comparison and interpretation of results. Volume IV contains three books presenting: reduced data (Book 1), raw data (Book 2), and single and multiple regression analyses (Book 3).

Volume V - Ash/Residue Characterization and Solidification, provides the results of the leachate program for both organic and inorganic contaminants conducted by Environment Canada's Wastewater Technology Centre.

Volume VI - External QA/QC Evaluation Report, contains the details of the independent external quality assurance/quality control (QA/QC) program.

1.5 Structure of this Report

The RDF facility is described in Section 2. A description of the program, including approach to testing, sampling locations, the characterization test series, and the selection of process conditions for performance testing, is provided in Section 3. Sampling and analytical protocols and quality assurance/quality control procedures are reviewed in Section 4.

The results of the performance tests for the combustion system are outlined in Section 5, while the results of the performance tests for the air pollution control system are outlined in Section 6. In Section 7, key findings of ash characterization tests are provided. Conclusions and recommendations are summarized in Sections 8 and 9.

Section 2

Description of Facility

2.1 Site Overview

The facility selected for the joint Environment Canada/U.S. EPA test program was the Mid-Connecticut Resources Recovery Facility, owned by the Connecticut Resources Recovery Authority (CRRA). This facility was designed and constructed by ABB/RRS at Connecticut Light and Power's South Meadows generating station on the south side of the Connecticut River in Hartford, Connecticut. The RDF processing facilities were built on land adjacent to the existing generating station.

The Mid-Connecticut facility consists of a waste processing facility, a steam generation power block, and an electrical generation system.

The waste processing facility, operated by the Metropolitan District Commission (MDC), processes raw municipal waste into RDF, which is then provided to the steam generation power block. The power block facility is operated by ABB/RRS and includes three new ABB Combustion Engineering (CE) boilers, ash handling systems, and pollution control systems. The electricity generating portion of the facility is owned by Connecticut Light and Power. The facility began operation in 1987.

2.2 Process Description

The facility is designed to process 1814 tonnes (2000 tons) per day of MSW received from 44 communities in the greater Hartford area. As shown in Figure 1, the facility design includes fuel preparation,

steam generation, and combustion gas cleanup. The RDF preparation and storage areas are housed in a separate building located approximately 360 m south of the boiler house. The three RDF-fired, spreader-stoker boilers are located inside the boiler house. Adjacent to the boiler house are the combustion air preheaters, forced draft fans, spray dryer absorbers, fabric filter modules, induced draft fans, and the exhaust gas outlet stack (Figure 2).

2.2.1 Refuse-derived Fuel Preparation/Handling System

As shown in Figure 1, conversion of MSW into RDF consists of the following steps:

- reception of the raw MSW at the refuse truck unloading area;
- manual inspection and picking process to remove large bulky items, smaller noncombustible items, and potentially explosive items, such as propane tanks;
- flailing and primary shredding for cutting open bags and reducing size of waste;
- magnetic separation for removing ferrous materials; and
- trommel screening for dirt, glass, and fines removal, and secondary shredding to obtain the proper RDF size.

The processed RDF is then conveyed to the storage area where it awaits transfer to the boiler house for burning.

- | | |
|--------------------------------------|---|
| 1. Refuse Truck Unloading Area | 10. Refuse Derived Fuel (RDF) Conveyors |
| 2. Refuse Shredders | 11. Barge Delivery of Coal |
| 3. Ferrous Metal Magnets | 12. Coal Storage |
| 4. Primary Separation Units | 13. Coal Reclaim Conveyors |
| 5. Secondary Shredders | 14. RDF & Coal Conveyors to Boilers |
| 6. Metal Outloading | 15. C-E VU-40 RDF and/or Coal Fired Boilers |
| 7. Residue Outloading | 16. High Efficiency Emission Control Equipment (Dry Scrubber/Baghouses) |
| 8. Secondary Separation | 17. Stack |
| 9. Refuse Derived Fuel (RDF) Storage | 18. Turbine Generators |
| | 19. Switch Yard |




Figure 1 Mid-Connecticut Facility Design




Figure 2 Refuse-derived Fuel Incinerator Schematic

The processing facility has two parallel processing lines to provide high throughput of RDF as well as a backup system during scheduled maintenance and downtime. The processing capacity of one line is sufficient to maintain load on two of the three boilers. Two parallel conveyors leave the RDF storage area, pass through the RDF/coal midstation, and then enter the upper level of the boiler house. Processed RDF may be fed from either conveyor to any of the three feed bins above the boilers. Screw auger feeders are located within the bins to break up clumps of RDF and meter the downward flow of the RDF to the boiler.

2.2.2 Steam Generating System

The Mid-Connecticut facility operates three identical RDF spreader-stoker steam generators, referred to as Units 11, 12, and 13. Unit 11 was selected for this test

program. Each steam generator is designed for a maximum continuous rating (MCR) of 29.1 kg/s (231 000 lb/h) at 6.1 MPa-gauge (880 psig) and 441°C (825°F) when firing RDF.

The fuel-burning system includes ABB's Refuse Combustor stoker which has been specifically designed for resource recovery facilities burning RDF alone, or in combination with coal. Four pneumatic distributors spread the RDF across the width of the combustion grate. The grate includes a self-cleaning key design to remove fused/clinkered ash during grate operation. Ten undergrate air zones (two rows of five each, parallel to the direction of grate travel) allow the operator to optimize the combustion process on the grate and to respond quickly to "piling" situations by

manual adjustment of undergrate air (UGA) zone dampers.

Coal is a secondary fuel and is used as required to maintain steam demand from the boilers. Coal was not fired in Unit 11 during the testing program.

Each boiler is equipped with a forced draft centrifugal fan to supply the required combustion air. There are separate overfire air (OFA) systems for RDF and coal. The OFA system for RDF is equipped with four tangential overfire air windbox assemblies located in the furnace corners. At each corner windbox assembly, there are three OFA levels that are separately controlled. Preheated combustion air enters the furnace tangentially to form a vortex. The resulting internal recirculation and turbulence in the bulk gas provide longer furnace residence times for burning low density RDF particles entrained by the gas stream. The normal OFA/UGA distribution percentage is 30/70, but the OFA capacity can be raised to 50%.

The flue gases generated in the combustion chamber flow through a superheater, which is a vertical two-stage design with parallel steam and gas flow. Upon leaving the superheater, the combustion gases pass through a 28-tube deep steam generating bank which includes a vertical outlet duct to the economizer. The economizer consists of two horizontal banks of in-line tubes. Subsequently, the flue gas goes to a combustion air preheater.

Each steam generator is equipped with one 3-pass horizontal tubular air preheater. Flue gas flows over the tubes and the combustion air flows through the tubes. A steam coil air preheater maintains the average cold end temperature high enough to prevent sulphuric acid corrosion of the air heater. After the air preheater, the flue gas flows

through the air pollution control system and then, via an induced draft (ID) fan, to the stack.

Each boiler is equipped with soot blowers located between superheater banks, at the boiler bank inlet, in the boiler bank centre cavity, in the economizer, and in the air preheater. Ash deposits are released during the soot-blowing cycles and are collected in hoppers under the economizer and air heater.

Ash is removed from each boiler in two streams. The first stream contains the bottom ash, economizer ash, and stoker siftings. A submerged scraper conveyor is used for bottom ash collection. The second stream contains the baghouse and air heater ash. Mechanical flight conveyors are used to transport the ash streams. The two streams are combined after the baghouse ash and air heater ash have been conditioned in pug mills. The combined ash stream is then transported to storage for eventual disposal.

2.2.3 Air Pollution Control System

Each boiler has a dedicated two-stage flue gas cleaning system composed of a spray dryer vessel for the absorption of acid gases, followed by a reverse-air-cleaned fabric filter for the removal of particulate (fly ash, reaction products, and unused calcium hydroxide $[\text{Ca}(\text{OH})_2]$). The cleaned gas stream passes through the system's ID fan and enters the outlet breeching for discharge through the common outlet stack. Major subsystems to the above individual gas cleaning systems include a common lime receiving/storage and lime slurry preparation/distribution system.

The spray dryer absorbs acid gases from the boiler flue gas and produces a dry product for disposal. This is accomplished by introducing a very fine spray of absorbent slurry into the flue gas stream and providing

intimate contact and sufficient time for the sorption and drying process to occur. The spray dryer absorber design consists of the following major components: inlet flue gas distributor, rotary atomizer spray machine, spray dryer absorber vessel, and flue gas outlet.

Concentrated slaked lime slurry is delivered on process demand to the individual additive feed tanks. There, the slurry is further diluted with water to the correct concentration required of the process parameters (i.e., to achieve the required spray down temperature and acid gas removal requirements). The slurry is then pumped from these individual additive feed tanks to their corresponding atomizers to be finely atomized within the spray dryer absorber vessel. Note that pond water is the primary dilution water for slaked lime when it is available. River water is used when pond water is not available.

The flue gas enters the top of the spray dryer absorber vessel through the distributor which consists of a primary and secondary swirl chamber. The primary and secondary swirl chambers distribute the flue gas through annular openings surrounding the atomizer wheel. The secondary gas passage can be set from 100% capacity to near shut-off, which provides operational flexibility for boiler conditions from 100% maximum continuous rating to 40%, without sacrificing performance. The spray dryer absorber vessel is sized to provide the contact between the flue gas and sorbent necessary to complete the acid gas sorption reactions and ensure product dryness.

Adiabatically cooled and treated flue gas flows from the spray dryer absorber vessel to the outlet duct. All of the dried product and ash are entrained in the flue gas as it travels from the vessel to the fabric filter particulate removal. This bottom discharge design eliminates the requirements for absorber solids removal equipment and avoids plugging by solids.

Each fabric filter consists of 12 modular reverse air compartments arranged in two rows of six compartments. The inlet/outlet manifolds are located between the two rows. Each compartment contains 168 woven glass fiber filter bags arranged in 12 rows of 14 bags. The modular compartments have a three-bag reach from the walkway area. The bags are automatically cleaned using either a differential pressure signal or a timed signal to initiate the cleaning cycle. The compartments are cleaned sequentially, one at a time, with the other compartments remaining on-line. A bag-collapsing action, plus reverse air flow, dislodges the dust from the inside of the bags permitting it to fall into the hoppers below.

Each fabric filter system is equipped with a bypass to route process gas directly to the stack without passing through the fabric filter. This is necessary in startup and emergency conditions where high temperatures, low temperatures, or high differential pressure may be encountered. The bypass system is activated either automatically or manually.

Section 3

Program Description

3.1 Approach to Testing

The test program conducted at the Mid-Connecticut Resource Recovery Facility was designed to address the Environment Canada and U.S. EPA objectives described in Subsection 1.2. The major objectives are to establish baseline emissions from a RDF-fired combustion source; to establish correlations between process operation and emission characteristics; and to define optimal design and operating characteristics.

The testing was divided into two phases. The characterization tests (CT) provided process data that were used to define the key operating variables to be investigated in detail during the subsequent performance tests (PT). This first phase also provided the opportunity to verify test procedures to be used during the performance test phase. The PT phase was designed to provide data to be used to establish correlations between process operation and emission characteristics.

3.2 Site Selection

The following criteria were used by Environment Canada and the U.S. EPA to select the Mid-Connecticut facility.

- Refuse-derived fuel is to be used as the sole fuel during the test program.
- The facility is to be representative of modern design, including RDF preparation and feed systems, boiler and

combustion systems, and air pollution control (APC) devices.

- The facility must have operational flexibility incorporating technical capabilities, management cooperation, permit considerations, and site logistics regarding installation of monitoring equipment.
- There must be access to sampling locations throughout the steam generation and APC system.

Site preparation did not require any major modifications to the feed system, Unit 11 combustion system, or the APC system for this program. However, many modifications were required at the sampling points to provide access to the process streams. These are discussed in Subsection 3.3.

3.3 Selection and Preparation of Sampling Locations

The feed and ash streams were measured or sampled at ten locations, eight of which required modifications. The flue gas stream had five sampling locations. These are shown in Figure 3. The various locations and modifications used are briefly described in the following subsections.

3.3.1 Feed Streams

At the RDF preparation area, each load of RDF was weighed as it was placed onto the dedicated conveyor by the front-end loader (one conveyor was dedicated solely to Unit 11 during each test). The data were




Figure 3 Process Schematic Showing Sampling Locations

used in determining the mass feed rate and energy input to the system.

In order to characterize the quality of the feed to the system, the RDF was sampled at the RDF midstation, located approximately halfway between the preparation facility and the boiler house. The conveyor housing was modified with a hinged plywood door to provide access. A 1.3 m³ box was installed adjacent to the conveyor for receiving the composite RDF samples.

The makeup water for the lime slurry was supplied from the coal pond adjacent to the coal pile. Samples were taken from a hose connected to the pond water supply line just before the entrance to the final slurry mixing tank.

The slurry sampling valve was located in the penthouse of the spray dryer of Unit 11. This location was selected because of its accessibility, low slurry pressures, and its proximity to the atomizer head itself. The latter factor was especially important due to slight dilution of the slurry upstream of this location with a water bleed line used for cooling purposes. Consequently, the slurry sampled was “as atomized”. The only modification required was the installation of a reducing coupling to which a flexible Teflon sampling line was attached.

3.3.2 Ash Streams

Total collection was used to quantify the ash production rate of each ash stream for grate sittings, economizer ash, and air heater ash. Each location was selected and modified accordingly to allow for the collection of a separate, discrete ash stream over the course

of each test run. Under normal operation, the economizer ash and grate siftings are combined within a drag chain conveyor beneath the boiler before entering the quench tank. A large valve was installed in the economizer ash down-pipe several floors above the bottom level. A temporary stainless steel down-pipe was attached to the valve and the other end of this down-pipe was on the bottom floor, facilitating collection of the ash in empty steel drums.

Since the economizer ash was collected separately, only the grate siftings (GS) were serviced by the drag chain conveyor. To collect the entire GS stream before quenching, the bottom of the inclined drag chain conveyor was modified just before entering the quench tank by adding a collection hopper and downtube. A stainless steel hose connected the downtube to the collection drum.

The air heater hopper was unintentionally plugged during the tests and could never be cleared out sufficiently to collect any ash sample.

The analytical characterization of the bottom ash samples had to be done on a dry sample before quenching. This was accomplished by sampling the ash from the view ports at the front of the boiler from the ash bed itself. No modifications were required at this sampling point.

Because the bottom ash dropped directly off the front of the travelling grate into the boiler hoppers and then into the quench tank, the production rate of unquenched ash could not be measured directly. Therefore, the quenched bottom ash was diverted from the common collector conveyor shared by all three boiler units into a tare-weighted hopper. Samples were collected from each hopper and analyzed for moisture. The net dry

weight of the bottom ash was determined by correcting for moisture.

A dedicated conveyor collected the fabric filter ash as it came off the two parallel West-East conveyors underneath the two banks of ash hoppers. The inclined pugmill conveyor was purposely shut off to allow the ash to accumulate at its base while the North-South conveyor was kept in service. As the ash was deposited, it was collected by a 15-m³ vacuum truck and weighed to yield the net ash production rate.

3.3.3 *Flue Gas Streams*

To verify the flow rate of preheated air to the boiler, two ports were installed in the twin horizontal ducts that provide preheated combustion air to the OFA nozzles, undergrate air, and other combustion air systems.

The **air preheater inlet (API)** combustion gas was sampled in the inclined duct leading from the boiler to the combustion air preheater. Sampling point modifications consisted of the installation of five ports on the preheater inlet duct and the erection of a sampling platform and shelter. The installed ports were oriented on a vertical axis and were not perpendicular to the gas flow. This was a deviation from the standard method for siting isokinetic sampling ports, but was selected to facilitate sampling at this location.

The **spray dryer inlet (SDI)** was sampled to obtain measurement of a variety of organic and inorganic compounds before they came into contact with any control device. As this was an existing sampling location, only two modifications were required. Two ports were installed to allow the installation of the continuous emission monitoring (CEM) equipment. In addition, the platform was enlarged and safety nets were added.

The **spray dryer outlet (SDO)** was an intermediate sample point to provide scrubber outlet measurements of several gaseous pollutants, including acid gas concentrations in the APC system. This point was an existing sampling location with ports suitable for CEM equipment. The only modification required was enlarging the platform.

The **fabric filter outlet (FFO)** provided for measurement of a large variety of organic and inorganic compounds before their discharge from the stack. Removal efficiency data across the APC were determined for particulate matter, organic compounds, trace metals, and acid gases.

The FFO is a vertical rectangular duct with five ports arranged horizontally across the face of the duct. However, a diagonal support beam prevented access to the centre port for isokinetic sampling. Consequently, the trace organics, metals, and hexavalent chromium trains were traversed through the remaining four ports. The single point particle sizing train was run in the centre port. The volatile organic sampling train (VOST) was run in a centrally located port at the back of the duct, on a slightly higher plane upstream of the isokinetic trains. Continuous emissions monitoring probes were installed in adjacent ports in the back of the duct.

All process data, continuous gas data, pressures, and temperatures were monitored throughout the tests via a data acquisition system. Relevant process data were gathered, recorded, and displayed on a real-time basis. The system is further described in Section 4.

3.4 Characterization Test Series

3.4.1 Objectives

The major objectives of the characterization tests (CT) were to familiarize test crews with the operation of the RDF incinerator; to identify furnace/boiler/APC operating conditions that would be most appropriate for the performance tests; and to verify sampling and analytical procedures to be used in the performance tests.

3.4.2 Overview

The CT phase examined incinerator and APC system performance under steady state conditions as operating parameters were changed one at a time. The set of 28 operating conditions encompassed both normal and potential upset conditions. The tests were conducted from January 11 to 25, 1989 and typically lasted one or two hours each.

The parameters that were monitored during the CT phase are summarized in Figure 4. Continuous emission monitoring at the inlet and outlet of the APC was the major analytical effort during the CT phase. Particulate testing, followed by loss on ignition (LOI) analysis, was conducted during half of the CT runs. During each test, relevant process data were monitored. In addition, familiarization runs involving a U.S. EPA-modified Method 5 train (U.S. EPA, 1988) for trace organics were conducted at the spray dryer inlet and the fabric filter outlet.

Ash, lime slurry, and RDF sampling were also conducted during the CT phase to identify potential complications in obtaining representative samples. These samples also provided a limited amount of analytical data and allowed verification of sample handling and preparation procedures. Perhaps the




Figure 4 Sampling Parameters for Characterization Test

most important aspect of the ash stream sampling during the CT phase was to verify expected rates of ash generation.

3.4.3 Process Conditions of Characterization Test Program

The characterization test program investigated the following key operating parameters for the combustion process: refuse fuel input rate (steam production rate); air injection quantity and distribution (excess air level and distribution); and combustion process temperature.

For the air pollution control system, the following key operating parameters were investigated: lime stoichiometry (lime pressure and flow rate), and gas temperature at the fabric filter outlet.

Five series of tests (Series A to E) that varied combustion parameters were completed, as shown in Figure 5. The major combustion test variables were boiler steam load, number of overfire air elevations, and rear wall air condition (on or off).

Four series of tests (Series K to N) that varied APC system parameters were also completed (as shown in Figure 6) and were integrated into the combustion test series. The APC test series examined the effect of stoichiometry at spray dryer outlet (SDO) temperatures of 105, 110, 140, and 177°C. The major APC test variables were SDO temperature and FFO SO₂ concentration (SO₂ removal is generally proportional to stoichiometry).

3.4.4 Summary of Characterization Test Results

Detailed results from the characterization tests are available in Volume II of the report series. Some relevant observations of results from the CT series are summarized here.

Stable Operation - In an effort to define stable operation, the variation in steam flow during each test period was evaluated and found to typically range from 2 to 8%. An almost linear relationship was found between excess oxygen and steam flow. This relationship indicated that the combustion air flows could not be changed as easily as the boiler load.

Low Load Conditions - The low load conditions presented an operational problem for the boiler. This mode of operation provided lower CO emissions during the characterization test (but not the performance tests), but was the worst operating mode in terms of energy utilization. Therefore, it would not be economically practical to operate these units at low load conditions as a normal practice.

Peak Load Conditions - Carbon monoxide levels increased during most of the peak load tests due largely to the lack of fuel burnout before discharge from the grate. These conditions provide enormous amounts of heat on the grate, but also provide improper combustion conditions caused by the bed depth on the grate and improper mixing in the combustion zone.

Optimum Combustion - Optimum combustion operation appears to correspond to a steam production rate between 95 000 and 107 000 kg/h (210 000 and 235 000 lb/h). The most effective means of introducing combustion air was by rear-wall overfire air (RW-OFA), as this seems to provide the total mixing required to promote good combustion and to minimize CO production. Tangential overfire air systems must also be used to mix the gases higher in the combustion chamber. Proper combustion air introduction and good combustion gas mixing corresponded with even fuel distribution and burning.




Figure 5 Characterization Test Operating Conditions for Combustion System Test Series




Figure 6 Characterization Test Operating Conditions for Air Pollution Control System Test Series

3.5 Performance Test Series

3.5.1 Objectives

To provide information on the environmental effects of RDF incinerator technology, the major objectives of the performance tests (PT) were: to establish correlations between the operating parameters of an RDF incineration system and the resultant emissions; to determine and investigate correlations between combustion parameters and flue gas compositions; and to investigate formation of PCDD/PCDF precursors.

To meet these program objectives, a series of performance tests were designed to characterize in detail the feed and effluent streams while monitoring the associated operating parameters. Fourteen separate test runs were conducted between February 13 and March 1, 1989.

3.5.2 Process Conditions of Performance Test Program

The targeted process conditions in the performance tests evolved from the results of the CT phase. Process parameters were chosen to provide test results at four different steam production rates, for a range of combustion conditions ranging from good to very poor. The quantity and distribution of combustion air to the furnace were also used in grouping the conditions. Operating conditions for the APC system included gas temperature in the spray dryer and SO₂ concentration after the fabric filter, which

served as a surrogate indicator of lime stoichiometric ratio.

The process conditions tested during the PT phase for the combustion system and for the APC system are shown in Figures 7 and 8.

Ideally, triplicate testing would have been conducted at each combination of operating parameters. Triplicate testing would increase the statistical reliability of the data gathered for each test condition. However, due to cost and time considerations, only 15 test runs were initially planned. The test program was further shaped by the decision that it was more important to obtain as much valid data as possible at a variety of conditions than to conduct three runs at five conditions.

Of the 14 test runs attempted, 13 were deemed to be valid. Problems with the fabric filter ash collection truck invalidated one test run. The 13 valid runs were divided into 7 discrete test conditions for the combustion system and 9 test conditions for the APC system. The APC system test conditions are actually a sub-set of the combustion system test conditions.

The performance test parameters sampled and monitored are summarized in Figure 9. Test results for the seven test conditions for the combustion system are described in detail in Section 5, while test results for the air pollution control system are presented in Section 6.




Figure 7 Performance Test Operating Conditions for Combustion System Test Series




Figure 8 Performance Test Operating Conditions for Air Pollution Control System Test Series




Figure 9 Performance Test Sampling Parameters

Section 4

Sampling and Analytical Protocols

4.1 Overview

The characterization of process conditions and emissions of the RDF-fired incinerator required a wide variety of measurements, using a variety of sampling and analytical protocols. These measurements were made at a number of diverse locations throughout the facility as shown in Figure 3 and as discussed in Section 3.

All sampling and analytical methodologies were based on recognized protocols. Modifications to existing methods were sometimes necessary to overcome certain sampling or analytical difficulties or to resolve differences in procedures normally used by Environment Canada and the U.S. EPA.

The sampling and analytical procedures used for process stream measurements, combustion gas sampling, and process monitoring are described in this section. Additional information may be found in the quality assurance project plan (QAPP) prepared for this program described in Volume VI and in the sampling/analytical methods presented in Volume III (Environment Canada, 1991).

4.2 Process Stream Sampling

The process streams were sampled at eight locations. Three of these were feed streams to the system (RDF feed to the boiler, and pond water and lime slurry feed to the spray dryer). The remaining five streams were ash discharges from various key locations within the combustion/pollution control system.

The **RDF feed rate** was determined at the RDF preparation area, by weighing each load of RDF as the front-end loader placed it onto the dedicated conveyor. A Tuffer weighing device was attached to the hydraulic lift system of the loader to provide this information. The times at which the loads of RDF were placed were also recorded.

RDF samples were taken at the point where RDF dropped off the conveyor into the boiler feed bin. A 0.06 m³ (2 ft³) sample was scooped from the stream every 30 minutes. To account for residence times in the feed bin, sampling was begun 15 minutes before a test run started and ended approximately 15 minutes before the run ended.

The collected RDF was emptied into the mixing box and spread out over the surface to provide fairly uniform layers. After coning and quartering the composite sample three or four times, the remainder was divided equally into three portions which were then double bagged, sealed, and placed in plastic pails with sealable lids.

The **pond water** that was used as makeup water in the slurry mixing tank was sampled three times during each test run to further characterize the lime slurry feed. The samples were collected from a flexible hose inside the slurry-mixing room. The valve was opened and the hose purged before collecting each grab sample. The samples were combined in a single 500-mL amber glass jar.

The **lime slurry** was sampled three times during each eight-hour test period from a valve in the slurry supply line leading to the atomizer head of the spray dryer. A 150-mL slurry sample was drawn into the impinger by a meter box pump.

Grate siftings and economizer ash were collected in their entirety in tared drums through flexible downtubes. To determine ash production rates, the filling time and weight of each drum were recorded. After collection and weighing, a core sample of the ash was taken from the drum.

Dry bottom ash samples were collected at 30-minute intervals during each test run from the grate through the four rectangular viewing ports located at bed level in the front of the boiler. Due to the high temperature, a modified stainless steel pan-type scoop with a long handle and hinged lid was pushed into the ash bed through the viewing ports. The composite container held dry ice to cool the sample and to quench any continuing combustion.

Quenched bottom ash samples were collected from a dumpster placed beneath the drop-off point of the dedicated bottom ash conveyor, using a trowel or scoop, and then placed into a five-gallon polyethylene bucket. When full, or at the end of the test run, the dumpster was weighed to determine the total production rate of wet bottom ash. The moisture analysis yielded the weight of water from which the dry bottom ash production rate could be calculated.

Fabric filter ash (FFA) was collected at the base of the inclined conveyor leading from the drag chain conveyor to the pugmill. This inclined conveyor was shut off, allowing the FFA to settle and collect at its base. A vacuum truck continuously removed the FFA out of this area. At 30-minute intervals,

the vacuum truck was shut down to allow enough FFA to accumulate to provide grab samples. When full or at the end of each run, the tared truck was weighed to obtain the ash production rate.

4.3 *Flue Gas Sampling*

Flue gas sampling and monitoring were conducted at the following four locations downstream of the combustion system: the air preheater inlet (API); the spray dryer inlet (SDI); the spray dryer outlet (SDO); and the fabric filter outlet (FFO).

Parameters examined included bulk gas composition, particulate matter, particle sizing, hydrogen chloride, trace organics, trace metals, mercury, and hexavalent chromium.

Continuous Emission Monitoring was completed at the SDI, SDO, and FFO locations using the instrumentation and parameters listed in Table 1. The signals from the instruments were tied into the data acquisition system to provide real-time output.

Flue gas molecular weight was determined by Integrated Orsat, U.S. EPA Method 3 (U.S. EPA, 1988). Integrated bag samples of gas were collected over the course of each test run at the SDI and FFO locations. The Orsat probe was attached to the particulate sampling probe. A lung-sampling system collected the integrated stack gas sample into a Tedlar bag at a rate of 0.1 L/min.

Method 5 Train (M5) was modified for the collection of particulate matter and metals (including mercury). The sample train was operated as a Method 5 particulate train (U.S. EPA, 1988) with modification to the impinger configuration to enhance the

Table 1 Continuous Emissions Monitoring Locations/Parameters/Instruments

CEM Location	Responsibility	Parameter	Instrument	Principle
Spray Dryer Inlet (SDI)	Environment Canada	O ₂	Beckman 755 Teledyne 320-P-4 Teledyne 3208B-RC	Paramagnetic Electrochemical Electrochemical
		CO ₂	Beckman 865 Anarad AR-421	NDIR NDIR
		CO	Bendix 8501-5BA Bendix 8501-5CA	NDIR NDIR
		SO ₂	Western Research 721A Western Research 721A	NDUV NDUV
		NO _x	TECO 10AR TECO 10AR	Chemiluminescence Chemiluminescence
		HCl	TECO15 TGM 555	GFC Wet Chemical
		THC	Ratfische RS55 Ratfische RS55	Hot FID Hot FID
		Moisture	Beckman 865/TECO 900 dilution system	NDIR
Spray Dryer Outlet (SDO)	IMET	CO ₂	Infrared IR702	NDIR
		SO ₂	Western Research 721A	NDUV
		HCl	TECO 15	GFC
Fabric Filter Outlet (FFO)	IMET	O ₂	Taylor OA269	Polarographic
		CO ₂	Infrared IR702	NDIR
		SO ₂	Western Research 721A	NDUV
		HCl	Bodensewerk	GFC
		THC	JUM VE7	Hot FID
		CO	Infrared IR702	NDIR

NDIR - nondispersive infrared
NDUV - nondispersive ultraviolet
GFC - gas filter correlation
FID - flame ionization detection

collection of the metals of interest (example A in Figure 10). Additional preparation for this train and associated sample containers included precleaning for metals collection. Particulate collected on the filter and in the probe was weighed to determine particulate loading and then analyzed for the metals of interest.

Particle size determination was conducted at the FFO using Andersen Mark III impactors. Three runs of different durations were conducted during the test program. Nozzle sizes for the first two runs were selected to maintain a flow rate through the impactor of 0.44 m³/h. The nozzle size was increased to maintain an impactor flow rate of 1.3 m³/h for the third test, since the very low grain loading at the FFO required a long sampling time to collect 50 mg of particulate. Gas flow was monitored and recorded by observing the pressure drop across a calibrated orifice. The total dry gas volume sampled was determined using a calibrated dry gas meter.

Flue gas samples for determining **hexavalent chromium** concentrations were collected for three runs in accordance with the protocol in the State of California Air Resources Board (CARB) Method 425 (CARB, 1982). This procedure calls for the collection of particulate matter using U.S. EPA Method 5, as shown in example C in Figure 10, then dividing the sample into equal portions to determine total chromium and hexavalent chromium.

Modified Method 5 (MM5) sampling trains were used for the collection of **polychlorinated dibenzo-*p*-dioxins, polychlorinated dibenzofurans (PCDD/PCDF)**, and for other trace organics. The MM5 sampling train is shown in example B of Figure 10.

During the performance tests, 13 MM5 runs were made at the SDI location, 14 runs at the FFO location, and 4 runs at the air preheater inlet. Each run lasted approximately 4 hours to ensure the collection of at least 3 m³ (105 dscf) of sample gas. The sampling start/stop times for each location were coordinated as closely as possible to ensure near simultaneous sampling.

During recovery of the MM5 trains, an aliquot of approximately 30 mL was removed from the condensate impinger for subsequent HCl analysis. It served as backup to the continuous HCl monitors.

The flue gas was sampled for **volatile organic compounds (VOC)** during each of the 14 performance tests. During each test, three VOC runs were conducted at the FFO. The volatile organic sampling train (VOST) was operated in accordance with EPA Method 0030 (U.S. EPA, 1988). The train consisted of a glass-lined probe with a glass wool plug to remove particulate matter, followed by an assembly of condensers and organic resin traps as shown in Figure 11.

4.4 Process Parameter Measurements

During each test, all facility operating parameters were continuously monitored in the control room by appropriate program personnel, using the project data acquisition system, which recorded the process and continuous emissions data for the parameters listed in Table 2.

These data assisted in identifying whether the process was operating as planned or experiencing changes or upset conditions. Carbon monoxide (CO) and oxygen (O₂) levels represented the most frequently used control parameters. Changes in these values initiated a review of the incinerator's




Figure 10 Schematic of Sampling Trains




Figure 11 Volatile Organic Sampling Train Schematic

Table 2 Major Process and Emission Parameters Monitored

Process Parameters	Continuous Emission Data
<ul style="list-style-type: none"> • steam and air flows • steam pressure and gas pressure drops • combustion chamber temperatures • boiler air supply and air distribution • flue gas composition • flue gas temperatures (SDI, SDO, and FFO) • outlet temperature of the spray dryer • lime slurry feed rate • acid gas removal 	<ul style="list-style-type: none"> • carbon monoxide • oxygen • carbon dioxide • sulphur dioxide • hydrogen chloride • total hydrocarbons • nitrogen oxides

primary process control parameters as well as a visual inspection of the combustion chamber.

Visual inspections of the furnace burning zone were frequently carried out by the combustion expert to determine whether the burn was occurring evenly on the grates. If unusual conditions were noted, the control system was adjusted by the operators to avoid burning conditions that were outside the selected target. The furnace burning zone was generally observed every half hour with special aspects and unusual conditions noted in the log book. During periods of abnormal operation, observations were made as frequently as every 5 to 10 minutes.

Visually inspecting the ash discharged from the incinerator to the quench tank and on the drag chain conveyor from the quench tank was part of the furnace observation routine. This observation was done primarily to identify if and when ash quality was deteriorating.

4.5 Data Acquisition System (DAS)

The complexity of this project required a sophisticated and well planned data acquisition system (DAS) that integrates data gathering, reduction, validation, and reporting procedures.

With regard to **data gathering**, the DAS was designed to automatically retrieve all outputs from instrumentation, including process data, on a continuous basis and to ensure that this information was correctly stored on a hard disk. As a backup, a hard copy of averaged values was printed every 6 minutes. The system could also recall previously recorded information.

Linked in a network configuration, five microcomputers monitored the following instrumentation:

- the continuous gas analyzers;
- the exhaust gas thermocouples and pressure drop (velocity) measurement;
- combustion air temperature;
- the facility process controller, with its instrumentation and set-point values.

Data acquisition software was custom designed to:

- continuously receive data from the data-logging equipment at 30-second intervals for the CEM data and 90-second intervals for the process data, from approximately two hours before each test started until approximately one hour after test completion;
- convert and store the data in a standard numeric format;
- display statistics, a process schematic, and graphical summaries on a real-time basis;
- provide access to the data from a remote location via a modem.

For **process monitoring**, 43 process points were monitored by the DAS through the facility controller. Four important process parameters were calculated: combustion efficiency, flue gas heat loss, excess air, and steam efficiency. These values were recalculated after every scan, and the current values displayed along with the maximum, minimum, and 6-minute rolling average values.

The constant availability of data proved invaluable during the test program, because it allowed process upsets to be quickly identified. The data replay feature clearly provided a better understanding of the process and emission trends.

Quality Assurance/Quality Control (QA/QC) procedures were instituted for the Data Acquisition System. Continuous emissions data were monitored by project staff and verified by QA/QC personnel to ensure that data sent corresponded to data received and stored. Zero and calibration voltages were recorded for each CEM before and after each test. A comparison was made between pre-test and post-test voltage readings to determine if the percentage drift was within acceptable limits. These data were reviewed by QA/QC personnel. For each Performance Test, a report containing six-minute averages, graphics, and statistics (average, minimum, and maximum for each CEM channel) was provided to project staff for review.

Data processing involved reworking the data retrieved during the test runs into a more meaningful form (i.e., producing 6-minute averages, graphics revealing trends in process parameters, and a summary report). Any problems were identified, noted, and accounted for. The overnight turnaround of data greatly assisted the team in evaluating the success of previous tests and in determining new operating conditions for the following tests. All comments from the QA/QC personnel were reviewed and any necessary corrections were made the following day. In this manner, many potential problems were avoided in the field.

Datalogger summary reports from the data processing included the following:

- Calibration Matrix report, documenting the detailed history of the state of the nine continuous stack gas monitoring instruments over the duration of each test run;
- Interval Average reports for each datalogger, displaying the 6- and 30-minute averages of selected channels over the duration of the test run;
- Channel Descriptions and Statistics report, displaying the average, maximum, minimum, percent variance, and standard deviation for all process and instrumentation data;
- summary presentation of steam characteristics, primary and secondary air flow rates and distributions, grate speeds, and boiler temperatures.

The data manually recorded on the sampling train field sheets for each sampling train were entered into the computer (along with sample recovery data from the field laboratory) and processed overnight for each test run. Summary reports were available on a daily basis for each test run. Between successive tests, 11 different graphs were produced, combining process and continuous gas data. Anomalies were investigated and corrections made as required. Following performance testing, all data were verified and corrected as required.

4.6 Laboratory Analytical Procedures

4.6.1 General

Each sampling train used in this program required a distinct sample recovery technique. The techniques used generally followed the procedures detailed in the respective sampling protocol (i.e., U.S. EPA, ASME, CARB) listed in Table 3.

One notable variation for the trace organic sampling train (MM5) was the use of ethylene glycol in the second impinger for consistency with previous NITEP programs. Additionally, the back half components were soaked once with acetone and once with hexane to improve recovery of the trace organic compounds from these components. These were deviations from the Quality Assurance Project Plan (QAPP) submitted for this program.

Another deviation from the original QAPP was HCl sampling. During recovery of the MM5 trains, an aliquot was removed from the condensate impinger for subsequent HCl analysis, as backup to the continuous HCl monitors.

For the particle size distribution samples, not enough particulate was collected to provide measurable cutpoints, due to the very low grain loading. The filter substrates were photographed and a qualitative assessment of each substrate was done.

A chain-of-custody procedure was established to document the identity of sample handling from first collection as a sample until analysis and data reduction were completed. Custody records traced a sample from its collection through all transfers of custody until it was transferred to the analytical laboratory. Internal laboratory records documented the custody of the sample from its collection through its disposition.

4.6.2 Analytical Protocols

The analytical laboratories responsible for each parameter and appropriate methodologies used are given in Table 3.

To determine the **calorific value** of the RDF, a weighed sample was burned in an oxygen bomb calorimeter under controlled

conditions and the calorific value was computed from temperature observations made before and after combustion.

The **trace metals** that were analyzed in each sample are listed in Table 4. Before conducting the metal analyses, it was necessary to release the analytes of interest from the environmental matrix in which they were held, so that the final analytes in the digestate were stable and interferences of organics and other possible analytes were eliminated or minimized. For this program, digestions were accomplished using the 3000 Series Digestion Methods as listed in EPA SW-846 (U.S. EPA, 1986).

Aqueous and solid samples were prepared for atomic absorption (AA) or inductively coupled plasma (ICP) using the digestion procedures outlined in SW-846 Method 3010 and Method 3050 (U.S. EPA, 1986) for aqueous and non-aqueous samples, and Method 3060 for refuse and ash. Flue gas samples for metals analysis were prepared in accordance with the procedures specified in the EMB protocol (Volume III, Appendix D of this report series, Environment Canada, 1991).

One notable exception in the analytical procedure used for **mercury** is the use of potassium permanganate at 6% concentration, as opposed to 5% concentration in U.S. EPA Method 7470 (U.S. EPA, 1986) and potassium sulphate at saturation (as opposed to 5% concentration in Method 7470). These were added to further oxidize the sample and minimize interferences from anions such as chloride and sulphide.

Arsenic was analyzed using a gaseous hydride atomic absorption procedure as outlined in SW-846, Method 7061 (U.S. EPA, 1986), with the following minor

Table 3 Analytical Responsibilities and Methods - Performance and Characterization Testing

Parameters	Method	Analytical Laboratory
Trace Organics	ASME/Environment Canada	Environment Canada
Volatile Organics	SW-846 5040/8240	Clean Harbors Analytical Services
Chlorides - Impinger Solutions	Ion Chromatography	Canviro Laboratories
All Metals (excluding As, Se, Hg, and Chromium in Gaseous Streams)	SW-846 - Method 6010	Canviro Laboratories
Hexavalent Chromium	CARB Method 425	Canviro Laboratories
Arsenic	SW-846 - Method 7061	Canviro Laboratories
Selenium	SW-846 - Method 7741	
Mercury	SW-846 - Method 7470	
Higher Heating Value of RDF	ASTM E711-81	Canviro Laboratories
Ultimate Analysis of RDF	ASTM D3176/E791	
Proximate Analysis of RDF	ASTM D3172/E791	
Available Lime	ASTM C25	
Combustibles in RDF	ASTM/E791	
Moisture in RDF/Ash	ASTM E790/D3173	
RDF Particle Sizing	ASTM E828	

Table 4 Trace Metals

Aluminum	Al	Manganese	Mn
Antimony	Sb	Mercury	Hg
Arsenic	As	Molybdenum	Mo
Barium	Ba	Nickel	Ni
Beryllium	Be	Phosphorus	P
Bismuth	Bi	Selenium	Se
Cadmium	Cd	Silicon	Si
Calcium	Ca	Silver	Ag
Chromium	Cr	Sodium	Na
Cobalt	Co	Tellurium	Te
Copper	Cu	Tin	Sn
Indium	In	Titanium	Ti
Iron	Fe	Vanadium	V
Lead	Pb	Zinc	Zn
Magnesium	Mg		

modifications. Hydrochloric acid and sodium iodide were used in place of stannous chloride to reduce the arsenic to its trivalent form (APHA Method 303E, APHA, 1985).

Chlorides were determined using ion chromatography. An aliquot from the MM5 train condensate (first impinger) was injected into a stream of 4-hydroxyl benzoic acid eluent before entering a separation column. The separated anions were measured on a conductivity detector and identified based on their retention time relative to known standards. Quantification was based on peak area single electronic integration.

Particulate samples (front half acetone rinse and the filter) collected from the particulate/metals train underwent **gravimetric analysis** before being submitted for metals analysis. The gravimetric analysis followed the procedures outlined in U.S. EPA Reference Method 5 (U.S. EPA, 1988). The gravimetric analysis requires measuring the weight gain on the particulate filter and the residue left over in the acetone rinse of the front half train components. The gravimetric analysis requires desiccation of the samples before determination. Samples were weighed to a constant weight of ± 0.5 mg.

The Environment Canada River Road Environmental Technology Centre laboratory analyzed RDF, ash, and flue gas samples for **semivolatile trace organics** including PCDD/PCDF. All samples generated during two of the runs were selected for high resolution gas chromatography/mass spectroscopy (GC/MS). Several other flue gas samples (MM5) were selected for analysis by high-resolution GC/MS. Some of the dry bottom ash and grate sifting samples were combined for analysis. Two runs were

analyzed separately. The target semivolatile organic analytes in this program are listed in Table 5.

Volatile organic compounds (VOC) in the gaseous streams were analyzed from each VOST run. The samples collected from each VOST run consisted of a Tenax cartridge and a Tenax/charcoal backup cartridge. For every third run, the condensate impinger sample was recovered.

Tenax tube samples were analyzed for volatile organics using the thermal desorption GC/MS procedures specified in Method 5040 of SW-846 (U.S. EPA, 1986). Condensates were analyzed using Method 8240 (U.S. EPA, 1986) via purge-and-trap GC/MS. The volatile analytes are listed in Table 6.

4.7 *Statistical Data Analysis*

Since all sampling and laboratory results and process measurements were entered into the computer via the data acquisition system described in Subsection 4.5, an extensive matrix of data was produced for each performance test. Accordingly, it was possible to perform statistical analysis of these data using the technique of regression analysis. This technique generates a mathematical model that best describes the relationship between sets of data.

Single regression analysis was first used to screen the database for relevant trends and correlations. The initial screening was for relevant linear relationships between pairs of variables. In most research, it is difficult to find a regression line, especially a straight one, that perfectly fits the data. A measure of the "goodness of the fit" is given by the correlation coefficient, R , and its square, the determination coefficient, R^2 . The

Table 5 Target Semivolatile Organic Analytes

Compound Group	Analytes																													
Polychlorinated dibenzo- <i>p</i> -dioxins*	T ₄ CDD P ₅ CDD H ₆ CDD H ₇ CDD O ₈ CDD																													
Polychlorinated dibenzofurans ⁽¹⁾	T ₄ CDF P ₅ CDF H ₆ CDF H ₇ CDF O ₈ CDF																													
Chlorobenzenes	Cl ₃₋₆ Benzene																													
Polychlorinated Biphenyls	Cl ₂₋₁₀ Biphenyl																													
Chlorophenols	Cl ₂₋₅ Phenol																													
Polycyclic Aromatic Hydrocarbons	<table border="0"> <tr> <td>Acenaphthylene</td> <td>Triphenylene</td> </tr> <tr> <td>Acenaphthene</td> <td>7 Methyl-Benzo(a) Anthracene</td> </tr> <tr> <td>Fluorene</td> <td>Benzo (b) Fluoranthene</td> </tr> <tr> <td>2-Methyl-Fluorene</td> <td>Benzo (k) Fluoranthene</td> </tr> <tr> <td>Phenanthrene</td> <td>Benzo (e) Pyrene</td> </tr> <tr> <td>Anthracene</td> <td>Benzo (r) Pyrene</td> </tr> <tr> <td>Fluoranthene</td> <td>Perylene</td> </tr> <tr> <td>Pyrene</td> <td>2-Methyl-Benzo (j) Aceanthrylene</td> </tr> <tr> <td>Benzo (a) Fluorene</td> <td>Indeno (123-cd) Pyrene</td> </tr> <tr> <td>Benzo (b) Fluorene</td> <td>Dibenzo (ah) Anthracene</td> </tr> <tr> <td>1 Methyl-Pyrene</td> <td>Benzo (b) Chrysene</td> </tr> <tr> <td>Benzo(ghi)Fluoranthene</td> <td>Benzo (ghi) Perylene</td> </tr> <tr> <td>Benzo (a) Anthracene</td> <td>Anthanthrene</td> </tr> <tr> <td>Chrysene</td> <td></td> </tr> </table>		Acenaphthylene	Triphenylene	Acenaphthene	7 Methyl-Benzo(a) Anthracene	Fluorene	Benzo (b) Fluoranthene	2-Methyl-Fluorene	Benzo (k) Fluoranthene	Phenanthrene	Benzo (e) Pyrene	Anthracene	Benzo (r) Pyrene	Fluoranthene	Perylene	Pyrene	2-Methyl-Benzo (j) Aceanthrylene	Benzo (a) Fluorene	Indeno (123-cd) Pyrene	Benzo (b) Fluorene	Dibenzo (ah) Anthracene	1 Methyl-Pyrene	Benzo (b) Chrysene	Benzo(ghi)Fluoranthene	Benzo (ghi) Perylene	Benzo (a) Anthracene	Anthanthrene	Chrysene	
Acenaphthylene	Triphenylene																													
Acenaphthene	7 Methyl-Benzo(a) Anthracene																													
Fluorene	Benzo (b) Fluoranthene																													
2-Methyl-Fluorene	Benzo (k) Fluoranthene																													
Phenanthrene	Benzo (e) Pyrene																													
Anthracene	Benzo (r) Pyrene																													
Fluoranthene	Perylene																													
Pyrene	2-Methyl-Benzo (j) Aceanthrylene																													
Benzo (a) Fluorene	Indeno (123-cd) Pyrene																													
Benzo (b) Fluorene	Dibenzo (ah) Anthracene																													
1 Methyl-Pyrene	Benzo (b) Chrysene																													
Benzo(ghi)Fluoranthene	Benzo (ghi) Perylene																													
Benzo (a) Anthracene	Anthanthrene																													
Chrysene																														

* Congeners with the 2,3,7,8 configuration were analyzed by high-resolution GC/MS in selected streams from selected test runs.

Table 6 Volatile Organics

Bromodichloromethane	Benzene
Bromoform	Bromomethane
Carbon tetrachloride	Chlorobenzene
Chloroethane	Chloroform
Chloromethane	cis-1,3-Dichloropropene
Dibromochloromethane	1,1-Dichloroethane
1,2-Dichloroethane	1,1-Dichloroethylene
trans-1,2-Dichloroethylene	trans-1,3-Dichloropropene
1,2-Dichloropropane	Ethylbenzene
Methylene chloride	1,1,2,2-Tetrachloroethane
Tetrachloroethylene	Toluene
1,1,1-Trichloroethane	1,1,2-Trichloroethane
Trichloroethylene	Trichlorofluoromethane
Vinyl chloride	

determination coefficient is often used in statistics because it is always a positive value, thus providing a convenient way of comparing the "goodness of fit" of different regression models. Furthermore, R^2 describes the portion of the total variance that is explained by the correlation with a value of one representing a "perfect fit".

For this project, it was decided to focus on relationships with R^2 values of greater than 0.5. For this program, regression analysis was based on 13 test runs and the critical R^2 value for 13 pairs of data for a 5% significance is 0.306. Therefore, the use of 0.5 as the low end cutoff for determination coefficients is within the 95% confidence interval.

Subsequent to an initial screening based on single linear regression, multiple regression correlations were generated using the Statistical Analysis System (SAS) computer package. This package examines all possible combinations of independent variables and selects the group of variables

that shows the best relationship with a dependent variable, i.e, highest R^2 .

The results of the statistical analyses for the combustion system are presented in Section 5 and for the air pollution control system, in Section 6.

4.8 Quality Assurance/Quality Control (QA/QC)

Due to the broad program scope and the number of parties involved in the project team, considerable effort was made to blend the activities of all parties together to ensure a high level of Quality Assurance/Quality Control (QA/QC). Alliance Technologies Corporation established its own internal QA/QC program in parallel with an independent external QA/QC program coordinated by the U.S. EPA's Emission Measurements Branch.

In general, the QA/QC personnel were responsible for overseeing all sampling and analytical aspects of the test program to ensure the sample quality. The

responsibilities for the internal and external QA/QC activities are summarized in Table 7. Briefly, QA/QC activities included:

- ensuring compliance with accepted Environment Canada/U.S. EPA test methods;
- ensuring that the respective operators and sample handlers thoroughly understand and adhere to recommended equipment procedures and their corresponding calibration;
- verifying that all equipment was functional, proofed, and calibrated to obtain the desired data quality;
- ensuring that all test personnel understood the procedures that they followed, and subsequently, regularly verifying during the test that the procedures were followed correctly;
- ensuring sample integrity for analysis throughout collection, recovery, and transfer;
- ensuring the quality of the data collected through data acquisition and processing;
- collecting duplicate samples for the various test processes, for independent analysis; and
- verifying laboratory procedures for organic and inorganic analysis.

The purpose of setting quality assurance objectives was to ensure that data of known and acceptable quality was produced. The U.S. EPA, Environment Canada, and Alliance Technologies collaborated to develop the Quality Assurance Project Plan

(QAPP), which defined QA/QC criteria, such as levels of precision, accuracy, representativeness, completeness, and comparability. These allowed for an adequate evaluation of the tests. Quality Assurance criteria were developed for the following critical analyses: metals, chloride, dioxins/furans, and calorific value. Laboratory and field blank samples were taken and analyzed to provide a quantitative assessment of the occurrence of sample contamination.

Results of the QA assessment of the chemical analyses of all samples are provided in Chapter 7 of Volume II (Environment Canada, 1991).

The QA/QC program represented a significant effort and expenditure of resources for the project. It provided both internal and external control over all elements and activities of the test program. It provided assurance for sample quality and assisted in immediate identification of potential problems.

The findings of both the internal and external QA/QC programs indicated that the field study was executed properly, according to the stated sampling and analytical protocols, using properly calibrated and/or proofed equipment. Samples collected during this test program were deemed to be representative and the data reported were complete and accurate. To the best of the QA/QC auditors' knowledge, any errors, omissions, and problems are correctly documented in the reports.

A more extensive discussion of the QA/QC program and results can be found in Chapter 7 of Volume II and in Volume VI of this report series, (Environment Canada, 1991).

Table 7 External and Internal Quality Assurance/Quality Control Responsibilities

Subject	Internal QA/QC Responsibility	External QA/QC Responsibility
Test Program	Define program objectives and design test matrix to achieve program objectives.	Assess if sampling program and data collection are sufficient to meet program objectives.
Test Protocols	Select protocols, detail procedures, and define QC activities and limits.	Review and critique protocols and procedures. Assess protocols for comparability to previous programs.
Calibration of Test Equipment	Verify accuracy of calibration. Document instrument performance.	Observe personnel, equipment, and procedures during performance of calibration procedures. Review documentation of instrument calibration performance. Provide on-site audit checks and document performance.
Sampling Locations	Identify suitable sampling locations and perform necessary modifications.	Check for suitability of location to permit collection of representative samples.
Field Sampling	Provide trained test crew, properly prepared and/or calibrated equipment, and sufficient supply of correct contamination-free reagents.	Observe testing, including leak checks, and document any deviations from protocols. Verify calibration by conducting on-site audits.
CEMS Testing	Document instrument performance and verify accuracy of calibration gases. Provide and follow detailed operating and QC procedures.	Review documentation on instrument performance and calibration gas analysis. Observe on-site testing and document any deviations from protocol. Conduct cylinder gas audits.
Data Acquisition System	Establish standard operating procedures and conduct routine QC checks to verify accuracy of program.	Observe operation of system. Perform audit of system by providing a known data set. Document results.
Process Samples	Provide trained/experienced personnel, acceptable sampling equipment, data sheets for documentation, and establish sample handling and sample preparation procedures.	Review sampling sites, sampling equipment, sample handling, and sample preparation protocols, as well as document activities during sampling. Observe efforts for deviations.
Sample Recovery	Recovery following defined protocols. Collect reagent blanks and field blanks.	Observe and document recovery operation. Document that correct reagent blanks and field blanks are collected.
Sample Custody	Samples logged, chain-of-custody sheets prepared, and samples properly packaged for transportation.	Review sample log-in and chain-of-custody documentation. Observe and document sample packaging. Obtain split samples for external QA/QC laboratory analysis.
Process and Field Sampling Data	Provide experienced DAS operator(s), reliable hardware, and validated software.	Document accuracy of logged data and verify accuracy of reported and calculated values with technical system audits.
Sample Analysis	Select acceptable methods and detail procedures and changes. Detail laboratory QC including calibrations, control samples, and matrix spikes.	Review and comment on selected procedures. Review performance and document deviations from selected protocol. Conduct performance evaluation audits. Submit split samples for external laboratory analysis.
Data Reduction Procedures	Establish standard data reduction procedures. Conduct initial checks on procedures/calculations to verify accuracy.	Review data reduction procedures. Perform audit of procedures/calculations using known data set and document results.

Section 5

Performance Test Series for Combustion System

5.1 Overview

The performance test (PT) results and key findings for the combustion system are summarized in this section. The PT results for the air pollution control system are provided in Section 6.

The performance test series was conducted from February 14 to March 1, 1989. As described earlier, 13 PT test runs were successfully conducted using 7 different test conditions for the combustion system. One full day was required for each run. The test crew used run PT-01 as a "practice" run to trouble-shoot and evaluate the sampling system. Because data from the run PT-01 are incomplete, it is not included in this report. Volume IV of the test report series (Environment Canada, 1991) presents all the data generated during the test program.

As discussed in Section 3, the objective of the PT Series was to evaluate the combustion system and air pollution control system under different operating conditions. Load (steam flow rate) and combustion air flow rates/distributions were the primary independent variables for combustion performance tests. The target test conditions for the performance tests evolved from the characterization test phase, but it was necessary to modify these during the PT Series due to changes in plant operation and performance. The seven operating conditions tested for the combustion system, are summarized in Figure 12 for each of the 13 test runs.

A major goal of this project was to determine combustor emissions of trace organics and metals under different process operating conditions. To account for the inherent variation in the flue gas characteristics, multiple PT runs were conducted for four of the seven combustion test conditions. Single test runs were performed for only three of the test conditions.

Some of the key findings determined from an analysis of the test data for the combustion system are listed below and are discussed in more detail in this section:

- Good combustion conditions resulted in a 96% net destruction efficiency for trace organics as determined by a comparison of the total quantified organics in the facility input (RDF feed) and output (ash and stack emission) streams. The net average destruction efficiency for quantified organics for poor combustion tests was 90%.
- When comparing CO emissions with PCDD/PCDF emissions, the arithmetic average of CO emissions over the testing period provided the best correlation with PCDD/PCDF concentrations at the spray dryer inlet. However, the correlation was poor when considering only those tests in which CO averaged below 200 ppm for the test period. Other comparisons of PCDD/PCDF concentrations with the number or magnitude of CO spikes and the percent of time above an absolute CO level produced less significant correlations.

- For poor combustion conditions, average total hydrocarbons (THC) or CO emission is the best single indicator of **uncontrolled** PCDD/PCDF emissions, with determination coefficients, R^2 of 0.97 and 0.95 respectively.
- For good combustion conditions, entrained particulate matter at the spray dryer atomizer inlet is a fair indicator of **uncontrolled** PCDD/PCDF emissions ($R^2 = 0.60$).
- Previous laboratory and field tests have shown that PCDD/PCDF concentrations increase when the flue gases pass through the 400 to 150°C temperature range. Contrary to earlier findings, the PCDD/PCDF emissions decreased when the flue gases passed through this range. This reduction may be related to the rapid cooling and/or the relatively short time the particulate matter was held at this range. The flue gas passes through this range in the air preheater which has a short residence time of 1.5 to 2 seconds.
- The best multiple regression **prediction models** for **uncontrolled** trace organic emissions typically use two or more easily monitored variables that characterize or identify the combustion process (i.e., CO, NO_x, HCl, furnace temperatures, and moisture).
- The best multiple regression **control models** for **uncontrolled** trace organic emissions typically use two or more combustion operation variables that impact lower furnace combustion conditions (i.e., undergrate air flow, rear wall air flow, moisture, and total combustion air).

5.2 Summary by Performance Test Run

Some of the key data generated during each PT run for the combustion system are summarized in Tables 8 and 9. Key process data for the combustion system are presented in Table 8 per test run. Parameters shown here include combustion parameters, feed and ash mass rates, and flue gas flow rates. Some of the flue gas data measured at the SD inlet per PT run are presented in Table 9. Detailed test results per PT run, including the organic and metal analyses of the RDF feed stream and the various ash streams leaving the combustor, as well as trace organics and metal analyses for the flue gas at the air preheater inlet, SD inlet, and FF outlet are presented in Volume II of the report series (Environment Canada, 1991).

The test runs are categorized by the steam load (low, intermediate, normal, or high) and combustor operation (good, poor, or very poor).

Combustor operation is rated by the average carbon monoxide level for the run, measured at the spray dryer inlet, as follows:

good:	CO ≤ 200 ppm
poor:	200 ppm < CO ≤ 400 ppm
very poor:	CO > 400 ppm.

5.3 Summary by Performance Test Condition

Key performance test data for the combustion system for each of the seven operating conditions are shown in Appendix B, while more detailed performance data are available in Appendix A. These data are discussed in small segments in this subsection.




Figure 12 Performance Test Key Operating Parameters for Combustion System Test Series

Table 8 Key Process Data for Combustion System per Performance Test Run

STEAM LOAD		LOW		INTERMEDIATE			NORMAL			NORMAL			HIGH	
COMBUSTOR OPERATION TEST #		GOOD PT-13	GOOD PT-14	GOOD PT-10	GOOD PT-02	VERY POOR PT-05	GOOD PT-09	GOOD PT-08	GOOD PT-11	POOR PT-03	POOR PT-04	POOR PT-07	GOOD PT-12	POOR PT-06
STEAM FLOW	('000 kg/h)	71	74	87	88	84	95	96	96	100	99	101	107	106
REFUSE FEED RATE	('000 kg/h)	20.7	18.9	26.1	27.6	27.0	30.4	28.7	25.4	30.8	30.7	26.4	28.0	27.5
RW O/F AIR	('000 kg/h)	0	0	0	0	1.5	3.6	3.6	3.6	3.8	0	0	3.2	0
TANGENTIAL O/F AIR	('000 kg/h)	39	43	51	51	32	49	46	51	39	63	56	52	66
TOTAL O/F AIR	('000 kg/h)	45	49	56	56	40	59	56	60	48	69	62	61	72
TOTAL COMB. AIR	('000 kg/h)	94	99	109	109	103	116	117	116	110	127	121	116	126
GRATE SPEED		17/19	15/17	15/19	37	23/18	27/23	29/27	18	19	20	27/23	29	27
F.D. FAN PRESSURE		9/10	10	14	15	15/11	13	15/13	15	15	15	13	18	16
AIR DISTRIBUTION														
UG AIR	%	53	51	48	48	62	49	52	48	56	46	49	47	43
PDA AIR	%	5.8	5.9	5.3	4.6	6.1	5.3	5.4	5.0	5.1	4.5	4.7	5.0	5.1
RW AIR	%	0	0	0	0	1.5	3.1	3.1	3.1	3.5	0	0	2.7	0
TANGENTIAL AIR	%	42	44	47	47	31	42	40	44	35	50	46	45	52
O/F AIR	%	47	49	52	52	38	51	48	52	44	54	51	53	57
PROCESS TEMPERATURES														
FURNACE TEMPERATURE	(°C)	965	1004	1012	1022	1020	1033	1015	1026	1034	1059	1006	1049	976
BOILER INLET TEMP.	(°C)	579	597	603	608	605	575	547	599	596	598	544	607	612
ECON. OUT. TEMP.	(°C)	346	365	373	355	367	371	387	374	370	371	387	387	365
A/H GAS OUTLET TEMP.	(°C)	179	193	193	192	190	193	203	187	208	193	204	197	185
TOFA ELEVATION (SETTINGS)														
- TOP	(DEG)	+10	+10	+10	+10	-	+10	+10	+10	+10	+10	+10	+10	+10
- MIDDLE	(DEG)	+6	+6	+6	+6	-/+6	+6	+6	+6	-	+6	+6	+6	+6
- BOTTOM	(DEG)	-	-	-	-	-	-	-	-	-	+2	+2	+2/-	+2
REAR OFA PRESSURE	(kPA)	-	0	0	0	8.8/0	8.8	8.8	8.8	8.8	0	0	0/8.8	0
ASH MASS RATES														
ECONOMIZER (ACTUAL)	kg/h	8.7	17	10	24	14	15	18	14	11	15	14	17	10
FABRIC FILTER (ACTUAL)	kg/h	673	1130	1170	NC	429	1320	434	2140	NC	1390	550	315	1240
TOTAL FLY ASH (ACTUAL)	kg/h	682	1150	1180	NC	443	1330	452	2150	NC	1400	564	332	1250
GRATE SIFTINGS (ACTUAL)	kg/h	85	89	91	140	103	118	100	110	125	105	116	106	71
BOTTOM ASH (WET)	kg/h	2380	2930	3410	4360	3210	3820	4370	3360	4040	4370	4610	4000	4710
FLUE GAS FLOW RATE														
AIR HEATER INLET														
MM5 SAMPLING TRAIN	Sm³/hr			137000			129000	131000				139000		
SPRAY DRYER INLET														
MM5 SAMPLING TRAIN:	Sm³/h	132000	141000	154000	151000	146000	145000	149000	145000	148000	153000	158000	143000	160000
METALS SAMPLING TRAIN	Sm³/h	123000	137000	156000	155000	148000	148000	151000	148000	147000	156000	158000	145000	162000

NC - Data not collected

Table 9 Key Data for Combustion Gas Composition per Performance Test Run

STEAM LOAD	LOW		INTERMEDIATE			NORMAL			NORMAL			HIGH	
COMBUSTOR OPERATION TEST #	GOOD PT-13	GOOD PT-14	GOOD PT-10	GOOD PT-02	VERY POOR PT-05	GOOD PT-09	GOOD PT-08	GOOD PT-11	POOR PT-03	POOR PT-04	POOR PT-07	GOOD PT-12	POOR PT-06
PREHEATER INLET													
Total PCDD (ng/Sm ³ **) (mg/tonne *)			174 0.80			141 0.60	258 1.16				390 2.06		
Total PCDF (ng/Sm ³ **) (mg/tonne *)			816 3.8			767 3.2	1,827 8.2				1,932 10.2		
SPRAY DRYER INLET													
** + CO ppm	158	70	77	108	903	92	89	68	432	214	387	116	397
CO2 %	9.8	10.1	10.5	10.4	11.0	11.9	11.8	11.6	12.0	11.9	12.1	12.9	11.5
O2 %	10.1	9.6	9.2	9.1	8.7	7.6	7.5	7.9	6.9	7.6	7.2	6.4	7.9
** NOx ppm	157	177	186	184	149	188	193	175	160	172	172	180	157
** SO2 ppm	175	189	194	177	169	178	184	174	200	186	183	198	192
** HCl ppm	421	442	429	472	469	432	538	413	419	471	399	470	404
** THC ppm	6	3	2	3	52	5	3	2	20	8	13	6	29
Moisture %	12.2	12.2	13.8	13.6	15.5	17.5	16.2	15.0	17.8	14.8	NA	16.0	14.7
Total PCDD (ng/Sm ³ **) (mg/tonne *)	147 0.76	72 0.45	243 1.26	213 1.01	580 2.86	71 0.33	211 1.08	92 0.51	230 1.11	151 0.74	207 1.25	67 0.36	317 1.76
Total PCDF (ng/Sm ³ **) (mg/tonne *)	452 2.35	356 2.23	424 2.19	733 3.48	1281 6.32	378 1.78	951 4.87	444 2.46	778 3.75	623 3.08	796 4.80	215 1.18	885 4.92
Mercury (µg/Sm ³ **) (g/tonne *)	531 2.58	914 5.57	718 3.76	726 3.54	634 3.18	644 3.10	646 3.35	661 3.71	583 2.79	614 3.10	584 3.53	558 3.10	583 3.30
Particulate (µg/Sm ³ **) (g/tonne *)	3,210,000 15,600	3,700,000 22,500	4,530,000 23,700	5,440,000 26,500	4,460,000 22,400	3,890,000 18,800	4,750,000 24,600	3,980,000 22,400	4,640,000 22,200	3,270,000 16,500	4,230,000 25,600	3,390,000 18,900	3,310,000 18,700

** Corrected to 12% CO2

* Refuse as fired

+ Reconstructed from measurements at SD inlet and FF outlet.

Note that preheater inlet samples were collected only for PT-07 to PT-10.

5.3.1 Process Data

Process operating conditions for the combustor system, including steam and refuse feed rates, process temperatures, and ash rates are shown in Table 10. The steam production rate ranged from 73 000 kg/h (160 000 lb/h) for the "low load" condition to 107 000 kg/h (235 000 lb/h) for the "high load" condition. Normal production was 96 000 to 100 000 kg/h. Refuse feed rate was 19 000 kg/h for the low load, but the refuse rate was within a narrow range (27 000 to 30 000 kg/h) for the other loads. Accordingly, there is a poor correlation between refuse feed rate and steam production. The distinction between "good operation" and "poor operation" using CO as the parameter is clearly shown: CO is below 200 ppm for good operation and over 200 ppm for poor operation.

5.3.2 Continuous Emissions Monitoring (CEM) Data

Test condition averages for the CEM data are given in Table 11 and include CO, CO₂, O₂, THC, SO₂, NO_x, and HCl at the spray dryer inlet (SDI).

The CO concentrations at the SDI are reconstructed from measurements at the SDI and fabric filter outlet (FFO). Two CO analyzers were used during the test program. One was located at the spray dryer inlet and the other at the fabric filter outlet. The scale of the analyzer at the SDI ranged from 0 to 500 ppm. The analyzer at the FFO read values greater than 500 ppm. The most reliable data from both analyzers were used, and a new data set (corrected to 12% CO₂) was reconstructed for the CO concentrations at the SDI and FFO. If either analyzer measured less than 500 ppm of CO, the reading from the analyzer at the SDI was used. If both analyzers read greater than

500 ppm of CO, the value from the analyzer at the FFO was used.

Excess oxygen appears to correlate inversely with steam load (i.e., higher O₂ [10%] at low load and lower O₂ [6 to 8%] at higher steam load).

As expected, the SO₂ and HCl at the spray dryer inlet were not affected by combustor operation. Based on averages for each PT operating condition, inlet SO₂ was in the range of 170 to 200 ppm and inlet HCl ranged from 400 to 470 ppm, which is typical for MSW incinerators. Variation in SO₂ and HCl at SDI location is attributable to differences in the amount of chlorine and sulphur in the refuse feed. Control of acid gases is discussed in Section 6.

Total hydrocarbon concentrations were 2 to 6 ppm for "good operation", and significantly higher (14, 29, 52 ppm) during "poor combustor operation".

5.3.3 Trace Organic Concentrations

Concentrations of trace organics measured at the air preheater inlet and spray dryer inlet for each performance test condition of the combustion system are summarized in Table 12. The concentrations at the spray dryer inlet are assumed to be the concentrations at the exit of the combustion system, before treatment in the air pollution control system.

It is relevant to note that, in general, concentrations of all trace organics at the SDI, except PCB (which is relatively low), were much higher under poor combustion conditions than under good combustion conditions. This is clearly illustrated in Table 13. Accordingly, combustor operations have a significant effect on trace organic concentrations in the flue gas. The use of carbon monoxide and total

Table 10 Key Process Data for Combustion System per Performance Test Condition

STEAM LOAD :		LOW	INTERMEDIATE		NORMAL		HIGH	
COMBUSTOR OPERATION :		GOOD	GOOD	VERY POOR	GOOD	POOR	GOOD	POOR
TEST # :		13,14	2,10	5	8,9,11	3,4,7	12	6
Steam Rate	kg/h	73,000	88,000	84,000	96,000	100,000	107,000	106,000
Refuse Feed Rate	kg/h	19,000	27,000	27,000	28,000	29,000	28,000	28,000
UG:OF Air Ratio		1.083	0.923	1.632	1.000	1.000	0.887	0.754
TOFA Number Levels		2	2	1	2	1&3	2	2
CO	(ppm)	114	93	903	83	344	116	397
Furnace Temperature	°C	985	1,016	1,020	1,025	1,033	1,049	976
Boiler Inlet Temp.	°C	588	605	605	574	579	607	612
Economizer Outlet Temp.	°C	356	364	367	377	376	387	365
A/H Outlet Temp.	°C	186	193	190	194	202	197	185
Economizer Ash Rate	kg/h	12.7	16.7	13.8	15.5	13.5	17.0	10.5
Fabric Filter Ash Rate	kg/h	903	583	429	1,297	968	315	1,239
Bottom Ash Rate (dry)	kg/h	2,370	3,100	2,830	3,120	3,550	3,280	3,350

Table 11 Continuous Emissions Monitoring Data for Combustion System per Performance Test Condition

STEAM LOAD :		LOW	INTERMEDIATE		NORMAL		HIGH	
COMBUSTOR OPERATION :		GOOD	GOOD	VERY POOR	GOOD	POOR	GOOD	POOR
TEST # :		13,14	2,10	5	8,9,11	3,4,7	12	6
Spray Dryer Inlet								
Flue Gas Flow Rate	Sm ³ /h	133,000	154,000	147,000	148,000	153,000	144,000	161,000
Moisture	%	12.2	13.7	15.5	16.2	16.3	16.0	14.7
*+CO	ppm	114	93	903	83	344	116	397
CO ₂	%	10.0	10.5	11.0	11.8	12.0	12.9	11.5
O ₂	%	9.9	9.2	8.7	7.7	7.2	6.4	7.9
* NO _x	ppm	167	185	149	185	168	180	157
* SO ₂	ppm	182	186	169	179	189	198	192
* HCl	ppm	432	450	469	461	430	470	404
* THC	ppm	4.7	2.5	52.4	3.3	13.9	6.1	28.6

* – Corrected to 12% CO₂

+ – Reconstructed from measurements at SD inlet and FF outlet.

Table 12 Trace Organic Concentrations for Combustion System per Performance Test Condition

STEAM LOAD :	LOW	INTERMEDIATE		NORMAL		HIGH	
OPERATION : TEST # :	GOOD 13,14	GOOD 2,10	VERY POOR 5	GOOD 8,9,11	POOR 3,4,7	GOOD 12	POOR 6
<u>CONCENTRATION</u> (ng/Sm ³ @ 12% CO ₂)							
Preheater Inlet							
PCDD	NC	174	NC	200	390	NC	NC
PCDF	NC	816	NC	1,300	1,900	NC	NC
CB	NC	12,000	NC	12,300	14,000	NC	NC
PCB	NC	252	NC	100	269	NC	NC
CP	NC	21,200	NC	39,000	59,300	NC	NC
PAH	NC	10,500	NC	44,800	88,900	NC	NC
Spray Dryer Inlet							
PCDD	109	228	580	125	196	67	317
PCDF	404	579	1,280	591	732	215	885
CB	3,960	6,050	15,800	5,480	6,940	6,030	9,400
PCB	–	20	20	33	11	34	12
CP	13,300	14,300	114,000	14,300	24,100	16,600	41,600
PAH	3,500	7,330	112,000	16,500	53,900	16,200	88,600
<u>REFUSE MASS RATIO</u> (mg/tonne*)							
Preheater Inlet							
PCDD	NC	0.24	NC	0.28	2.1	NC	NC
PCDF	NC	0.19	NC	0.18	10.2	NC	NC
CB	NC	55	NC	54	74	NC	NC
PCB	NC	1.2	NC	0.4	1.4	NC	NC
CP	NC	97	NC	171	313	NC	NC
PAH	NC	48	NC	194	470	NC	NC
Spray Dryer Inlet							
PCDD	0.61	1.1	2.9	0.64	1.0	0.36	1.8
PCDF	2.3	2.8	6.3	3.0	3.9	1.2	4.9
CB	23	30	78	28	37	33	52
PCB	–	0.1	0.1	0.17	0.06	0.19	0.065
CP	76	71	560	73	127	91	231
PAH	20	36.0	552	81	281	89	493

Note: "–" denotes value below detection limit

* – refuse as fired

NC – not collected; Preheater inlet samples collected for PT07 through PT10 only.

Table 13 Trace Organic Concentrations (ng/Sm³ @ 12% CO₂) Before Air Pollution Control (after Combustion System) for Good Operation versus Poor Operation

Trace Organic	Under Good Combustion	Under Poor Combustion
PCDD	70 to 230	200 to 600
PCDF	220 to 600	700 to 1 300
CB	4 000 to 6 000	7 000 to 16 000
CP	13 000 to 17 000	24 000 to 114 000
PAH	4 000 to 17 000	54 000 to 112 000

hydrocarbons as measures of combustion conditions that affect organic emissions is discussed in Subsection 5.6.2. Removal of trace organics by the APC system was excellent. This is further discussed in Section 6.

5.3.4 Particulate/Metal Concentrations

The concentrations of particulate matter and selected trace metals from the combustor system for each performance test condition of the combustion system are summarized in Table 14. The significant removal of these compounds by the APC system is discussed in Section 6. It is interesting to note that there is no significant difference in concentrations of particulates and trace metals under poor operation and good operation of the combustion system.

5.3.5 Analysis of Refuse-derived Fuel (RDF)

Ultimate and proximate analyses were performed on the RDF and are reported on a dry basis in Table 15. The content of trace organics and selected trace metals in the RDF for each performance test condition are also summarized in Table 15. The higher heating value of the RDF was in the range of 18.1 to 20.9 MJ/kg (7 800 to 9 000 Btu/lb) (dry basis). The ash content of the RDF

ranged from 12.5 to 18.2% (dry basis), with most results between 16 and 17%. Chlorine content was relatively broad (0.36 to 0.84%), as expected. Sulphur content was 0.19 to 0.31%. Generally, there was a very wide range in the amount of trace organics or trace metals present in the RDF samples, which is to be expected when analyzing for compounds at very low concentrations.

5.3.6 Ash Analysis

The content of trace organics in the various ash streams for each performance test condition is summarized in Table 16. Data for the fabric filter ash is also provided to illustrate that trace organics are highest in the fabric filter ash and lowest in incinerator ash.

Trace metals in the various ash streams for each performance test condition are summarized in Table 17. These results are further discussed later in this report.

5.4 Organics: Input/output Analysis

Combustion is an effective means of reducing waste and of rapidly converting its organic constituents to carbon dioxide, water vapor, and ash. The average net destruction

Table 14 Particulate and Trace Metals Concentration for Combustion System per Performance Test Condition

STEAM LOAD :	LOW	INTERMEDIATE		NORMAL		HIGH	
OPERATION :	GOOD	GOOD	VERY POOR	GOOD	POOR	GOOD	POOR
TEST # :	13,14	2,10	5	8,9,11	3,4,7	12	6
CONCENTRATION ($\mu\text{g}/\text{Sm}^3$ @ 12% CO ₂)							
Spray Dryer Inlet							
Antimony	113	120	122	135	60	173	51
Arsenic	205	240	230	211	186	247	194
Cadmium	573	584	527	694	552	562	7,440
Chromium	1,050	983	623	984	539	745	353
Copper	2,010	1,990	1,430	2,530	1,530	1,110	1,260
Lead	10,800	8,710	14,300	5,160	10,200	4,040	7,230
Mercury	723	722	634	650	594	558	583
Nickel	3,380	1,420	2,030	805	503	523	257
Zinc	48,300	44,000	31,200	44,300	35,600	34,700	31,000
Particulate	3,920,000	5,310,000	4,770,000	4,490,000	4,320,000	3,670,000	3,580,000
REFUSE MASS RATIO: (g/tonne*)							
Spray Dryer Inlet							
Antimony	0.62	0.61	0.61	0.70	0.32	0.96	0.29
Arsenic	1.1	1.2	1.2	1.1	1.0	1.4	1.1
Cadmium	3.2	3.0	2.6	3.6	2.9	3.1	2.5
Chromium	5.7	4.9	3.1	5.0	2.8	4.1	2.0
Copper	11.2	10.0	7.2	13.0	8.0	6.2	7.2
Lead	59	43	72	28	52	22	41
Mercury	4.1	3.6	3.2	3.4	3.1	3.1	3.3
Nickel	17.4	7.0	10.2	4.0	2.6	2.9	1.5
Zinc	263	223	157	230	187	193	176
Particulate	21,500	26,700	24,000	23,400	22,900	20,400	20,300

* – refuse as fired

Table 15 Refuse-derived Fuel Analysis (Dry Basis) per Performance Test Condition

STEAM LOAD:		LOW	INTERMEDIATE		NORMAL		HIGH	
OPERATION:		GOOD	GOOD	VERY POOR	GOOD	POOR	GOOD	POOR
TEST #:		14	2-10	5	8-9-10	3-4-7	12	6
HIGHER HEATING VALUE	BTU/LB	8,525	7,985	7,813	7,930	8,187	8,434	8,995
<u>PROXIMATE ANALYSIS:</u>								
VOLATILE MATTER	%	70.51	72.42	72.01	71.02	73.36	73.02	75.36
FIXED CARBON	%	12.97	11.03	12.02	10.78	10.93	9.65	12.17
ASH	%	16.52	16.56	15.97	18.21	15.71	17.33	12.47
<u>ULTIMATE ANALYSIS:</u>								
Cl	%	0.51	0.36	0.84	0.45	0.52	0.71	0.64
C	%	50.41	47.62	44.37	47.54	46.74	48.53	50.66
H	%	4.69	6.78	6.15	5.62	5.83	5.84	5.89
N	%	0.27	0.50	0.51	0.42	0.42	0.46	0.41
S	%	0.31	0.28	0.24	0.19	0.29	0.30	0.25
ASH	%	16.52	16.56	15.97	18.21	15.71	17.33	12.47
O2 (BY DIFFERENCE)	%	27.29	27.91	31.92	27.58	30.50	27.01	29.68
MOISTURE CONTENT (as fired)	%	17.12	24.27	23.26	22.31	22.54	20.47	17.23
<u>TRACE ORGANICS:</u>								
Refuse Mass Ratio (mg/tonne*)								
PCDD		6.3	2.5	5.2	3.5	3.9	4.8	13.0
PCDF		0.170	0.087	-	0.340	0.058	0.110	0.150
CB		22.0	13.0	22.0	5.9	702.0	53.0	-
PCB		-	57	194	270	-	188	-
CP		626	473	625	452	580	558	2,278
Total PAH		57,100	5,140	4,070	4,640	5,540	11,200	8,260
<u>TRACE METALS:</u>								
Refuse Mass Ratio (g/tonne*)								
Antimony		6.5	2.1	4.7	3.8	7.9	7.3	14.0
Arsenic		1.8	2.3	2.2	1.9	4.8	3.7	1.6
Cadmium		4.3	1.5	3.0	2.1	3.5	3.0	2.0
Chromium		26	20	16	66	56	11	13
Copper		243	541	26	583	100	5,890	404
Lead		180	87	159	429	296	324	143
Mercury		0.051	0.045	0.041	0.116	0.052	0.038	0.034
Nickel		37	34	19	52	58	23	13
Zinc		455	335	206	286	167	3335	357

"-" denotes value below detection limit

* - refuse as fired

Note: No data available for PT-13; values are for PT-14 only.

Table 16 Trace Organics in Ash per Performance Test Condition

STEAM LOAD :	LOW	INTERMEDIATE		NORMAL		HIGH	
OPERATION : TEST # :	GOOD 14	GOOD 2,10	VERY POOR 5	GOOD 8,9,11	POOR 3,4,7	GOOD 12	POOR 6
<u>REFUSE MASS RATIO:</u> (mg/tonne of refuse*)							
Incinerator Ash							
PCDD	—	—	—	0.012	—	—	—
PCDF	—	—	—	0.021	—	—	—
CB	—	—	—	—	—	—	—
PCB	—	—	—	—	—	—	—
CP	1.4	1.5	1.6	0.29	1.4	—	1.7
PAH	5.7	824	8.2	1.9	20	24	17
Economizer Ash							
PCDD	—	—	0.221	0.034	—	—	0.011
PCDF	—	0.019	0.93	0.22	0.159	0.066	0.456
CB	—	—	—	—	—	—	—
PCB	—	—	—	—	—	—	—
CP	21.2	8.8	5.1	7.0	5.2	6.1	1.5
PAH	—	5.2	242	7.5	34	—	413
Fabric Filter Ash							
PCDD	11	1.2	1.5	3.3	3.5	0.23	10
PCDF	10	2.1	1.1	6.5	6.7	0.63	13
CB	103	31	17	42	34	8	76
PCB	—	—	—	—	—	—	—
CP	133	86	46	133	127	16	275
PAH	421	63	150	114	62	13	335
<u>CONCENTRATION:</u> (ng/g of ash)							
Incinerator Ash							
PCDD	—	—	—	0.10	—	—	—
PCDF	—	—	—	0.17	—	—	—
CB	—	—	—	—	—	—	—
PCB	—	—	—	—	—	—	—
CP	10	12	15	2.5	11	—	14
PAH	44	6,430	76	16	161	196	136
Economizer Ash							
PCDD	—	—	0.43	0.061	—	—	0.03
PCDF	—	0.029	1.83	0.38	0.35	0.11	1.2
CB	—	—	—	—	—	—	—
PCB	—	—	—	—	—	—	—
CP	24	15	10	13	11	10	4.0
PAH	—	6.0	475	14	78	—	1,087
Fabric Filter Ash							
PCDD	184	27	96	74	119	20	227
PCDF	166	47	71	139	222	56	282
CB	1,730	684	1,090	900	1,000	708	1,680
PCB	—	—	—	—	—	—	—
CP	2,220	1,920	2,870	2,730	4,160	1,450	6,100
PAH	7,030	1,400	9,440	2,920	1,900	1,160	7,430

Note: "—" denotes value below detection limit

* — refuse as fired

Table 17 Trace Metals in Ash per Performance Test Condition

STEAM LOAD :	LOW	INTERMEDIATE		NORMAL		HIGH	
OPERATION : TEST # :	GOOD 14	GOOD 2,10	VERY POOR 5	GOOD 8,9,11	POOR 3,4,7	GOOD 12	POOR 6
CONCENTRATION: ($\mu\text{g/g}$ of ash)							
<u>Dry Bottom Ash</u>							
Antimony	1.7	–	1.1	1.9	0.4	2.1	–
Arsenic	12	10	10	10	8	14	8
Cadmium	9.1	6	6	7	7	4	5
Chromium	316	184	196	204	232	189	158
Copper	4,370	6,710	3,840	4,550	2,780	16,100	1,120
Lead	3,600	1,250	1,910	2,400	1,600	1,290	1,020
Mercury	–	0.041	–	–	0.102	0.026	0.322
Nickel	333	337	294	211	172	172	96
Zinc	1,880	1,620	1,150	1,400	1,200	1,100	1,260
<u>Grate Sifting Ash</u>							
Antimony	21	26	25	37	45	23	44
Arsenic	10	10	8.1	11	8.7	13	9.4
Cadmium	8.8	8.7	11	10	11	13	12
Chromium	297	409	454	282	337	192	284
Copper	3,960	9,370	956	2,340	1,540	1,620	11,500
Lead	8,550	12,900	3,880	9,730	7,710	8,560	16,800
Mercury	0.56	0.46	2.02	0.98	1.81	0.76	1.02
Nickel	432	693	1,136	401	337	253	303
Zinc	1,630	3,240	1,790	2,280	4,210	1,930	2,800
<u>Economizer Ash</u>							
Antimony	8.1	10	13	3.2	8.9	2.7	9.3
Arsenic	14	12	15	11	12	12	18
Cadmium	6.5	8.0	5.9	7.3	7.0	8.9	6.2
Chromium	310	245	330	400	307	210	150
Copper	1,130	660	679	1,540	606	580	509
Lead	940	785	949	923	949	979	659
Mercury	0.028	0.011	0.02	0.014	0.019	–	0.024
Nickel	660	355	1,289	377	396	260	170
Zinc	1,820	1,200	1,410	1,930	1,520	1,350	1,760
<u>Fabric Filter Ash</u>							
Antimony	17	10	9.0	12	8.9	8.2	10
Arsenic	21	19	15	20	18	16	19
Cadmium	98	87	70	93	93	138	96
Chromium	226	274	264	245	163	187	154
Copper	600	637	431	676	355	365	374
Lead	2,750	2,350	1,990	3,130	3,230	2,870	3,670
Mercury	45	14	25	31	43	32	36
Nickel	541	304	744	415	239	246	374
Zinc	7,870	5,880	5,460	6,970	7,830	4,810	9,790

Note: "–" denotes value below detection limit

efficiencies of the organics are listed in Table 18. The average net destruction efficiency was determined by first subtracting the mass rate of the inputs from the sum total mass rate of the outputs and dividing by inputs. Negative values, such as those noted for PCDF and CB, indicate a net increase (formation) of a particular class of compounds.

For all organics except chlorobenzene, greater destruction is achieved for good combustion than for poor combustion. An overall net destruction efficiency for the combined tests was found to be 94.5%. Similar results were obtained for the net destruction efficiencies from the Quebec City combustion tests (Environment Canada, 1988). The Quebec City unit is a mass burn municipal waste incinerator with an electrostatic precipitator (ESP). The input/output for each stream for dioxins and furans is shown in Figure 13. Each bar in the figure represents the average amount (mg/h) of quantified organic material found

in each stream during these tests. Note that the concentrations of organics in the incinerator ash, economizer ash, and stack emissions are extremely low. Also note slightly greater output levels of organic material during poor combustion as compared to good combustion.

5.5 Formation of Nitrogen Oxides (NO_x)

In modern municipal waste combustors, there is a general tendency to produce higher temperatures and better mixing in the combustor to reduce carbon monoxide (CO) and organic emissions. The higher temperatures and better mixing also lead to higher NO_x emissions. The trade-off between CO and NO_x emissions is shown in Figure 14. This figure contains 30-second readings from the continuous emission monitors for performance tests 3 and 9. For both good and poor combustion tests, low NO_x emissions correspond to high CO

Table 18 Destruction of Organics by Combustion

Organics	Poor Combustion 5 Tests (%)	Good Combustion 7 Tests (%)	Combined Conditions 12 Tests (%)
PCDD	74.3	80.6	77.3
PCDF	-6668*	-1076*	-2143*
PCDD/PCDF	-2.2*	17.0	7.1
CB	88.1	-81.6*	79.4
PCB	99.8	99.95	99.9
CP	74.8	84.4	78.8
PAH	93.2	97.2	96.0
Average	90.5	96.4	94.5

* indicates formation




Figure 13 Input/Output Analysis for PCDD and PCDF





Figure 14 Carbon Monoxide versus Nitrogen Oxides in Flue Gas at Spray Dryer Inlet


emissions and low CO emissions correspond to high NO_x emissions.

The test average CO versus NO_x is shown in Figure 15. Note that the plots are not linear but hyperbolic. Therefore, a region exists at the base of the curve where moderate CO and NO_x emissions are achievable. By using a second order curve fit on the data (good combustion, normal load), a minimum average CO emission value of 71 ppm can be estimated to maintain a maximum average NO_x concentration of 180 ppm (all new MWCs over 225 Mg/day in the U.S. must comply with an NO_x limit of 180 ppm).

5.6 Furnace Formation of PCDD/PCDF

The two predominant theories regarding PCDD/PCDF formation are (1) that

PCDD/PCDF is associated with the entrained particulate matter (PM) leaving the furnace, and (2) that PCDD/PCDF is formed in greater quantities during combustion upsets (or during periods of high CO emissions). The following analysis of the test data will show that, during periods of good combustion, a parameter indicating PCDD/PCDF formation in the furnace is the amount of entrained particulate matter exiting the furnace. For periods of poor combustion, the predominant parameter with which PCDD/PCDF formation is correlated is the level of organic matter escaping the furnace, as indicated by elevated carbon monoxide (CO) or total hydrocarbon (THC) concentrations. Accordingly, reducing PM carryover, and the frequency and magnitude of CO excursions, will result in lower PCDD/PCDF concentrations before pollution control.



Values corrected to 12% CO₂

Figure 15 Test Average Carbon Monoxide versus Nitrogen Oxides

5.6.1 Good Combustion - Effects of Entrained Particulate Matter


Data from the Mid-Connecticut test program show a fair correlation ($R^2 = 0.61$) between entrained particulate matter and PCDD/PCDF at the spray dryer inlet for test conditions of good combustion. As shown in Figure 16, PCDD/PCDF increases with increasing carryover of particulate matter. This supports the findings from other MWC test programs at Quebec City (Environment Canada, 1988) and Montgomery County (Kilgroe *et al.*, 1992), and the belief that the concentration of PCDD/PCDF leaving the stack is associated with the relative concentration of entrained particulate matter leaving the combustor. One possible interpretation is that the particulate matter provides all or some of the necessary components for forming PCDD/PCDF. These components may include reaction sites (surface area), metallic promoters, and organic precursor material (probably fused

ring structures). Therefore, reducing carryover of particulate matter will reduce uncontrolled PCDD/PCDF emissions.

It should be noted that the relationship between entrained particulate matter and PCDD/PCDF emissions is significant only for good combustion. When all combustion test conditions are examined, no statistically significant relationship is found ($R^2 = 0.17$). The relationship for all test conditions is shown in Figure 17. The scatter is great. During times of poor combustion, parameters other than PM carryover provide better prediction of the concentration of PCDD/PCDF leaving the combustor, as discussed in Subsection 5.6.2.


5.6.2 Poor Combustion - Effects of Carbon Monoxide Emissions

The level of carbon monoxide is a direct indicator of combustion efficiency. High levels of CO imply that the flue gases were



Values corrected to 12% CO₂

Figure 16 PCDD/PCDF versus Particulate at Spray Dryer Inlet for Good Combustion Conditions




Values corrected to 12% CO₂

Figure 17 PCDD/PCDF versus Particulate at Spray Dryer Inlet for all Tests

not held at a high temperature in the presence of oxygen for a sufficient time period to convert the CO to CO₂. Very high levels of CO correspond with an increase in total hydrocarbon (THC) emissions and other organics, such as volatile compounds, semi-volatile compounds, and soot. It is this organic material that is believed to be converted into PCDD/PCDF.


The theory that higher levels of organic material escaping the furnace lead to greater levels of PCDD/PCDF was first examined by plotting the average CO and THC concentration versus the PCDD/PCDF concentration. As can be seen in Figures 18 and 19, there is a strong correlation between CO, THC, and PCDD/PCDF. Note that the correlation appears stronger for poor combustion tests than for good combustion tests.

Poor combustion implies that greater amounts of organic material escape the combustor unburned. In the correlation between CO and PCDD/PCDF, use of only the poor combustion tests would improve R² from 0.70 to 0.95. This can be interpreted to mean that, for all tests, the variation in CO emissions can be used to explain 70% of the variation in PCDD/PCDF from the furnace. For the poor combustion tests, however, 95% of the change in PCDD/PCDF values can be explained by the change in CO emissions. Similarly, the correlation between THC and PCDD/PCDF improved from an R² value of 0.68 when considering all test runs, to 0.97 for poor combustion tests only. These correlations are consistent with the theory that, during periods of poor combustion, the amount of organic matter escaping the furnace strongly influences the formation of PCDD/PCDF.



Values corrected to 12% CO₂

Figure 18 PCDD/PCDF versus Carbon Monoxide at Spray Dryer Inlet



Values corrected to 12% CO₂

Figure 19 PCDD/PCDF versus Total Hydrocarbon at Spray Dryer Inlet

The CO and THC data generated by the continuous emission monitors can be viewed as periods of stable combustion on which short periods of unstable combustion are superimposed, where CO and THC concentrations are substantially higher. One would expect higher concentrations of PCDD/PCDF for test conditions which had many combustion excursions. One method of evaluating the possible contribution of unstable combustion conditions (CO excursions) to PCDD/PCDF emissions is to examine the percentage of operating time above a given CO concentration. The correlations between portion of time above a given CO concentration and the PCDD/PCDF concentration was examined for increments of 50 ppm. It was found that the correlations steadily improve until the portion of time that CO is greater than 400 ppm was reached, where R^2 was 0.61. Above this value, only slight improvements in the correlations were observed. The amount of PCDD/PCDF versus percent time

that the CO exceeded 400 ppm is shown in Figure 20.

The test average CO value was a good indicator of other organic compounds besides PCDD/PCDF, such as chlorobenzene, chlorophenols, and polycyclic aromatic hydrocarbons. Uncontrolled emissions of all these organics increased with increasing CO concentration with an R^2 over 0.83. The plot of CO versus polychlorinated biphenyls showed no correlation, but this may be due to the extremely low concentrations measured ($<70 \text{ ng/Sm}^3$).

In summary, formation of PCDD/PCDF increased in the presence of greater levels of organic material as indicated by higher CO emissions. At low levels of CO (or small amounts of organic material), other factors, such as particulate matter carryover, probably played more important roles in determining the amount of PCDD/PCDF formed. As CO levels increased above




Figure 20 PCDD/PCDF at Spray Dryer Inlet versus Percent of Time Carbon Monoxide is Greater than 400 ppm

200 ppm, the amount of PCDD/PCDF increased. The formation appears to be more strongly related to absolute CO levels than to excursions of CO above stable operation. Combustor temperature did not vary significantly and therefore it did not appear to affect organic emissions.

5.7 “Downstream” or Low Temperature Formation of PCDD/PCDF

Low temperature or “downstream” formation of PCDD/PCDF has been observed in many municipal waste combustors as the flue gas cools through the temperature range of 400 to 150°C (Schindler, 1989). At the Mid-Connecticut facility, the temperature range associated with maximum net formation rates occurs in the air preheater. During the testing program, four PCDD/PCDF samples were taken at the air preheater inlet for comparison with concentrations at the spray dryer inlet to evaluate the formation or destruction of PCDD/PCDF as flue gas and fly ash pass through the temperature range where low temperature formation of PCDD/PCDF has been observed in other experiments. The results are shown in Figure 21. Contrary to expectations, a decrease across the air preheater was observed in total PCDD/PCDF for all test runs, with only PCDD increasing during test 10.

The observed reduction at this facility may be related to the short time the entrained particulate matter is held in the formation temperature range. The residence time of the flue gas in the air preheater is only 1.5 to 2 seconds. The flue gases pass through the peak formation temperature (572°F) somewhere within the air preheater. This short time of less than two seconds may not

allow significant formation of PCDD/PCDF to occur. In addition, it may be speculated that the observed reduction in PCDD/PCDF concentration is also due to decomposition in the duct before the air preheater.

Another possible explanation is artifact formation of PCDD/PCDF in the sampling probe used at the air heater inlet. The flue gas temperature at the exit of the economizer averaged from 371 to 388°C. Therefore, the gases must pass through the low temperature formation window before entering the constant temperature filters (121°C) of the sampling train. It is possible that PCDD/PCDF is formed in the probe. The actual preheater inlet concentrations may thus be lower than the spray dryer inlet concentrations and PCDD/PCDF may form across the air heater. Artifact formation would be expected to have a less significant impact when sampling at temperatures less than 150°C, such as at the spray dryer inlet.

5.8 Effects of Carbon in Ash on PCDD/PCDF Concentrations

Economizer ash hopper samples were subjected to weight loss-on-ignition (LOI) tests to provide information that could be used to evaluate correlations between organic material in the ash and the amount of PCDD/PCDF leaving the combustor. The relationship of economizer ash LOI to PCDD/PCDF concentration at the spray dryer inlet is shown in Figure 22. As one would expect, the plot does show that the LOI (i.e., fraction that is carbon) is lower during good combustion than poor combustion test conditions. A positive correlation is observed between PCDD/PCDF concentrations and LOI, i.e., increased PCDD/PCDF appears to be associated with increased LOI. This is similar to laboratory results that have shown





Figure 21 PCDD and PCDF Levels Across Air Preheater




Figure 22 PCDD/PCDF at Spray Dryer Inlet versus Loss-on-Ignition of Economizer Ash

that the PCDD/PCDF formation potential in fly ash is proportional to the fly ash carbon content (Stieglitz and Vogg, 1990).

5.9 Parameters Affecting Emissions of Carbon Monoxide

Low CO emissions indicate good combustion conditions while high CO emissions correspond to poor combustion conditions. One of the objectives of the overall test program was to evaluate combustion system performance by determining: minimum achievable CO emissions; operating conditions resulting in low CO emissions (<200 ppm corrected to 12% CO₂); and potential methods of reducing CO emissions.

Average CO emissions of less than 150 ppm with steady state minimum CO emissions of

30 to 50 ppm were achievable over the tested range of boiler loads. The mode of overfire air system operations that consistently produced the best mixing and performance was identified for each boiler load. At the low and intermediate loads, the best performance as indicated by CO and THC emissions was achieved using two elevations of TOFA nozzles (no RW-OFA) and an OFA/UGA flow split of nearly 50/50. The best performance at normal and high load was achieved using two elevations of TOFA nozzle plus the RW-OFA nozzles (upper row only) and an OFA/UGA flow split of nearly 50/50. Average CO levels for good combustion conditions are moderately sensitive to the UFA/UGA flow split. All other combinations tried produced poorer results.

Operating oxygen levels also had an impact on CO emissions. High CO emissions

occurred when operating with too much or too little combustion air. This finding suggests that improving the system control and maintaining the operating O₂ level within a narrower range (less than 4% O₂ variation) would result in lower overall CO emissions.

5.10 Multiple Regression Analysis - Combustion System

5.10.1 Overview

As described in Section 4, statistical analysis is an important technique used to study the performance test data obtained. The primary goals for applying statistical analyses to the combustion system were to determine which emissions and operating parameters can be used as surrogate indicators for predicting trace organic emissions from the combustor, and to identify how various combustor operating parameters affected emissions from the combustor (before treatment in the APC system).

This resulted in the development of two types of models:

- (a) **prediction models** that provide a method to **predict** trace organic emissions from the combustor by **monitoring** more readily measurable parameters; and
- (b) **control models** that identify combustor operating variables which can be adjusted to **control** and **minimize** the formation and release of trace organics from the combustor.

For the combustion system, the concentration of each of the trace organics at the spray dryer inlet was selected as the dependent variable for modelling by linear regression analysis.

The independent variables were separated into two groups. Those that were used to generate **prediction models** are referred to as the “monitoring variables”. Those that were used to generate the **control models** are referred to as the “control variables”.

The monitoring variables for the prediction models are: carbon monoxide; nitrogen oxides; water; oxygen; total hydrocarbons; hydrogen chloride; sulphur dioxide; furnace temperature; boiler temperature; economizer temperature; and air preheater gas outlet temperature.

Some of the control variables or operational settings for the control model include: total undergrate air flow; main steam flow; rear wall air flow; total overfire air flow; and RDF moisture.

The final number of variables used in the “best fit” models was based on the reviewers’ experience and judgement. In most of the cases, three-variable models were chosen as being adequate. In a few cases, two-variable or four-variable models were selected as the best fit.

Some of the models are illustrated in this section using graphs that show a straight diagonal line to mark the position of a perfect match between the measured values and the calculated values. Data points represented by numbers 2 to 14 correspond to the performance test runs PT-02 to PT-14. The models for each of the organics examined can be better understood by examining these graphs. The closer the numbers are to the diagonal, the stronger the model.

Two parallel lines have been placed on each side of the diagonal of these graphs: one above and one below the perfect fit diagonal. These are each displaced from the perfect fit

by a distance equal to the average of the absolute values of all the residuals. The band formed by these lines is called the residual band and is used to visually represent the R^2 value. The residual band has no statistical significance beyond the purpose of visual comparisons between correlation models. The narrower the residual band, the closer the numbers approach the diagonal and, therefore, the higher the R^2 values and the better the model. As more variables are added to the model, the residual band should become narrower or else the model should be rejected. A wide residual band indicates a poor model.

The tables that accompany the figures show the progressive increase in R^2 values achieved by going from a one-variable model to a two-variable model, three-variable model and four-variable model. The best fit model is highlighted in each table.

5.10.2 Dioxin Models

As shown in Table 19, the prediction model for PCDD that used NO_x , CO, and moisture in the flue gas resulted in one of the highest R^2 values (0.89). As shown in Figure 23, this model has a narrow residual band with most of the points falling within these bands.

A similar model using NO_x , CO, moisture in the flue gas, and furnace temperature resulted in a higher R^2 (0.928). As discussed earlier, concentrations of PCDD before the APC are related to unburned organic material. The four variables that gave the best fit are indicators of or directly influence the completeness of the combustion process.

Unfortunately, the control models do not provide correlations that are as strong as those for the monitoring variable models. As shown in Table 20, maximum R^2 was

0.67. The model variables that provide the strongest correlations are combustion air flows and RDF moisture. These parameters also influence mixing and combustion completeness. It may be assumed then that some reduction in PCDD could be achieved by effective control of these parameters.

5.10.3 Furan Models

The variables that produced very good predictions of PCDD concentrations at the spray dryer inlet also produced good predictions of PCDF at the spray dryer inlet. For the monitoring model with the highest R^2 (0.811), three of the four variables (CO, H_2O , and furnace temperature) are indicators of combustion conditions. The fourth variable is HCl. As discussed earlier, the amount of chlorine in the refuse is believed to influence the formation of PCDD/PCDF. High concentration of chlorine can also suppress combustion reaction rates. The best three-variable monitoring models for PCDF ($R^2=0.78$) are shown in Figure 24. This model uses CO, NO_x , and moisture.

The control models for PCDF concentrations at the spray dryer inlet use the same variables as the control models for PCDD, i.e., combustion air flows and RDF moisture. Maximum R^2 was 0.67.

5.10.4 Models for Other Trace Organics

The monitoring models to predict concentrations of chlorophenols (CPs), chlorobenzenes (CBs), and polycyclic aromatic hydrocarbons (PAHs) from the combustion system (before APC) typically contained variables that are indicators of combustion performance, i.e., CO, THC, or NO_x . Many of these models also contained expressions for moisture variables (RDF moisture content or flue gas moisture content) that directly or indirectly affect combustion conditions. The R^2 for the best

Table 19 Multiple Regression for PCDD and Spray Dryer Inlet - Prediction Models

R ²	Variables in Model			
	CO (Corrected)	NO _x (SDI)	H ₂ O (SDI)	Furnace Temperature
0.79	X			
0.82	X	X		
0.89	X	X	X	
0.93	X	X	X	X


**Figure 23 Calculated PCDD versus Measured PCDD at Spray Dryer Inlet - Prediction Model**

Table 20 Multiple Regression for PCDD at Spray Dryer Inlet - Control Models

R ²	Variables in Model			
	RDF Moisture	Rear Wall Over Fire Wall	Undergate Air Flow	Total Air
0.31	X			
0.39	X	X		
0.59	X	X	X	
0.67	X	X	X	X

models was typically 0.96 to 0.97. Further details on these prediction models are in Volume II of the report series (Environment Canada, 1991).

The best control models for CP, CB, and PAH for the most part also contain variables that are related to combustion difficulties (a high RDF moisture content) or combustion air flow distribution problems. Further evaluation of the effects of RDF moisture

content and combustion air variables leads to the conclusion that organic emissions from the combustor are strongly related to combustion conditions in the lower furnace. The best control models had R² values of 0.83 for CP, 0.81 for CB, and 0.66 for PAH. Further details are in Volume II of the report series (Environment Canada, 1991). Good predictive or control models were not found for PCB emissions from the combustion system.

BEST 3 MONITORING VARIABLES




Figure 24 Calculated PCDF versus Measured PCDF at Spray Dryer Inlet - Prediction Model

Section 6

Performance Test Series for Air Pollution Control System

6.1 Overview

In this section the performance test results and key findings for the air pollution control system, including concentrations at the inlet to the APC system (i.e., spray dryer inlet) and emissions from the fabric filter to the stack are summarized. The APC system test series consists of the same 13 PT runs discussed in Section 5. As shown in Figure 25, however, these tests have been regrouped into the nine different operating conditions of the air pollution control equipment. The data discussed in this section pertain only to the APC system, whereas the data in Section 5 were relevant only to the combustion system. Concentrations at the spray dryer inlet are common to both systems and are used in both sections.

One objective of the PT tests for the APC system was to evaluate emissions and pollutant removal efficiency at different flue gas temperatures and lime addition rates (i.e., stoichiometric ratio). Sulphur dioxide concentration at the fabric filter outlet was used as a surrogate for stoichiometric ratio. Due to budget constraints, it was not possible to do duplicate runs for each of the nine test conditions.

6.2 Summary by Performance Test Run

Some of the key data generated during each PT run for the APC system are summarized in Tables 21 and 22. Specifically, key process data for the APC system, such as flue gas temperatures, pressure drops, lime slurry parameters, and flue gas flow rates are

presented in Table 21. Some of the emission data at the inlet and outlet of the spray dryer and at the fabric filter outlet are presented in Table 22. More detailed test results for each PT run are presented in Appendix A and in Volume II of the report series, (Environment Canada, 1991).

The PT runs for the APC system are categorized by flue gas temperature at the spray dryer outlet (low, medium, and high) and SO₂ concentration at the fabric filter outlet (which serves as a surrogate indicator of lime stoichiometry).

6.3 Summary by Performance Test Condition

Key performance test data for the APC system for each of the nine operating conditions are shown in the nine figures in Appendix C. These data are discussed in small segments in this section.

6.3.1 Air Pollution Control Process Data

Key process data for the APC system, including flue gas temperature, slurry flow, and SO₂ at the fabric filter outlet (which is an indicator of lime stoichiometry) are presented in Table 23. The APC test conditions are grouped into three broad categories based on the temperature of flue gas at spray dryer absorber outlet: low (120°C), medium (140°C), and high (165 to 170°C). These three temperature ranges were selected to indicate the effect of the degree of cooling of the flue gas (i.e., temperature at the spray dryer outlet) on the overall removal of pollutants by the APC system. For the low temperature category,




Figure 25 Performance Test Key Operating Parameters for Air Pollution Control System Test Series

Table 21 Key Process Data for Air Pollution Control System per Performance Test Run

SO2 AT FFO TEST #	SDO LOW TEMPERATURE				SDO MEDIUM TEMPERATURE					SDO HIGH TEMPERATURE			
	LOW PT-07	MED PT-10	HIGH PT-02	HIGH PT-05	LOW PT-06	MED PT-12	MED PT-13	MED PT-14	HIGH PT-08	LOW PT-03	LOW PT-11	MED PT-04	HIGH PT-09
PROCESS TEMPERATURES													
A/H GAS OUTLET TEMP. (°C)	204	193	192	190	185	197	179	193	203	208	187	193	193
SDA OUTLET TEMP (°C)	124	123	123	122	141	141	141	141	142	166	166	166	171
BAGHOUSE OUTLET TEMP. (°C)	106	106	107	104	123	119	112	119	118	139	140	142	140
OTHER APC DATA													
SDA PRESSURE DROP (Pa)	1200	1075	1050	925	1150	1050	750	825	1100	1075	1025	1075	1025
BAGHOUSE PRESSURE DROP (Pa)	950	975	900	900	925	975	900	900	950	975	975	950	975
ATOM. SLURRY FLOW (l/min)	125	102	102	91	76	91	61	75	91	64	45	45	34
SLURRY FEED (l/min)	17.0	7.2	8.7	1.9	30.0	9.5	9.5	7.9	8.3	28.0	27.0	23.0	7.2
LIME SLURRY DENSITY (g/l)	1560	1560	1440	1500	1440	1560	1560	1560	1560	1560	1560	1560	1560
FLUE GAS FLOW RATE													
AIR HEATER INLET													
MM5 SAMPLING TRAIN: Sm³/hr	139,000	137,000	NC	NC	NC	NC	NC	NC	131,000	NC	NC	NC	129,000
SPRAY DRYER INLET													
MM5 SAMPLING TRAIN: Sm³/hr	158,000	154,000	151,000	146,000	160,000	143,000	132,000	141,000	149,000	148,000	145,000	153,000	145,000
METALS SAMPLING TRAIN: Sm³/hr	158,000	156,000	155,000	148,000	162,000	145,000	123,000	137,000	151,000	147,000	148,000	156,000	148,000
FABRIC FILTER OUTLET													
MM5 SAMPLING TRAIN: Sm³/hr	171,000	168,000	166,000	153,000	173,000	167,000	153,000	150,000	163,000	165,000	158,000	167,000	163,000
METALS SAMPLING TRAIN: Sm³/hr	175,000	167,000	163,000	155,000	171,000	174,000	142,000	146,000	165,000	162,000	161,000	165,000	163,000

Notes: NC – Data not collected

Table 22 Key Concentration Data for Air Pollution Control System per Performance Test Run

SO2 AT FFO TEST #	SDO LOW TEMPERATURE				SDO MEDIUM TEMPERATURE					SDO HIGH TEMPERATURE			
	LOW PT-07	MED PT-10	HIGH PT-02	HIGH PT-05	LOW PT-06	MED PT-12	MED PT-13	MED PT-14	HIGH PT-08	LOW PT-03	LOW PT-11	MED PT-04	HIGH PT-09
SPRAY DRYER INLET													
* SO2 ppm	182.9	193.6	177.4	169.1	191.6	197.5	175.4	188.9	183.5	199.9	174.3	185.6	177.9
* HCl ppm	399.4	428.6	472.3	468.7	404.4	469.5	421.4	442.3	538.2	419.0	413.3	471.3	431.5
* THC ppm	13.3	1.6	3.3	52.4	28.6	6.1	6.4	3.0	3.0	20.1	1.5	7.7	5.4
Moisture %	NA	13.8	13.6	15.5	14.7	16.0	12.2	12.2	16.2	17.8	15.0	14.8	17.5
PCDD (ng/Sm³ *)	207	243	213	580	317	67	147	72	211	230	92	151	71
(mg/tonne **)	1.25	1.26	1.01	2.86	1.76	0.36	0.76	0.45	1.08	1.11	0.51	0.74	0.33
PCDF (ng/Sm³ *)	796	424	733	1281	885	215	452	356	951	778	444	623	378
(mg/tonne **)	4.80	2.19	3.48	6.32	4.92	1.18	2.35	2.23	4.87	3.75	2.46	3.08	1.78
Mercury (µg/Sm³*)	584	718	726	634	583	558	531	914	646	583	661	614	644
(g/tonne **)	3.53	3.76	3.54	3.18	3.30	3.10	2.58	5.57	3.35	2.79	3.71	3.10	3.10
Particulate (µg/Sm³*)	4,230,000	4,530,000	5,440,000	4,460,000	3,310,000	3,390,000	3,210,000	3,700,000	4,750,000	4,640,000	3,980,000	3,270,000	3,890,000
(g/tonne **)	25,600	23,700	26,500	22,400	18,700	18,900	15,600	22,500	24,600	22,200	22,400	16,500	18,800
SPRAY DRYER OUTLET													
* SO2 ppm	127.3	131.4	NA	165.0	108.0	133.9	107.6	166.5	163.3	141.2	73.7	NA	158.7
* HCl ppm	9.5	15.2	44.2	55.8	19.7	37.1	12.9	46.1	44.1	23.2	8.4	44.5	145.5
FABRIC FILTER OUTLET (STACK)													
* + CO ppm	387	77	108	903	397	116	158	70	89	432	68	214	92
* SO2 ppm	17.0	73.7	110.0	131.8	8.7	62.5	29.0	84.5	126.3	13.1	19.5	44.4	188.8
* HCl ppm	7.7	18.8	20.0	20.9	10.2	16.7	18.4	20.0	40.6	17.5	23.1	30.8	98.2
* THC ppm	12.4	1.9	1.4	35.3	26.1	5.4	1.8	NA	1.6	14.9	2.3	5.1	8.5
PCDD (ng/Sm³ *)	0.167	0.181	0.079	0.371	0.346	0.067	0.108	0.012	0.286	0.562	0.131	0.368	0.582
(µg/tonne**)	0.93	0.89	0.37	1.68	1.86	0.36	0.57	0.07	1.41	2.71	0.69	1.83	2.71
PCDF (ng/Sm³ *)	0.145	0.103	0.121	1.124	0.162	0.075	0.269	0.020	0.467	0.376	0.194	0.486	0.495
(µg/tonne**)	0.81	0.50	0.56	5.09	0.87	0.41	1.42	0.12	2.30	1.81	1.02	2.43	2.30
VOST (ng/Sm³ *)	984,000	151,000	53,500	3,370,000	175,000	685,000	100,000	56,200	253,000	606,000	59,800	307,000	416,000
(µg/tonne**)	5,580	735	247	15,300	929	3,820	512	325	1,260	2,900	316	1,520	1,930
Mercury (µg/Sm³*)	7.4	8.4	6.5	6.8	11.5	3.2	11.0	13.4	4.2	21.4	17.8	13.4	14.1
(g/tonne **)	0.042	0.041	0.030	0.031	0.061	0.018	0.054	0.076	0.021	0.102	0.095	0.066	0.066
Particulate (µg/Sm³*)	4,390	4,090	5,770	3,880	2,680	3,980	7,690	4,720	3,880	5,500	5,700	7,620	5,790
(g/tonne **)	25.2	19.9	26.4	17.8	14.2	22.7	37.9	26.9	19.4	26.1	30.4	37.6	26.9

NA = not available

* - Corrected to 12% CO2

** - Refuse as fired

+ - Reconstructed from measurements at SD inlet and FF outlet.

Table 23 Key Process Data for Air Pollution Control System per Performance Test Condition

	SDO Low Temp (120°C)			SDO Medium Temp (140°C)			SDO High Temp (165°C)		
	Low	Med	High	Low	Med	High	Low	Med	High
SO ₂ at FFO - Target									
- Actual (ppm)	17	74	121	9	59	126	17	44	189
Test Number	7	10	2, 5	6	12,13,14	8	3,11	4	9
SDI Temp (°C)	204	193	191	185	190	203	198	190	193
SDO Temp (°C)	124	123	122	141	140	142	165	166	170
FFO Temp (°C)	106	106	106	123	117	118	140	142	140
SD Pressure Drop (Pa)	1200	1075	1000	1200	875	1100	1050	1075	1025
Baghouse Pressure Drop (Pa)	950	975	900	925	950	950	975	950	975
Atomizer Slurry flow (L/min)	125	120	98	76	76	91	57	45	34
Slurry Feed (L/min)	17	7.2	5.3	30	9	8.3	28	23	7.2

atomizing slurry flow was highest (98 to 125 L/min). For the high temperature category, atomizing slurry flow was lowest (34 to 57 L/min) and provided less cooling of the flue gas, as desired for test purposes.

Within each of the temperature categories, the amount of lime was allowed to vary from very low to medium to a high amount [which is indicated by high SO₂ (over 100 ppm), medium SO₂, (21 to 100 ppm), and low SO₂ concentrations (under 20 ppm) at the fabric filter outlet]. Since lime stoichiometric ratio was not readily known, SO₂ concentration at the fabric filter outlet was used as a surrogate, which immediately indicated the relative amount of lime used.

6.3.2 Continuous Emissions Monitoring (CEM) Data

The CEM data for SO₂, HCl, and THC are summarized in Table 24 for each PT condition of the APC system. This includes CEM data at spray dryer inlet (SDI), spray

dryer outlet (SDO), and fabric filter outlet (FFO).

Sulphur dioxide concentrations at the spray dryer inlet (i.e., from the combustor) ranged from 170 to 200 ppm, which is typical for MSW incinerators. Sulphur dioxide was between 100 and 160 ppm at the SDO and between 9 and 190 ppm at the FFO, depending on the flue gas temperature and the amount of lime used. Sulphur dioxide removal efficiency is illustrated in Figure 26. Clearly, SO₂ removal by the APC system can be easily controlled and can range from good removal (over 90% and less than 20 ppm at stack) to poor removal (under 20% and more than 100 ppm at stack), depending on operating conditions selected for the spray dryer and fabric filter. As shown in Figure 26, up to 60% of SO₂ removal occurs across the spray dryer, the balance occurring across the fabric filter.

Table 24 Continuous Emissions Monitoring Data for Air Pollution Control System per Performance Test Condition

	SDO Low Temp (120°C)			SDO Medium Temp (140°C)			SDO High Temp (165°C)		
	Low	Med	High	Low	Med	High	Low	Med	High
SO ₂ at FFO - Target									
Test Number	7	10	2, 5	6	12,13,14	8	3,11	4	9
Spray Dryer Inlet (ppm at 12% CO ₂)									
- SO ₂	183	194	173	192	187	184	187	186	178
- HCl	399	429	470	404	445	538	416	471	432
- THC	13	2	29	29	5	3	11	8	5
Spray Dryer Outlet (ppm at 12% CO ₂)									
- SO ₂	127	131	NA	108	136	163	107	NA	159
- HCl	10	15	50	20	32	44	15	45	146
Fabric Filter Outlet (ppm at 12% CO ₂)									
- SO ₂	17	74	121	9	59	126	17	44	189
- HCl	8	19	20	10	18	41	21	31	98
- THC	12	2	19	26	3	2	9	5	9

Hydrogen chloride concentrations at the SDI (i.e., from combustor) ranged from 400 to 540 ppm, which is typical for MSW incinerators. Hydrogen chloride was between 10 and 50 ppm at the SDO for all PT conditions (except PT9 at 146 ppm) and 8 to 40 ppm at the FFO for all PT conditions (except PT9 at 98 ppm). Hydrogen chloride removal efficiency is illustrated in Figure 27. It is clear that HCl removal over 95% and stack emissions below 20 ppm are possible, depending on the operating conditions selected for the spray dryer and fabric filter. Because of its high reactivity, HCl removal exceeded 92%, even when there was low SO₂ removal of 20%. Most of the HCl removal occurred across the spray dryer; the

fabric filter accounted for less than 10% removal of the total HCl. A more detailed discussion of operating variables for removal of SO₂ and HCl is provided in Subsection 6.4.

6.3.3 Trace Organic Concentrations

Trace organic concentrations at the SDI (i.e., leaving the combustor) and at the FFO (i.e., after the APC system) are summarized in Table 25 for the different PT conditions of the APC system.

PCDD was reduced from a range of 70 to 400 ng/Sm³ to less than 0.6 ng/Sm³. This is a PCDD removal efficiency of more than 99.7% in all cases (except for PT9 at 99.2%).




Figure 26 Sulphur Dioxide Removal Efficiency per Performance Test Run




Figure 27 Hydrogen Chloride Removal Efficiency per Performance Test Run

PCDF was reduced from a range of 300 to 1000 ng/Sm³ to less than 0.6 ng/Sm³ in all cases, except PT5 at 1.1 ng/Sm³. The removal efficiency for PCDF exceeded 99.9% for all test runs.

In summary PCDD/PCDF removal was consistently high for all test runs and APC operating conditions. Because PCDD/PCDF removal was so high, it is difficult to distinguish whether process operating parameters had any significant effect on removal efficiency or whether differences in

removal efficiency are due to limits in sampling and analytical precision. Statistical analysis for correlations and multiple regression analysis indicated that APC operating conditions appeared to have little, if any, effect on PCDD/PCDF control. HCl concentration at FFO, FF pressure drop, and SD outlet temperature appeared to have a weak impact on PCDD removal. As each of these parameters increased, PCDD removal decreased slightly. Note, however, that PCDD removal was over 99.2% in all cases.

Table 25 Concentrations of Trace Organics for Air Pollution Control System per Performance Test Condition

	SDO Low Temp (120°C)			SDO Medium Temp (140°C)			SDO High Temp (165°C)		
SO ₂ at FFO - Target	Low	Med	High	Low	Med	High	Low	Med	High
Test Number	7	10	2, 5	6	12,13,14	8	3,11	4	9
Spray Dryer Inlet (ng/Sm ³ @ 12% CO ₂)									
- PCDD	207	243	396	317	95	211	161	151	71
- PCDF	796	424	1 007	885	341	951	611	623	378
- PCB	17	13	23	12	ND	24	42	ND	6
- CB	7 100	6 200	10 900	9 400	4 600	7 100	6 200	6 000	4 800
- CP	25 200	16 200	62 900	41 600	14 400	20 200	20 800	17 000	11 300
- PAH	51 800	6 300	60 200	88 600	7 700	10 300	47 100	22 500	32 400
Fabric Filter Outlet (ng/Sm ³ @ 12% CO ₂)									
- PCDD	0.17	0.18	0.23	0.35	0.06	0.29	0.35	0.37	0.58
- PCDF	0.15	1.10	0.62	0.16	0.12	0.47	0.29	0.49	0.50
- PCB	ND	ND	ND	ND	ND	7	27	19	14
- CB	110	42	400	540	ND	110	290	90	110
- CP	230	80	1 600	1 300	90	190	190	170	390
- PAH	1 400	2 600	4 800	2 000	2 900	2 400	3 700	2 000	2 400

The data in Table 25 for CB, CP, and PAH concentrations are further summarized as follows:

	Spray Dryer Inlet (ng/Sm ³)	Fabric Filter Outlet (ng/Sm ³)
CB	5 000 to 11 000	100 to 500
CP	11 000 to 63 000	100 to 1 600
PAH	6 000 to 90 000	2 000 to 5 000

There is a wide variation in concentration at the spray dryer inlet. As discussed in Chapter 5, the higher values occurred under poor operating conditions of the combustor system. The significant reduction in CB, CP, and PAH concentrations across the APC system is apparent in the data presented. Removal efficiency of CB, CP, and PAH by the APC system was significant; over 94% for CB and CP, and over 60% for PAH. Low PAH removal efficiencies were typically associated with low PAH inlet concentrations.

PCB concentrations at both locations were relatively low; under 40 ng/Sm³. PCB was not detected at the fabric filter outlet (i.e., the stack) for almost all operating conditions, except where spray dryer outlet temperature was relatively high (i.e., 165°C).

6.3.4 Particulate/Metal Concentrations

The range of particulate and trace metal concentrations is summarized in Table 26, for the spray dryer inlet and the fabric filter outlet.

Particulate concentrations were reduced very significantly from a range of 3 210 to 5 440 mg/Sm³ at the SDI to 3 to 8 mg/Sm³ at

the FFO. This corresponds to a particulate removal efficiency that exceeds 99.7%. This is consistent with the good performance expected for the fabric filter dust collector (i.e., emissions below 10 mg/Sm³).

Trace metals were also significantly removed by the APC system, typically from thousands (µg/Sm³) to less than 90 µg/Sm³. Several metals (e.g., arsenic, antimony, cadmium, and zinc) showed non-detectable concentrations at the FFO. Accordingly, removal of all condensed trace metal was very high, except for nickel in run PT8 (84%). There is no obvious explanation for the lower removal efficiency of nickel for PT8. The removal of mercury exceeded 96% during all tests.

Due to the high removal efficiencies for particulate and metals, it is difficult to determine whether any differences in emissions or removal efficiency were due to process operating conditions or limitations in sampling/analytical precision. The removal of mercury was investigated further, as discussed in Subsection 6.4.

Table 26 Range of Concentrations for Particulate and Trace Metals

	Spray Dryer Inlet	Fabric Filter Outlet
Particulate (mg/Sm ³)	3 210 to 5 440	2.7 to 7.7
Trace Metals (µg/Sm ³)		
- Mercury	531 to 914	7 to 21
- Antimony	44 to 173	ND
- Arsenic	159 to 270	ND
- Cadmium	437 to 832	ND
- Chromium	353 to 1 095	8 to 32
- Copper	1 100 to 3 220	ND
- Lead	2 600 to 14 700	29 to 91
- Nickel	257 to 2 230	2 to 67
- Zinc	31 000 to 50 000	ND

6.4 Multiple Regression Analysis - Air Pollution Control System

The statistical analysis techniques described in Subsections 4.7 and 5.10 for the combustion system were also applied to the APC system. In particular, the process operating variables for the APC system that may affect acid gas removal (HCl and SO₂) and mercury removal are discussed in this section. The removal of other pollutants was also examined for relevant correlations, but no statistically significant relationships were found.

6.4.1 Air Pollution Control Operating Variables for Regression Analysis

One objective of the program was to determine the impact of APC system operating parameters on removal of acid gas and mercury.

The two process parameters generally having the greatest impact for acid gas control by lime spray dryer/fabric filters systems are the approach to adiabatic saturation temperature of the flue gas and the stoichiometric ratio of available alkali to acid gases.

In spray dryer systems, the adiabatic approach to saturation temperature provides an indication of the length of time wetted alkali remains reactive and is a function of the flue gas temperature and moisture content. As the flue gas temperature approaches the adiabatic saturation temperature, the reactivity of the sorbent decreases. Because of problems with directly monitoring adiabatic saturation temperature, the flue gas temperature at the SD or FF outlet is typically used for process control.

The stoichiometric alkali-to-acid gas ratio is a function of the total content of reactive alkali in added sorbent, fly ash, slaking, and slurry dilution water and the concentration of individual acid gases in the flue gas.

Due to limitations in determining the total alkali input to the spray dryer, calculation of stoichiometric sorbent feed rates was based on the alkalinity in the lime slurry alone. To help interpret SD/FF performance, two different stoichiometric ratio formulas were used. The first formula, referred to as the overall stoichiometric ratio (OSR), is the commonly used format for comparing moles of alkali to moles of acid gases:

$$\text{OSR} = \frac{\text{mol/h of Ca(OH)}_2}{\text{mol/h of SO}_2 + \frac{1}{2}(\text{mol/h of HCl})}$$

The second formula, referred to as the reduced stoichiometric ratio (RSR), recognizes that HCl is more reactive than SO₂, and that the amount of alkali available for reaction with SO₂ is a function of the amount of alkali remaining after reaction with HCl. Assuming 100% reaction of HCl with the alkali, RSR is defined as:

$$\text{RSR} = \frac{\text{mol/h of Ca(OH)}_2 - \frac{1}{2}(\text{mol/h of HCl})}{\text{mol/h of SO}_2}$$

6.4.2 Correlations for Removal of Sulphur Dioxide

In Figure 28, the SO₂ removal efficiency of the APC system is shown as a function of the Overall Stoichiometric Ratio (OSR). Although it is not shown here, a similar relationship was obtained for SO₂ removal versus Reduced Stoichiometric Ratio (RSR). There is a relevant dependence of SO₂ removal by the APC system on stoichiometric ratio.

The SO₂ removal is plotted versus OSR for the three flue gas temperatures in Figure 28.

The scatter of the points is such that the effect of flue gas temperature on SO₂ removal appears to be very weak for any selected SR value. However, multivariate analysis, as discussed next, does indicate that flue gas temperature has some effect on SO₂ removal by the APC system.

Based on multivariate analysis, a strong relationship ($R^2 = 0.90$) was found to predict SO₂ removal by the APC system versus overall SR and flue gas temperature at FFO. The statistical relationship is expressed as follows:

$$\ln(100 - \text{overall \% SO}_2 \text{ Removal}) = -1.3986 (\text{OSR}) + 0.0177 (\text{FFO Temperature}) + 0.6087$$

The performance of this prediction model using OSR and FFO temperature is illustrated in Figure 29, where the calculated values of SO₂ removal are plotted against the measured values of SO₂ removal.

Correlations of SO₂ removal across the spray dryer versus RSR and SO₂ removal across the fabric filter versus RSR were also completed and show a strong relationship between percent removal and RSR, as expected.

To examine the effect on SO₂ removal of HCl in the flue gas, SO₂ removal by the spray dryer versus HCl at SDI was plotted in Figure 30. This figure suggests that HCl levels may influence the SO₂ removal efficiency across the SD. Since HCl is more reactive with lime than is SO₂, the sorbent available for reaction with SO₂ depends on the HCl concentration for a given SR. Therefore, at higher HCl concentrations for a given SR, SO₂ removal will be lower. A similar relationship was found for SO₂ removal across the fabric filter versus HCl at SDO.




Figure 28 Sulphur Dioxide Removal by Air Pollution Control System versus Overall Stoichiometric Ratio (OSR), One Variable Model




Figure 29 Measured versus Calculated Overall Sulphur Dioxide Removal, Two Variable Model (Overall Stoichiometric Ratio and Fabric Filter Outlet Temperature)




Figure 30 Sulphur Dioxide Removal by Spray Dryer versus Hydrogen Chloride at Spray Dryer Inlet

Various other statistical relationships developed from multivariate analyses for SO₂ removal are discussed in Volume II of the report series (Environment Canada, 1991).

6.4.3 Correlations for Removal of Hydrogen Chloride

The HCl removal efficiency of the APC system is shown in Figure 31 as a function of the Overall Stoichiometric Ratio (OSR). The effect of SR on HCl removal appears to be rather small for the range tested. Flue gas temperature appears to affect HCl removal, as can be seen from lower HCl removal for the PT runs at 168°C versus 140°C or 124°C (i.e. points \diamond versus points \square or $+$). These relationships were further investigated by a multivariate analysis.

Based on multivariate analysis, a good relationship ($R^2 = 0.82$) was found for HCl removal by the APC system using the two variables of RSR and flue gas temperature at the spray dryer outlet. The statistical relationship is expressed as follows:

$$\ln(100 - \text{Overall \% HCl Removal}) = -0.270 (\text{RSR}) + 0.0186 (\text{SDO Temp.}) - 3.4111$$

This relationship is illustrated in Figure 32. Other statistical relationships for percentage of HCl removal are discussed in Volume II of the report series (Environment Canada, 1991).

6.4.4 Correlations for Removal of Trace Organics

As indicated in Subsection 6.3, APC operating conditions appeared to have little,




Figure 31 Overall Hydrogen Chloride Removal by Air Pollution Control System versus Overall Stoichiometric Ratio




Figure 32 Measured versus Calculated Overall Hydrogen Chloride Removal - Two Variable Model (Reduced Stoichiometric Ratio and Spray Dryer Outlet Temperature)

if any, effect on the removal of PCDD/PCDF by the APC system for the range tested. Based on statistical analyses, HCl at FFO, FF pressure drop and SDO temperature appeared to decrease PCDD removal slightly ($R^2 = 0.71$), when any of these parameters increased in value.

6.4.5 Correlations for Removal of Mercury

The removal of mercury by APC systems for municipal waste combustors has become an important issue to the industry. Some facilities have reported good mercury removal, whereas others have measured poor mercury removal. Accordingly, the PT data were analyzed statistically to identify parameters that may be relevant for good removal of mercury.

The operating parameters selected for analyses for mercury removal efficiency of the APC system were flue gas temperature, stoichiometric ratio, fabric filter pressure drop, and percentage of carbon in fabric filter ash (based on percentage in LOI).

Overall stoichiometric ratio versus mercury removal efficiency across the SD/FF system

are shown in Figure 33. The figure indicates that mercury removal decreased as OSR increased. This phenomenon suggests that chlorine may be stripped from $HgCl_2$ formed in the flue gas at higher stoichiometric ratios. As a result, volatile ionic Hg^{2+} may be liberated, resulting in increased mercury emissions. Because acid gas removal increases with increasing stoichiometric ratio, a tradeoff may exist between acid gas and mercury control levels.

The relationship between FF outlet temperature and mercury removal is shown in Figure 34. As shown in the figure, mercury removal decreased with increasing FF outlet temperature. It can be inferred that mercury condensation/adsorption decreased at higher flue gas temperatures and, as a result, less mercury was captured with the particulate matter.

Because there was little variation in the FF pressure drop and mercury removal was consistently high (more than 96%), no significant correlation was observed between these two parameters. No correlation was found with percentage of carbon in the FF ash (loss-on-ignition).




Figure 33 Overall Mercury Removal versus Overall Stoichiometric Ratio




Figure 34 Overall Mercury Removal versus Fabric Filter Outlet Temperature

Section 7

Ash Characterization Results

7.1 Overview

The four separate ash streams, namely bottom ash (BA), grate siftings (GS), economizer (EC) ash, and fabric filter (FF) ash, that were sampled during the 13 performance tests were further tested as part of an ash characterization program. It should be noted that the ash products generated by the facility are combined and are currently disposed in a monofill, but no sampling or analysis was done on this combined product.

This section provides highlights of major findings of the ash characterization program and discusses implications for facility operation, ash management, and recommendations for further study. The ash test program was conducted in three parts.

1. Analyses for trace organics and trace metals were conducted on ash samples from all 13 performance tests. Detailed results are included in Volume II (Environment Canada, 1991).
2. Chemical analyses of ash leachates generated using four different leaching/extraction tests were performed on samples from 5 of 13 performance tests. A complete discussion of these analyses is included in Volume V, Book #1 (Environment Canada, 1991).
3. Chemical analyses and engineering tests were performed on solidified mixtures of fabric filter ash, waste pozzolanic material, and Portland Type II cement. Solidification is one popular method for

ultimate disposal and use of ash from these facilities. A complete discussion of the results of the analyses and tests is given in Volume V, Book #2, (Environment Canada, 1991).

7.2 Chemical Composition Analyses

Trace organic concentrations in the ash streams for each performance test condition are presented in Section 5 and in Appendices A and B. The data are summarized in Table 27. Generally, there is a progressively significant increase in concentrations of all trace organics, except PAH, through the system, (i.e., highest for fabric filter ash and lowest for incinerator ash).

The range of distribution of most trace metals appears to be a function of thermal properties of the elements. Typically, for example, higher concentrations of relatively volatile trace metals, such as arsenic, cadmium, mercury, and zinc, were measured in the fabric filter ash than in the bottom ash/grate siftings. However, relatively heat-stable elements, such as chromium, copper, and nickel, were generally measured in higher concentrations in the bottom ash/grate siftings. For lead, the highest concentrations were measured in the grate siftings. A fair correlation ($R^2 > 0.5$) was observed between concentrations in the bottom ash and grate siftings and concentrations in the refuse. Complete data are provided in Volumes II and V (Environment Canada, 1991).

Additional analytical work to determine specific metal species present in the different

Table 27 Summary of Average Concentrations ($\mu\text{g/g}$) of Trace Metals in Ash

Metal	Dry Bottom Ash	Grate Siftings	Economizer	Fabric Filter Ash
Antimony	2	34	8	11
Arsenic	10	10	13	18
Cadmium	6	10	7	96
Chromium	211	325	301	216
Copper	5066	4036	888	491
Lead	1859	9645	893	2856
Mercury	0.15	1.2	0.02	34
Nickel	266	477	451	408
Zinc	136.9	2839	1591	6945

fractions might promote better understanding of the effect of operating conditions on metal distribution.

7.3 Acid Neutralization Capacity

The acid neutralization capacity (ANC) of a material is a measure of that material's capacity to resist changes in pH, which is a relevant factor with regard to leachability of trace metals. The average ANCs of the bottom ash, grate siftings, economizer ash, and fabric filter ash are shown in Figure 35. As shown in the figure, the fabric filter ash has higher buffering capacities than either the economizer ash or the bottom/grate siftings ash, which have very similar ANCs. The higher ANC values for the fabric filter ash are due to lime slurry being added to the flue gas stream in the spray dryer. The high ANC values mean that, in order to reduce the pH of fabric filter ash from its initial highly alkaline pH to a pH of 7.0, 1 g of the ash would have to come in contact with approximately 94 L of acidic precipitation. It is estimated that it would take about 70 years for the pH of a 1-cm layer of fabric filter ash to drop to a pH of 7.0. This

calculation is based on: an average precipitation pH of 4.5; an assumed average annual rainfall of 1000 mm/yr; an assumed compacted density for fabric filter ash of 0.75 g/cm^3 (Sawell *et al.*, 1989); and an assumed 100% infiltration rate of precipitation, which would be less in practice.

7.4 Leachability

Ash samples were subjected to the Sequential Batch Extraction Procedure (SBEP) to determine the potential organic and inorganic contaminant mobility in water over a wide range of liquid-to-solid ratios (20:1 to 100:1). Detailed information on the SBEP is contained in Volume V (Environment Canada, 1991).

7.4.1 Organic Contaminants

The maximum concentrations of organic contaminants in the composite leachates from the five cycles of the SBEP are presented in Table 28. Based on these results, the trace organic contaminants measured in the ashes are considered to be immobile in water.




Figure 35 Average Acid Neutralization Capacity Results

Table 28 Maximum Detected Concentration of Trace Organics in Leachates

Trace Organics	Bottom Ash /Grate Siftings	Economizer Ash	Fabric Filter Ash
PCDD (ppt)	0.16*	0.06*	0.4*
PCDF (ppt)	0.17*	0.08*	0.3*
PAH (ppb)	0.17	0.14	0.06
PCB (ppb)	ND	ND	ND
CP (ppb)	0.29	0.06	0.09
CB (ppb)	ND	ND	ND

ND = Not detected

* analyzed using high resolution GC/MS

No PCB or CB was detected in any of the leachates from the SBEP. Very low concentrations (less than 0.3 ppb) of CP and PAH were detected in the leachates from all three types of ash. No PCDD or PCDF was detected in the leachates using standard analytical techniques; however, extremely low concentrations (less than 0.4 ppt) were detected in most of the leachates analyzed using high resolution GC/MS. The detected organic compounds are not considered soluble and were probably strongly bound to sub-micron sized particles which were not removed during sample filtration.

7.4.2 Inorganic Contaminants

The solubility of the ashes in water was determined by the Sequential Batch Extraction Procedure. As shown in Figure 36, the results indicate that the bottom ash/grate siftings and economizer ash were much less soluble in distilled water (about 7% of the solid dissolved) than the fabric filter ash (about 34% dissolved). The

higher solubility of the fabric filter ash is due to the lime and soluble flue gas condensation/reaction products that sorb onto the fly ash particles in the air pollution control system. A significant portion of the dissolved material from the fabric filter ash consisted of sulphate and chloride (almost 14% sulphate and 27% chloride).

Metal solubility in distilled water was limited. No antimony, cadmium, cobalt, manganese, nickel, or selenium were detected in any of the leachates. Of those metals that were detected, most represented small fractions (less than 10%) of the concentrations present in the ashes. Up to 60% of the very low concentrations of mercury present in the ashes was soluble during the SBEP. The limited solubility of the metals was due to the moderately alkaline pH of the leachates generated from the ashes. The different operating conditions did not appear to have any effect on metal leachability.




Figure 36 Average Cumulative Total Fraction of Solids Dissolved during the Sequential Batch Extraction Procedure

The leachability of metals from the ashes was also determined using the Sequential Chemical Extraction (SCE) Procedure, which is a step-wise separation of the total concentration of each metal into five distinct fractions using increasingly more aggressive leaching media to digest the solid material. The descriptions and interpretations related to each of the five fractions are summarized in Table 29.

Although the potential fraction of a metal measured in Fraction A is considered to be available for leaching upon contact with water, it is not indicative of the fraction that would be considered available for leaching under ash monofill disposal conditions over a prolonged period of time. The total potential fraction of a metal available for leaching under acidic conditions which may prevail in a municipal co-disposal landfill, is assumed to be represented by the sum of Fractions A and B. It must be emphasized that the results from this test are only potential fractions and that these cannot be construed as field leachate concentrations that may occur under the conditions

suggested (Table 29) and that the interpretations are assumed to be generalities.

Results from the SCE procedure indicate that none or only a very small fraction of the metals present in the ashes are considered available for leaching upon initial contact with water. Larger fractions of the metals are considered available for leaching under acidic conditions, especially in the fabric filter ash.

The SCE results indicate substantial differences in species profiles between the three types of ash. Slightly larger proportions of barium, copper, lead, manganese, and nickel were measured in Fractions A and B of the economizer ash than in Fractions A and B of the bottom ash/grate siftings ash. In turn, larger proportions of barium, cadmium, chromium, manganese, and zinc were measured in Fractions A and B of the fabric filter ash than in Fractions A and B of the economizer ash.

Table 29 Summary of Descriptions and Interpretations for the Sequential Chemical Extraction Procedure

Fraction	Description	Interpretation
A	– ion exchangeable	– immediately available for leaching
B	– surface oxide and carbonate bound ions	– potentially available for leaching under acidic conditions
C	– iron and manganese bound metal ions	– potentially available for leaching under severe reducing conditions
D	– sulphide and organic matter bound ions	– unavailable for leaching under normal leaching conditions
E	– residual metal ions	– unavailable for leaching

In the five test runs examined, there were no apparent differences in the species profiles for most metals in each ash type, with the notable exception of lead. The lead species profiles for bottom ash/grate siftings and fabric filter ash were considerably different from the “good” and “poor” incinerator operating condition runs.

The species profiles for the two types of ash from the five test runs are given in Figure 37. Over 20% of the lead in the bottom ash/grate siftings ash from PT5 and PT7 (poor operating conditions) were measured in Fractions A and B, whereas (with the exception of PT10) less than 9.3% of the lead in the bottom ash/grate siftings ash from the good operating condition runs was measured in these fractions. Conversely, larger proportions of lead were

measured in Fractions A and B of the fabric filter ash samples from PT8, PT9, or PT10 (good operating condition runs) than in those from the “poor” condition runs. These results indicate that the better operating conditions volatilized a greater proportion of the “heat reactive” lead from the waste which ultimately condensed out as potentially soluble lead compounds on the fabric filter ash particles.

The results from the Leach Procedure and the Toxicity Characteristic Leaching Procedure, Ontario Regulation 309 (Government of Ontario, 1990) indicate that if the ashes from this facility were subject to Ontario’s regulatory requirements, which they are not, some of the bottom ash/grate siftings samples (PT7 and PT8) and all of the fabric filter ash samples from this facility




Figure 37 Sequential Chemical Extraction Results for Lead from the Bottom Ash/Grate Siftings and Fabric Filter Ash

would require special handling and disposal due to the leachable lead in bottom ash/grate siftings and cadmium in the fabric filter ashes.

7.5 Evaluation of Solidified Fabric Filter Ash

Solidification of ash is of significant interest as a technique for ultimate disposal and use of ash from municipal waste combustion facilities. The long-term environmental suitability of solidified mixtures of fabric filter ash, Portland Cement Type II, and one of three types of waste pozzolanic material was characterized using chemical, leaching, and standard cement engineering tests. Optimal formulations were selected based on the criterion that minimum quantities of solidifying agents be used, while still maintaining a sufficient physical strength.

The physical properties of the solidified specimens were tested after 56 days of curing time using the following tests: moisture content; bulk density; solids specific gravity; hydraulic conductivity; unconfined compressive strength; and freeze/thaw weathering tests. The results indicate that the solidified formulations produced specimens that: (1) have a low volume change factor of about 1.0; (2) possess low hydraulic conductivities; (3) have sufficient unconfined compressive strength (greater than 345 kPa) for landfill disposal; and (4) are very durable.

The fabric filter ash and crushed samples of the three formulations were subjected to the Sequential Batch Extracting Procedure. The results indicate that solidification reduces the total solubility of the fabric filter ash beyond what would normally be expected due to dilution with the solidification agents. Much

of this reduction is due to the transformation of readily soluble sulphate compounds to insoluble gypsum.

For most metals, the fraction solubilized by SBEP represented less than 1.0% of the total concentration of each metal present in the solidified ash. This was much less than for the untreated fabric filter ash. Conversely, the solubility of aluminum and mercury in the solidified material was equal to or higher than in the untreated fabric filter ash and is probably due to the chloride or hydroxide forms of these metals which are soluble under highly alkaline conditions.

The leachates from the SBEP were subjected to two different types of biological toxicity tests, both of which are given in detail in Volume V (Environment Canada, 1991). Results indicated that solidification reduced the lethal toxicity of the fabric filter ash leachates. However, two of the solidification treatment leachates (i.e., cement kiln dust and coal fly ash) exhibited a genotoxic response. The appearance of a genotoxic response has not been explained.

Crushed samples of the three formulations were also subjected to the Government of Ontario Regulation 309 Leach Procedure and the Toxicity Characteristic Leaching Procedure [TCLP], (Government of Ontario, 1990). The results indicate that concentrations of all metals in the solidified ash leachates from both tests were well below the Ontario guideline limits whereas concentrations of cadmium in the untreated fabric filter ash leachates exceeded the Ontario guideline limit by a factor of 6. Therefore, the untreated fabric filter ash from this facility would be classified as "hazardous", whereas the treated ashes would be considered non-hazardous.

Section 8

Conclusions

8.1 Overview

Those significant findings and conclusions from the Mid-Connecticut test program that are likely to be of interest to the general public and researchers are presented in this section.

Readers should be aware that the combustion and air pollution control systems at the facility were deliberately operated over a wide range of conditions as part of the test program. It would not be appropriate, therefore, to “average the data” from many of the test runs when making judgments on normal operating conditions at this facility. Because of the time lag in collecting fabric filter ash, the elemental metal input/output or mass balance data are particularly difficult to reconcile. Nevertheless, general statements based on trends or ranges can be made when certain test data are carefully and scientifically grouped together. Also, it should be noted that the ash samples analyzed during this test program were taken from the location where the ash was generated. No testing of the combined ash product was conducted. This facility normally combines its ash for disposal.

8.2 General

1. Very low concentrations of trace organics, heavy metals, and acid gases in stack emissions were observed under all tested operating conditions. As an example, total PCDD/PCDF emissions were 1.5 ng/Sm³ or less in all tests.
2. High removal efficiencies were attained for trace organics in the flue gas during all measurements between the spray dryer inlet and fabric filter outlet. As an example, PCDD and PCDF removal efficiencies exceeded 99% for all tests.
3. Removal efficiencies for all metals in the flue gas, except mercury, typically exceeded 98%. For mercury, the removal efficiencies ranged from 96 to 99%.
4. Refuse-derived fuel spreader stoker combustors can be operated with low CO concentrations under steady state conditions (i.e., excluding startup and shutdown). Average CO concentrations below 100 ppm were attained in a number of the completed 5- to 6-hour tests.
5. Emissions of THC below 7 ppm were achieved under “good combustion conditions”. Combustion conditions that produced low CO emissions also produced low THC emissions.
6. Input/output (mass balance) comparisons of trace organic compounds in the RDF feed (input) with those in the ash and stack emissions (output) suggest that overall, combustion of RDF resulted in: a net reduction in PCDD, PAH, CP, CB, PCB; a net increase in PCDF; but a net decrease in total PCDD/PCDF.

The estimated average net destruction efficiencies for these trace organic compounds were 96% for good

combustion conditions and 90% for poor combustion conditions.

7. No consistent evidence was obtained to substantiate PCDD/PCDF formation in the flue gas temperature range of 400 to 150°C (750 to 300°F) (measured across the airheater). This was contrary to what was expected for this temperature range.
8. As anticipated, flue gas temperature at the spray dryer outlet and (estimated) calcium hydroxide to acid gas ratio were found to be the most important operating parameters for controlling HCl and SO₂ emissions.

8.3 Ash Results

1. The average loss-on-ignition (LOI) in bottom ash/grate siftings (0.7 to 1.5%) was lower than that measured in bottom ash from waterwall mass burning systems (1.5 to 5.0%) and much lower than in bottom ash from two-stage combustion systems (12 to 30%).
2. Concentrations of PCDD/PCDF in the bottom ash and grate siftings were at or below the detection limit.
3. No PCB was detected in any of the ashes.
4. Trace organic contaminants were measured in the fabric filter ash. For example, over 99% of the total PCDD/PCDF associated with the residues was measured in the fabric filter ash.
5. Concentrations of PCDD/PCDF in fabric filter ash ranged from 70 to 509 ng/g. Although the statistical correlation was not significant, these data suggest that good combustion conditions tend to result in comparatively low PCDD/PCDF concentrations in the fabric filter ash.
6. Organic contaminants in the ashes, including PCDD, PCDF, CB, and PAH, were not soluble in water.
7. Typically, concentrations of less volatile metals (e.g., chromium, nickel, copper) were higher in the combined bottom ash/grate siftings, whereas concentrations of relatively volatile metals (e.g., cadmium, mercury, zinc) were higher in the fabric filter ash. Lead concentrations were relatively high in both grate siftings and fabric filter ash, and relatively low in the bottom and economizer ash.
8. Fabric filter ash was more soluble in water (approximately 34% solubilized) than either the combined bottom ash/grate siftings or economizer ash (approximately 7% solubilized). A substantial portion of the solubilized material from the fabric filter ash consisted of sulphate and chloride anions (14% sulphate and 27% chloride).
9. Only very small amounts (typically less than 10%) of most trace metals present in the ashes were soluble in water.
10. In general, under simulated acidic conditions, larger fractions of cadmium, chromium, lead, manganese, and zinc, were potentially available for leaching from the fabric filter ash than from the bottom and grate siftings ash. Under most controlled disposal conditions, however, an acidic leaching environment is unlikely given the high acid neutralization capacity of the fabric filter ash.

11. Fabric filter ash was solidified using cement and three types of waste pozzolanic materials. Engineering test results indicate that these solidified materials were physically strong, durable, and relatively impermeable. In addition, results from different leach tests indicate that metal mobility was significantly reduced through both physical encapsulation and chemical fixation.

8.4 Correlations

Single-value regression analysis, comparing all test parameters with one another, was conducted to investigate possible correlations. In addition, multiple regression analysis of selected test data was conducted for two main purposes.

- a) The first purpose was to investigate the feasibility of using easily monitored variables, either individually or in clusters, as surrogate measures of difficult-to-monitor variables. This was done by choosing a difficult-to-monitor chemical, such as PCDD, as the dependent variable, and easily monitored variables, such as SO₂ and CO, as independent variables in the multiple regression equation.
- b) The second purpose was to explore the individual and collective influence of various operation controls on the emissions of certain compounds. This was done by choosing an emitted chemical as the dependent variable and selecting operating conditions as independent variables in the multiple regression equation.

The following are the key results of the regression analysis.

1. Moderate correlations were observed for CO and THC as compared to PCDD/PCDF at spray dryer inlet over the entire data set ($R^2 = 0.7$ and 0.68 , respectively). An excellent correlation ($R^2 = 0.95$) was observed for CO as compared to PCDD/PCDF when considering only those tests in which CO emissions were over 200 ppm. No correlation was observed when considering only those tests in which CO emission concentrations were less than 200 ppm. Similarly, tests with THC emissions above 7 ppm correlated excellently with PCDD/PCDF ($R^2 = 0.97$), but no correlation was found between PCDD/PCDF and THC emissions when THC concentrations are less than 7 ppm.
2. When comparing various measures of CO emissions with PCDD/PCDF emissions, the arithmetic average of CO emissions over the testing period provides the best correlation with PCDD/PCDF concentrations at the spray dryer inlet. However, the correlation was poor when considering only those tests in which CO averaged below 200 ppm for the test period. Other comparisons of PCDD/PCDF concentrations with the number or magnitude of CO spikes and the percent of time above an absolute CO level produced less significant correlations.
3. Multiple regression analyses show that the best easily monitored variable for correlating concentrations of PCDD, PCDF, CP, CB, and PAH at the spray dryer inlet typically include any two or more of the following: CO, THC, NO_x, HCl, H₂O in flue gas, and temperature in furnace or at economizer outlet.

For example, the best correlation for PCDD concentrations ($R^2 = 0.9$) at the spray dryer inlet is based on CO, NO_x, and H₂O concentrations in the flue gas.

4. Multiple regressions based on combustor operating variables that best explained the variation in concentrations of PCDD, PCDF, CP, CB, and PAH at the spray dryer inlet, use a combination of operating variables. These operating variables are also good indicators of conditions within the furnace and relate to fundamental combustion conditions (time, temperature, air/fuel ratio, and mixing).
5. Multiple regression analyses based on easily-monitored variables ("good" to "excellent" range, $R^2 = 0.8$ to 0.98 , respectively) were more conclusive than those based on combustor operating variables ("fair" to "good" range, $R^2 = 0.6$ to 0.8 , respectively).
6. A fair correlation ($R^2 = 0.61$) was obtained between PCDD/PCDF and particulate matter concentrations at the spray dryer inlet under good combustion conditions.
7. Poor correlations of uncontrolled PCDD/PCDF concentrations were observed under all combustion conditions for the following parameters: loss-on-ignition (LOI) in economizer ash; hydrogen chloride at the spray dryer inlet; and copper concentrations in fly ash.
8. The removal of trace organic compounds by the flue gas cleaning system correlated best with increased sorbent-to-acid-gas ratio (stoichiometric ratio) and decreasing spray dryer outlet temperature. These same variables were also seen to correlate with the degree of acid gas control.
9. Multiple regression analyses showed a very good correlation ($R^2 = 0.89$) between mercury removal by the flue gas cleaning system and decreasing flue gas temperature (spray dryer outlet) and increasing LOI of the fabric filter ash. Increases in stoichiometric ratio appeared to cause increased mercury emissions.

Section 9

Recommendations

1. The effect of the quantity and quality of refuse on emissions and residues should be better assessed and quantified.
2. Research is required to identify which metals are the major contributors to the wastestream and to document the effect of source separation, recycling, and front-end processing of waste before combustion on the ultimate quality of the different emissions and ash streams.
3. Research should be conducted on speciation of metals before (refuse feed) and after the combustion process (ash) to determine the impact of feed materials on ash quality and to determine an effective removal process for volatile species in flue gas.
4. The results of this study on municipal solid waste demonstrate that incineration is effective in destroying trace organic compounds (more than 96% under good combustion conditions, more than 90% under poor combustion conditions). The results also demonstrate that the air pollution control system is highly efficient in removing the organics in flue gases (more than 99%). These findings indicate that incineration may be an effective disposal option for trace organic compounds commonly found in household hazardous waste. Future research should be directed to examining the amounts and characteristics of household hazardous waste in the wastestream and the impacts on incinerator air emissions and ash residue.
5. A reliable method to determine the carbon content in fly ash is required for assessing incomplete products of combustion. This would determine if loss-on-ignition (LOI) is a suitable method for determining products of incomplete combustion.
6. Definitive stoichiometric ratio data should be obtained for evaluating flue gas cleaning system performance at municipal waste combustion facilities. Stoichiometric ratio is recognized to be an important parameter in controlling acid gases and possibly trace organics.
7. The impact of high sorbent stoichiometric ratio (more than 2) in spray dryer absorber fabric filter systems should be investigated to determine its effect on fabric filter ash solubility and capture of mercury.
8. The potential for artifact formation of PCDD/PCDF in the U.S. EPA Modified Method 5 sampling train at high temperatures [more than 200°C (400°F)] should be further investigated. This investigation may explain the decrease of PCDD/PCDF concentrations measured between the air preheater inlet and spray dryer inlet.
9. Research should be undertaken on the characteristics of particles in the flue gas

entering the air pollution control system, including studies of particle size distribution, metals speciation, and organic content.

10. A thorough environmental characterization, such as performed in this study, should be completed on waste recycling technologies.

References

- American Public Health Association (APHA), "Standard Methods for the Examination of Water and Wastewater", 16th Edition, Washington, D.C. (1985).
- American Society for Testing and Materials (ASTM), "Annual Book of ASTM Standards", Philadelphia, Pennsylvania (1988).
- California Air Resources Board (CARB), "Method 425: Determination of Total Chromium and Hexavalent Chromium Emissions from Stationary Sources", Sacramento, California (1982).
- Environment Canada, "The National Incinerator Testing and Evaluation Program: Two-stage Combustion (Prince Edward Island) - Summary Report", Conservation and Protection, Ottawa, Ontario, Report EPS 3/UP/1 (1985).
- Environment Canada, "The National Incinerator Testing and Evaluation Program: Air Pollution Control Technology", Conservation and Protection, Ottawa, Ontario, Report EPS 3/UP/2 (1986).
- Environment Canada, "National Incinerator Testing and Evaluation Program: Environmental Characterization of Mass Burning Incinerator Technology at Quebec City - Summary Report", Conservation and Protection, Ottawa, Ontario, Report EPS 3/UP/5 (1988).
- Environment Canada, "Methodology for Organic Analysis - NITEP/Mid-Connecticut Combustion Test", Conservation and Protection, Ottawa, Ontario, Report CD-891201 (1989).
- Environment Canada, "The Environmental Characterization of RDF Combustion Technology: Mid-Connecticut Facility, Hartford, Connecticut", Conservation and Protection, Ottawa, Ontario, Volumes II to VI, Report WM-14 (1991).
- Government of Ontario, "Regulation 309. Revised Regulations of Ontario, 1980, as amended to O. Reg. 138/90 under Environmental Protection Act", Ontario Ministry of the Environment, Ontario Gazette (1990).
- Kilgroe, J.D., W.S. Lanier, and T.R. von Alten, Montgomery County South Incinerator Test Project: Formation, Emission, and Control of Organic Pollutants, In Proceedings, 1991 International Conference on Municipal Waste Combustion, Volume 1, EPA-600/R-92-209a (NTIS PB93-124170), pp 161-175, November 1992.
- Sawell, S.E., R.J. Caldwell, P.L. Coté, T.W. Constable, and R.P. Scroggins, "Evaluation of Solidified Electrostatic Precipitator Ash from a Mass Burning Municipal Waste Incinerator", Conservation and Protection, Ottawa, Ontario, Report IP-82, Volume VII (1989).

Schindler, P.J., "Municipal Waste Combustion Assessment: Combustion Control at Existing Facilities", EPA 600/8-89-058 (NTIS PB90-154941) (August, 1989).

Stieglitz, L. and H. Vogg, "The De-novo-Synthesis of PCDD/PCDF and other Organohalogen Compounds on Fly Ash", Volume 3 - Dioxin 90 Short Papers, O. Hutzinger and H. Fielder (eds.), pp. 173-174 (1990).

U.S. EPA, "Test Methods for Evaluating Solid Waste: Physical/Chemical Methods, SW-846" (NTIS PB88-239223). Office of Solid Waste and Emergency Response, Washington, D.C. (1986).

U.S. EPA, "Stationary Source Sampling Methods", Federal Register, Title 40, Code of Federal Regulations, Part 60 Washington, D.C. (1988).

Appendix A

Combustion and Air Pollution Control System Test Results

TABLE A-1. PERFORMANCE TEST SUMMARY DATA: PROCESS PARAMETERS

STEAM LOAD COMBUSTOR OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V. POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
TEST DATE	14/2/89	15/2/89	16/2/89	18/2/89	20/2/89	21/2/90	22/2/89	23/2/89	24/2/89	25/2/89	27/2/89	28/2/89	01/3/89
START TIME	10:00	11:45	10:10	09:15	9:15	10:00	9:45	9:00	9:40	10:10	9:00	9:00	9:30
END TIME	15:35	17:10	17:15	15:05	14:10	15:10	14:55	14:00	14:45	15:10	14:18	15:00	16:40
PROCESS PARAMETERS													
MAIN STEAM PRESSURE (MPa g)	5.8	5.8	5.7	5.7	5.2	5.8	5.6	5.7	5.5	5.4	5.2	5.4	5.6
MAIN STEAM FLOW ('000 kg/h)	88	100	98	84	106	101	96	95	87	96	107	71	74
TOTAL COMB. AIR (PROC) ('000 kg/h)	94	105	121	90	111	107	101	106	97	102	103	84	90
R.S. UG AIR FLOW (PROC) ('000 kg/h)	26	30	29	32	27	29	30	28	26	28	28	25	25
PDA FLOW (PROCESS) ('000 kg/h)	4.9	5.6	5.7	6.2	6.4	5.7	6.4	6.1	5.8	5.8	5.8	5.4	5.8
RW O/F AIR ('000 kg/h)	0.0	3.8	0.0	1.5	0.0	0.0	3.6	3.6	0.0	3.6	3.2	0.0	0.0
TANGENTIAL O/F AIR ('000 kg/h)	51	39	63	32	66	56	46	49	51	51	52	39	43
TOTAL O/F AIR ('000 kg/h)	56	48	69	39	72	62	56	59	56	60	61	45	49
TOTAL COMB. AIR ('000 kg/h)	108	110	127	103	126	121	117	116	108	116	116	94	99
PROCESS SETPOINTS													
UG AIR DAMPER SETTINGS	15	15	15	30	30	15	15 15	15 15	15	15	30	30	15
	90	90	90	90	90	90	90 90	90 90	90	90	90	90	90
	90	90	90	90	90	90	90 90	90 90	90	90	90	90	90
	90	90	90	90	90	90	90 90	90 90	90	90	90	90	90
	30	30	30	30	30	30	30 45	30 45	30	30	30	30	30
GRATE SPEED	37	19	20	23/18	27	27/23	29/27	27/23	15/19	18	29	17/19	15/17
F.D. FAN PRESSURE	15	15	15	15/11	16	13	15/13	13	14	15	18	9/10	10
AIR DISTRIBUTION													
UG AIR (%)	48	56	46	62	43	49	52	49	48	48	47	53	51
PDA AIR (%)	4.6	5.1	4.5	6.1	5.1	4.7	5.4	5.3	5.3	5.0	5.0	5.8	5.9
RW AIR (%)	0	3.5	0	1.5	0	0	3.1	3.1	0	3.1	2.7	0	0
TANGENTIAL AIR (%)	47	35	50	31	52	46	40	42	47	44	45	42	44
O/F AIR (%)	52	44	54	38	57	51	48	51	52	52	53	47	49
PROCESS TEMPERATURES													
FURNACE TEMPERATURE (Deg C)	1022	1034	1059	1020	976	1006	1015	1033	1012	1026	1049	966	1004
BOILER INLET TEMP. (Deg C)	608	596	598	606	612	544	547	575	603	599	607	579	597
ECON. OUT. TEMP. (Deg C)	356	370	371	367	365	387	387	371	373	374	387	346	366
A/H GAS OUTLET TEMP. (Deg C)	192	208	193	190	186	204	203	193	193	187	197	179	193
SDA OUTLET TEMP (Deg C)	123	166	166	122	141	124	142	171	123	166	141	141	141
BAGHOUSE OUTLET TEMP. (Deg C)	107	139	142	104	123	106	118	140	106	141	119	112	119
A/H AIR INLET TEMP. (Deg C)	10	3	3	-3	5	8	5	2	-5	-2	3	1	4
COMBUSTION AIR TEMP. (Deg C)	263	247	243	262	259	277	277	250	258	263	273	249	254
TOFA ELEVATION (SETTINGS)													
- TOP (DEG)	+10	+10	+10	-	+10	+10	+10	+10	+10	+10	+10	+10	+10
- MIDDLE (DEG)	+6	-	+6	0	+6	+6	+6	+6	+6	+6	+6	+6	+6
- BOTTOM (DEG)	-	-	+2	-	+2	+2	-	-	-	-	0	-	-
REAR OFA PRESSURE (kPa)	0	8.8	0	0	0	0	8.8	8.8	0	8.8	0	-	0

(continued)

TABLE A-1. PERFORMANCE TEST SUMMARY DATA: PROCESS PARAMETERS (Continued)

STEAM LOAD		INTERM	NORMAL	NORMAL	INTERM	HIGH	NORMAL	NORMAL	NORMAL	INTERM	NORMAL	HIGH	LOW	LOW
COMBUSTOR OPERATION		GOOD	POOR	POOR	V. POOR	POOR	POOR	GOOD	GOOD	GOOD	GOOD	GOOD	GOOD	GOOD
TEST #		PT-02	PT-03	PT-04	PT-05	PT-06	PT-07	PT-08	PT-09	PT-10	PT-11	PT-12	PT-13	PT-14
APC OPERATING DATA														
SDA PRESSURE DROP	(Pa)	1050	1075	1075	925	1150	1200	1100	1025	1075	1025	1050	750	825
BAGHOUSE PRESSURE DROP	(Pa)	900	975	950	900	925	950	950	975	975	975	975	900	900
ATOM. SLURRY FLOW	(L/min)	102	64	45	91	76	125	91	34	102	45	91	61	75
SLURRY FEED	(L/min)	8.7	28.0	23.0	1.9	30.0	17.0	8.3	7.2	7.2	27.0	9.5	9.5	7.9
LIME SLURRY DENSITY	(g/L)	1440	1560	1560	1500	1440	1560	1560	1560	1560	1560	1560	1560	1560
MASS RATES														
REFUSE (ACTUAL)	(kg/h)	27577	30800	30680	27043	27511	26416	28667	30412	26082	25431	27964	20724*	18939
ASH														
ECONOMIZER (ACTUAL)	(kg/h)	24	11	15	14	10	14	18	15	10	14	17	8.7	17
FABRIC FILTER (ACTUAL)	(kg/h)	NC	NC	1385	429	1239	550	434	1317	1166	2140	315	673	1133
TOTAL FLY ASH (ACTUAL)	(kg/h)	NC	NC	1400	443	1249	564	452	1332	1176	2154	332	682	1150
GRATE SIFTINGS (ACTUAL)	(kg/h)	140	125	105	103	71	116	100	118	91	110	106	85	89
BOTTOM ASH (WET)	(kg/h)	4361	4041	4366	3212	4706	4612	4368	3823	3407	3357	4003	2381	2929
FLUE GAS VOLUME AND MOISTURE														
AIR HEATER INLET														
MM5 SAMPLING TRAIN:														
FLUE GAS FLOW RATE	(Sm ³ /h)						138587	130740	129300	137127				
MOISTURE	(%)						16.9	17.3	16.5	13.8				
SPRAY DRYER INLET														
MM5 SAMPLING TRAIN:														
FLUE GAS FLOW RATE	(Sm ³ /h)	151058	148422	152969	145505	159711	157853	149222	144758	154066	145387	142576	132245	140881
MOISTURE	(%)	15.4	17.6	15.1	13.0	13.5	15.2	16.3	15.1	12.3	14.1	16.2	12.4	11.1
METALS SAMPLING TRAIN:														
FLUE GAS FLOW RATE	(Sm ³ /h)	155041	147164	156049	148156	162412	158255	151184	147751	155889	147770	144663	123359	137010
MOISTURE	(%)	13.4	17.7	14.0	13.6	14.4	16.2	16.2	15.9	13.7	15.1	16.3	12.8	12.5
FABRIC FILTER OUTLET														
MM5 SAMPLING TRAIN:														
FLUE GAS FLOW RATE	(Sm ³ /h)	166015	164931	166980	153127	173383	170785	162987	163312	167933	157928	166508	152514	149593
MOISTURE	(%)	15.8	15.5	14.6	15.4	15.3	18.6	17.9	15.0	15.2	14.6	16.7	13.3	13.8
METALS SAMPLING TRAIN:														
FLUE GAS FLOW RATE	(Sm ³ /h)	162961	162329	164959	154818	170831	174747	165039	162976	166862	160909	173850	142431	145847
MOISTURE	(%)	16.3	16.1	15.2	15.9	15.7	19.1	18.1	15.7	15.7	14.5	15.7	13.5	14.3
PLANT ENVIRONMENTAL DATA														
BAGHOUSE OUTLET SO ₂	(kg/J)	129.2	0.0	43.1	86.1	0.0	0.0	129.2	43.1	0.0	0.0	86.1	43.1	43.1
BAGHOUSE OUTLET NO _x	(kg/J)	86.1	86.1	86.1	43.1	86.1	86.1	86.1	86.1	0.0	43.1	86.1	86.1	86.1
BOILER O ₂	(%)	6.5	5.0	4.6	5.0	4.9	4.5	4.8	5.2	6.7	5.8	5.0	8.2	7.6
PROCESS CO-SDA IN(12% CO	(ppm)	86.5	322.8	223.8	279.7	235.1	237.7	98.4	106.4	71.1	28.0	74.0	128.1	81.2

Notes: NC - Data not collected; * - Weighted average of other 12 test runs.

TABLE A-2. TEST SUMMARY DATA: CONTINUOUS EMISSIONS MONITORS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM VERY POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
Spray Dryer Inlet													
*+ CO ppm	108	432	214	903	397	387	89	92	77	68	116	158	70
CO2 %	10.4	12.0	11.9	11.0	11.5	12.1	11.8	11.9	10.5	11.6	12.9	9.8	10.1
O2 %	9.1	6.9	7.6	8.7	7.9	7.2	7.5	7.6	9.2	7.9	6.4	10.1	9.6
* NOx ppm	184.1	159.7	171.8	148.9	157.0	171.9	192.9	187.5	186.1	175.4	179.7	156.7	177.3
* SO2 ppm	177.4	199.9	185.6	169.1	191.6	182.9	183.5	177.9	193.6	174.3	197.5	175.4	188.9
* HCl ppm	472.3	419.0	471.3	468.7	404.4	399.4	538.2	431.5	428.6	413.3	469.5	421.4	442.3
* THC ppm	3.3	20.1	7.7	52.4	28.6	13.3	3.0	5.4	1.6	1.5	6.1	6.4	3.0
Moisture %	13.6	17.8	14.8	15.5	14.7	NA	16.2	17.5	13.8	15.0	16.0	12.2	12.2
Spray Dryer Outlet													
CO2 %	9.2	11.4	11.0	10.0	10.8	11.1	11.0	11.1	9.6	10.7	11.9	9.1	9.4
* SO2 ppm	NA	141.2	NA	165.0	108.0	127.3	163.3	158.7	131.4	73.7	133.9	107.6	166.5
* HCl ppm	44.2	23.2	44.5	55.8	19.7	9.5	44.1	145.5	15.2	8.4	37.1	12.9	46.1
Fabric Filter Outlet													
*+ CO ppm	108	432	214	903	397	387	89	92	77	68	116	158	70
CO2 %	9.3	10.8	11.0	9.6	10.2	10.4	10.4	10.4	9.1	10.1	11.0	8.6	8.9
O2 %	10.8	9.1	9.3	10.3	9.8	9.4	9.6	9.7	10.9	9.9	9.3	11.6	11.2
* SO2 ppm	110.0	13.1	44.4	131.8	32.1	17.0	126.3	188.8	73.7	19.5	62.5	29.0	84.5
* HCl ppm	20.0	17.5	30.8	20.9	10.2	7.7	40.6	98.2	18.8	23.1	16.7	18.4	20.0
* THC ppm	1.4	14.9	5.1	35.3	26.1	12.4	1.6	8.5	1.9	2.3	5.4	1.8	NA

NA = not available

* Corrected to 12% CO2

+ Reconstructed from measurements at SD inlet and FF outlet.

TABLE A-3. PERFORMANCE TEST SUMMARY DATA: REFUSE FEED ORGANICS/METALS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
ORGANICS													
TOTAL PCD (mg/h)	44	122	155	141	350	70	67	182	87	59	134	NC	119
(ng/g)	1.6	4.0	5.0	5.2	12.7	2.7	2.3	6.0	3.3	2.3	4.8	NC	6.3
(mg/tonne *)	1.6	4.0	5.0	5.2	12.7	2.7	2.3	6.0	3.3	2.3	4.8	NC	6.3
TOTAL PCD (mg/h)	0	5.3	0	0	4.2	0	11.7	18.9	4.5	0	3.0	NC	3.2
(ng/g)	0	0.173	0	0	0.151	0	0.406	0.622	0.174	0	0.106	NC	0.169
(mg/tonne *)	0	0.173	0	0	0.151	0	0.406	0.622	0.174	0	0.106	NC	0.169
TOTAL CB (mg/h)	0	0	0	604	0	55,658	0	0	660	447	1,476	NC	422
(ng/g)	0	0	0	22	0	2,107	0	0	25	18	53	NC	22
(mg/tonne *)	0	0	0	22	0	2,107	0	0	25	18	53	NC	22
TOTAL PCB (mg/h)	3,123	0	0	5,251	0	0	0	0	0	20,627	5,266	NC	0
(ng/g)	113	0	0	194	0	0	0	0	0	811	188	NC	0
(mg/tonne *)	113	0	0	194	0	0	0	0	0	811	188	NC	0
TOTAL CP (mg/h)	11,569	15,073	17,732	16,905	62,682	17,767	14,818	13,386	13,724	10,143	15,601	NC	11,857
(ng/g)	420	489	578	625	2,278	673	517	440	526	399	558	NC	626
(mg/tonne *)	420	489	578	625	2,278	673	517	440	526	399	558	NC	626
TOTAL PAH (mg/h)	121,355	145,207	148,388	109,927	227,318	186,926	140,148	127,859	153,189	122,782	312,336	NC	1,081,194
(ng/g)	4,401	4,715	4,837	4,065	8,263	7,076	4,889	4,204	5,873	4,828	11,169	NC	57,088
(mg/tonne *)	4,401	4,715	4,837	4,065	8,263	7,076	4,889	4,204	5,873	4,828	11,169	NC	57,088
METALS													
ANTIMONY (g/h)	47	115	65	126	385	469	53	100	64	161	205	NC	123
(ug/g)	1.7	3.7	2.1	4.7	14.0	17.7	1.8	3.3	2.4	6.3	7.3	NC	6.5
(g/tonne *)	1.7	3.7	2.1	4.7	14.0	17.7	1.8	3.3	2.4	6.3	7.3	NC	6.5
ARSENIC (g/h)	24	57	120	58	44	227	23	84	97	53	105	NC	34
(ug/g)	0.85	1.85	3.93	2.16	1.58	8.59	0.80	2.77	3.74	2.09	3.75	NC	1.80
(g/tonne *)	0.9	1.8	3.9	2.2	1.6	8.6	0.8	2.8	3.7	2.1	3.7	NC	1.8
CADMIUM (g/h)	36	98	69	81	54	136	79	56	45	44	83	NC	81
(ug/g)	1.32	3.18	2.24	3.00	1.97	5.16	2.75	1.84	1.72	1.72	2.96	NC	4.26
(g/tonne *)	1.3	3.2	2.2	3.0	2.0	5.2	2.8	1.8	1.7	1.7	3.0	NC	4.3
CHROMIUM (g/h)	579	583	845	437	371	3,192	4,374	713	487	543	302	NC	500
(ug/g)	21	19	28	16	13	121	153	23	19	21	11	NC	26
(g/tonne *)	21	19	28	16	13	121	153	23	19	21	11	NC	26
COPPER (g/h)	3,143	1,147	1,441	714	11,117	5,713	43,981	4,432	25,233	1,760	164,599	NC	4,604
(ug/g)	114	37	47	26	404	216	1,534	146	967	69	5,886	NC	243
(g/tonne *)	114	37	47	26	404	216	1,534	146	967	69	5,886	NC	243
LEAD (g/h)	1,737	2,819	4,572	4,306	3,924	17,138	8,276	4,075	2,884	21,994	9,053	NC	3,403
(ug/g)	63	92	149	159	143	649	289	134	111	865	324	NC	180
(g/tonne *)	63	92	149	159	143	649	289	134	111	865	324	NC	180
MERCURY (g/h)	1.700	1.400	1.400	1.100	0.900	1.600	1.200	1.500	0.800	6.500	1.100	NC	1.000
(ug/g)	0.061	0.047	0.047	0.041	0.034	0.061	0.042	0.050	0.029	0.257	0.038	NC	0.051
(g/tonne *)	0.061	0.047	0.047	0.041	0.034	0.061	0.042	0.050	0.029	0.257	0.038	NC	0.051
NICKEL (g/h)	806	311	621	507	349	3,797	3,310	790	1,027	336	631	NC	701
(ug/g)	29	10	20	19	13	144	115	26	39	13	23	NC	37
(g/tonne *)	29	10	20	19	13	144	115	26	39	13	23	NC	37
ZINC (g/h)	4,384	3,306	5,864	5,572	9,809	5,377	13,714	6,877	13,338	3,881	93,273	NC	8,608
(ug/g)	159	107	191	206	357	204	478	226	511	153	3,335	NC	455
(g/tonne *)	159	107	191	206	357	204	478	226	511	153	3,335	NC	455

Notes: NC - not collected; ND - values below detection limit; * - refuse as fired.

TABLE A-4. PERFORMANCE TEST SUMMARY DATA: ASH ORGANICS/METALS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
DRY BOTTOM ASH													
<i>ORGANICS:</i>													
TOTAL PCDD (mg/h)	0	0	0	0	0	0	0.900	0.120	0	0	0	NC	0
(ng/g)	0	0	0	0	0	0	0.25	0.04	0	0	0	NC	0
(mg/tonne *)	0	0	0	0	0	0	0.031	0.004	0	0	0	NC	0
TOTAL PCDF (mg/h)	0	0	0	0	0	0	1.536	0.297	0	0	0	NC	0
(ng/g)	0	0	0	0	0	0	0.43	0.09	0	0	0	NC	0
(mg/tonne *)	0	0	0	0	0	0	0.054	0.010	0	0	0	NC	0
TOTAL CB (mg/h)	0	0	0	0	0	0	0	0	0	0	0	NC	0
(ng/g)	0	0	0	0	0	0	0	0	0	0	0	NC	0
(mg/tonne *)	0	0	0	0	0	0	0	0	0	0	0	NC	0
TOTAL PCB (mg/h)	0	0	0	0	0	0	0	0	0	0	0	NC	0
(ng/g)	0	0	0	0	0	0	0	0	0	0	0	NC	0
(mg/tonne *)	0	0	0	0	0	0	0	0	0	0	0	NC	0
TOTAL CP (mg/h)	73.3	15.1	38.7	42.8	46.4	66.6	14.5	11.4	9.8	0	0	NC	25.8
(ng/g)	20.7	4.2	10.3	14.6	13.6	18.0	4.1	3.4	3.4	0	0	NC	10.5
(mg/tonne *)	2.66	0.49	1.26	1.58	1.69	2.52	0.51	0.38	0.38	0	0	NC	1.36
TOTAL PAH (mg/h)	45431	774	371	221	464	618	84	46	32	31	663	NC	108
(ng/g)	12853	217	99	76	136	168	24	14	11	11	196	NC	44
(mg/tonne *)	1647	25.1	12.1	8.2	16.9	23.4	2.9	1.5	1.2	1.2	23.7	NC	5.7
<i>METALS:</i>													
ANTIMONY (g/h)	0	0	0	3.1	0	3.9	12.4	0	0	6.0	7.1	NC	4.0
(ug/g)	0	0	0	1.1	0	1.1	3.6	0	0	2.2	2.1	NC	1.7
(g/tonne *)	0	0	0	0.11	0	0.15	0.43	0	0	0.24	0.25	NC	0.21
ARSENIC (g/h)	46	31	32	30	26	21	46	30	19	18	46	NC	28
(ug/g)	13.7	8.9	8.7	10.5	7.8	5.9	13.1	9.1	6.8	6.5	14.1	NC	11.5
(g/tonne *)	1.68	0.99	1.04	1.10	0.96	0.81	1.59	0.97	0.73	0.70	1.66	NC	1.47
CADMIUM (g/h)	18	30	22	17	16	18	24	20	18	18	14	NC	22
(ug/g)	5.4	8.7	6.0	5.9	4.6	5.1	7.0	6.1	6.6	6.8	4.3	NC	9.1
(g/tonne *)	0.67	0.98	0.71	0.61	0.57	0.70	0.85	0.64	0.70	0.73	0.51	NC	1.16
CHROMIUM (g/h)	616	1084	782	555	534	602	810	679	518	464	622	NC	761
(ug/g)	181	314	214	196	158	166	232	210	186	170	189	NC	316
(g/tonne *)	22	35	25	21	19	23	28	22	20	18	22	NC	40

(continued)

TABLE A-4. PERFORMANCE TEST SUMMARY DATA: ASH ORGANICS/METALS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14	
COPPER	(g/h)	33,583	11,271	13,586	10,851	3,795	4,874	8,292	20,599	9,869	13,312	52,861	NC	10,525
	(ug/g)	9,878	3,267	3,728	3,835	1,121	1,348	2,371	6,383	3,546	4,882	16,067	NC	4,369
	(g/tonne *)	1,218	366	443	401	138	185	289	677	378	523	1,890	NC	556
LEAD	(g/h)	3,218	5,500	5,050	5,414	3,439	6,590	13,099	3,864	4,303	6,147	4,240	NC	8,675
	(ug/g)	947	1,594	1,386	1,913	1,016	1,823	3,746	1,197	1,546	2,254	1,289	NC	3,601
	(g/tonne *)	117	179	165	200	125	249	457	127	165	242	152	NC	458
MERCURY	(g/h)	0	0	0.130	0	1.090	0.980	0	0	0.230	0	0.085	NC	0
	(ug/g)	0	0	0.035	0	0.322	0.272	0	0	0.081	0	0.026	NC	0
	(g/tonne *)	0	0	0.004	0	0.040	0.037	0	0	0.009	0	0.003	NC	0
NICKEL	(g/h)	1,931	867	631	833	326	331	594	705	293	663	565	NC	802
	(ug/g)	568	251	173	294	96	92	170	218	105	243	172	NC	333
	(g/tonne *)	70	28	21	31	12	13	21	23	11	26	20	NC	42
ZINC	(g/h)	4,813	3,414	4,539	3,262	4,269	4,935	5,942	3,603	5,092	3,737	3,618	NC	4,523
	(ug/g)	1,416	990	1,245	1,153	1,261	1,365	1,699	1,116	1,830	1,370	1,100	NC	1,877
	(g/tonne *)	175	111	148	121	155	187	207	118	195	147	129	NC	239
GRATE SIFTINGS ASH METALS:														
ANTIMONY	(g/h)	5.75	3.81	5.60	2.62	3.13	5.91	0.61	6.96	1.03	4.96	2.47	NC	1.87
	(ug/g)	41	30	53	25	44	51	6.1	59	11	45	23	NC	21
	(g/tonne *)	0.209	0.124	0.183	0.097	0.114	0.224	0.021	0.229	0.039	0.195	0.088	NC	0.098
ARSENIC	(g/h)	1.84	1.00	0.83	0.84	0.67	1.19	0.97	1.58	0.70	1.06	1.39	NC	0.86
	(ug/g)	13.2	8.0	7.9	8.1	9.4	10.3	9.7	13.4	7.7	9.7	13.1	NC	9.7
	(g/tonne *)	0.067	0.033	0.027	0.031	0.024	0.045	0.034	0.052	0.027	0.042	0.050	NC	0.046
CADMIUM	(g/h)	0.88	1.02	1.30	1.16	0.82	1.32	1.29	0.63	1.02	1.33	1.38	NC	0.78
	(ug/g)	6.3	8.1	12.4	11.3	11.5	11.4	12.9	5.3	11.2	12.1	13.0	NC	8.8
	(g/tonne *)	0.032	0.033	0.042	0.043	0.030	0.050	0.045	0.021	0.039	0.052	0.049	NC	0.041
CHROMIUM	(g/h)	60	29	48	47	20	37	21	39	35	34	20	NC	26
	(ug/g)	430	233	461	454	284	319	208	328	388	311	192	NC	297
	(g/tonne *)	2.18	0.94	1.58	1.73	0.73	1.40	0.73	1.27	1.36	1.34	0.73	NC	1.39
COPPER	(g/h)	307	93	218	98	819	208	156	192	1,505	420	171	NC	352
	(ug/g)	2,196	745	2,079	956	11,534	1,797	1,563	1,630	16,533	3,819	1,616	NC	3,958
	(g/tonne *)	11.1	3.0	7.1	3.6	29.8	7.9	5.5	6.3	57.7	16.5	6.1	NC	18.6

(continued)

TABLE A-4. PERFORMANCE TEST SUMMARY DATA: ASH ORGANICS/METALS

STEAM LOAD OPERATION TEST #		INTERM GOOD	NORMAL POOR	NORMAL POOR	INTERM V POOR	HIGH POOR	NORMAL POOR	NORMAL GOOD	NORMAL GOOD	INTERM GOOD	NORMAL GOOD	HIGH GOOD	LOW GOOD	LOW GOOD
		PT-02	PT-03	PT-04	PT-05	PT-06	PT-07	PT-08	PT-09	PT-10	PT-11	PT-12	PT-13	PT-14
LEAD	(g/h)	2,869	268	522	400	1,195	1,859	443	2,084	482	782	907	NC	760
	(ug/g)	20,494	2,142	4,971	3,881	16,829	16,022	4,429	17,665	5,294	7,105	8,558	NC	8,545
	(g/tonne *)	104.0	8.7	17.0	14.8	43.4	70.4	15.5	68.5	18.5	30.7	32.4	NC	40.2
MERCURY	(g/h)	0.127	0.293	0.201	0.208	0.072	0.135	0.229	0.052	0	0.021	0.081	NC	0.050
	(ug/g)	0.910	2.350	1.920	2.020	1.020	1.160	2.290	0.440	0	0.200	0.760	NC	0.560
	(g/tonne *)	0.005	0.010	0.007	0.008	0.003	0.005	0.008	0.002	0	0.001	0.003	NC	0.003
NICKEL	(g/h)	143	27	44	117	21	44	30	54	33	50	27	NC	38
	(ug/g)	1,025	214	416	1,136	303	381	295	455	361	453	253	NC	432
	(g/tonne *)	5.20	0.87	1.42	4.33	0.78	1.67	1.03	1.77	1.26	1.96	0.96	NC	2.03
ZINC	(g/h)	161	205	446	184	199	780	217	235	485	293	205	NC	145
	(ug/g)	1,153	1,639	4,248	1,789	2,798	6,727	2,171	1,994	5,330	2,664	1,930	NC	1,628
	(g/tonne *)	5.9	6.7	14.5	6.8	7.2	29.5	7.6	7.7	18.6	11.5	7.3	NC	7.7
ECONOMIZER ASH														
ORGANICS:														
TOTAL PCDD	(mg/h)	0	0	0	0.0060	0.0003	0	0.0017	0.0014	0	0	0	NC	0
	(ng/g)	0	0	0	0.43	0.03	0	0.09	0.09	0	0	0	NC	0
	(ug/tonne*)	0	0	0	0.221	0.011	0	0.058	0.045	0	0	0	NC	0
TOTAL PCDF	(mg/h)	0.0008	0.0049	0.0023	0.0252	0.0125	0.0064	0.0116	0.0076	0.0002	0	0.0019	NC	0
	(ng/g)	0.03	0.44	0.15	1.83	1.20	0.45	0.65	0.49	0.02	0	0.11	NC	0
	(ug/tonne*)	0.029	0.159	0.076	0.931	0.456	0.242	0.403	0.249	0.008	0	0.066	NC	0
TOTAL CB	(mg/h)	0	0	0	0	0	0	0	0	0	0	0	NC	0
	(ng/g)	0	0	0	0	0	0	0	0	0	0	0	NC	0
	(ug/tonne*)	0	0	0	0	0	0	0	0	0	0	0	NC	0
TOTAL PCB	(mg/h)	0	0	0	0	0	0	0	0	0	0	0	NC	0
	(ng/g)	0	0	0	0	0	0	0	0	0	0	0	NC	0
	(ug/tonne*)	0	0	0	0	0	0	0	0	0	0	0	NC	0
TOTAL CP	(mg/h)	0.333	0.045	0.304	0.138	0.042	0.113	0	0.216	0.143	0.352	0.170	NC	0.401
	(ng/g)	14.0	4.0	20.0	10.0	4.0	8.0	0	14.0	15.0	26.0	10.0	NC	24.0
	(ug/tonne*)	12.1	1.5	9.9	5.1	1.5	4.3	0	7.1	5.5	13.8	6.1	NC	21.2
TOTAL PAH	(mg/h)	0.29	1.5	0.78	6.6	11.4	0.76	0.21	0.23	0	0.19	0	NC	0
	(ng/g)	12	130	51	475	1,087	54	12	15	0	14	0	NC	0
	(ug/tonne*)	10.4	47	25	242	413	29	7.4	7.6	0	7.4	0	NC	0

(continued)

TABLE A-4. PERFORMANCE TEST SUMMARY DATA: ASH ORGANICS/METALS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14	
METALS:														
ANTIMONY	(g/h)	0.15	0.06	0.15	0.18	0.10	0.16	0.04	0	0.14	0.10	0.05	NC	0.13
	(ug/g)	6.2	5.5	10.1	12.7	9.3	11.0	2.2	0	14.3	7.4	2.7	NC	8.1
	(g/tonne *)	0.0054	0.0020	0.0050	0.0065	0.0035	0.0059	0.0014	0	0.0052	0.0039	0.0017	NC	0.0071
ARSENIC	(g/h)	0.28	0.15	0.19	0.20	0.18	0.15	0.16	0.17	0.12	0.18	0.21	NC	0.24
	(ug/g)	11.9	13.0	12.5	14.6	17.6	10.7	9.3	10.9	12.7	13.1	12.4	NC	14.4
	(g/tonne *)	0.0103	0.0047	0.0062	0.0074	0.0067	0.0057	0.0057	0.0055	0.0047	0.0070	0.0075	NC	0.0127
CADMIUM	(g/h)	0.24	0.07	0.12	0.08	0.06	0.09	0.17	0.10	0.06	0.08	0.15	NC	0.11
	(ug/g)	10.2	6.6	7.9	5.9	6.2	6.5	9.9	6.5	5.9	5.7	8.9	NC	6.5
	(g/tonne *)	0.0088	0.0024	0.0039	0.0030	0.0023	0.0035	0.0061	0.0033	0.0021	0.0030	0.0054	NC	0.0058
CHROMIUM	(g/h)	5.2	1.8	8.2	4.5	1.6	3.1	2.8	12.8	2.6	2.8	3.6	NC	5.2
	(ug/g)	220	160	540	330	150	220	160	830	270	210	210	NC	310
	(g/tonne *)	0.19	0.06	0.27	0.17	0.06	0.12	0.10	0.42	0.10	0.11	0.13	NC	0.27
COPPER	(g/h)	10.5	6.2	10.3	9.4	5.3	8.3	39.9	28.0	8.4	7.3	9.9	NC	18.9
	(ug/g)	440	550	680	679	509	590	2259	1,820	880	540	580	NC	1130
	(g/tonne *)	0.38	0.20	0.34	0.35	0.19	0.32	1.39	0.92	0.32	0.29	0.35	NC	1.00
LEAD	(g/h)	14.0	10.4	14.3	13.1	6.9	13.8	20.1	11.7	9.4	11.8	16.7	NC	15.7
	(ug/g)	590	929	940	949	659	980	1,140	760	980	870	979	NC	940
	(g/tonne *)	0.51	0.34	0.47	0.48	0.25	0.52	0.70	0.38	0.36	0.46	0.60	NC	0.83
MERCURY	(mg/h)	0.500	0.390	0	0.280	0.250	0.300	0.370	0.310	0	0	0	NC	0.470
	(ug/g)	0.021	0.035	0	0.020	0.024	0.021	0.021	0.020	0	0	0	NC	0.028
	(mg/tonne *)	0.018	0.013	0	0.010	0.009	0.011	0.013	0.010	0	0	0	NC	0.025
NICKEL	(g/h)	9.8	1.5	11.7	17.8	1.8	4.1	2.3	12.2	2.9	2.8	4.4	NC	11.0
	(ug/g)	410	130	770	1289	170	290	130	790	300	210	260	NC	660
	(g/tonne *)	0.35	0.05	0.38	0.66	0.06	0.15	0.08	0.40	0.11	0.11	0.16	NC	0.58
ZINC	(g/h)	22.4	16.2	26.7	19.4	18.4	19.1	26.5	30.0	13.9	31.8	22.9	NC	30.4
	(ug/g)	940	1,449	1,759	1,408	1,758	1,349	1,499	1,950	1460	2350	1349	NC	1819
	(g/tonne *)	0.81	0.53	0.87	0.72	0.67	0.72	0.92	0.99	0.53	1.25	0.82	NC	1.60
FABRIC FILTER ASH														
ORGANICS:														
TOTAL PCDD	(mg/h)	NC	NC	117	41	281	85	27	147	32	105	6	NC	209
	(ng/g)	NC	NC	84	96	227	154	62	112	27	49	20	NC	184
	(mg/tonne *)	NC	NC	3.8	1.5	10.2	3.2	0.9	4.8	1.2	4.1	0.2	NC	11.0

(continued)

TABLE A-4. PERFORMANCE TEST SUMMARY DATA: ASH ORGANICS/METALS

STEAM LOAD OPERATION TEST #		INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
TOTAL PCDF	(mg/h)	NC	NC	238	30	349	149	42	292	55	213	18	NC	188
	(ng/g)	NC	NC	172	71	282	271	96	222	47	100	56	NC	166
	(mg/tonne *)	NC	NC	7.8	1.1	12.7	5.6	1.4	9.6	2.1	8.4	0.6	NC	9.9
TOTAL CB	(mg/h)	NC	NC	1,467	465	2,086	518	316	1,667	798	1,507	223	NC	1,957
	(ng/g)	NC	NC	1,059	1,085	1,684	941	729	1,266	684	704	708	NC	1,727
	(mg/tonne *)	NC	NC	48	17	76	20	11	55	31	59	8	NC	103
TOTAL PCB	(mg/h)	NC	NC	0	0	0	0	0	0	0	0	0	NC	0
	(ng/g)	NC	NC	0	0	0	0	0	0	0	0	0	NC	0
	(mg/tonne *)	NC	NC	0	0	0	0	0	0	0	0	0	NC	0
TOTAL CP	(mg/h)	NC	NC	4,598	1,231	7,552	2,748	710	5,711	2,243	4,762	456	NC	2,511
	(ng/g)	NC	NC	3,320	2,870	6,095	4,997	1,636	4,336	1,924	2,225	1,447	NC	2,216
	(mg/tonne *)	NC	NC	150	46	275	104	25	188	86	187	16	NC	133
TOTAL PAH	(mg/h)	NC	NC	2,501	4,048	9,207	1,096	1,261	6,295	1,635	2,326	364	NC	7,966
	(ng/g)	NC	NC	1,806	9,437	7,431	1,992	2,905	4,780	1,402	1,087	1,155	NC	7,031
	(mg/tonne *)	NC	NC	82	150	335	41	44	207	63	91	13	NC	421
METALS:														
ANTIMONY	(g/h)	NC	NC	11.9	3.9	12.4	5.1	5.5	16.8	11.2	20.5	2.6	NC	19.6
	(ug/g)	NC	NC	8.6	9.0	10.0	9.3	12.7	12.7	9.6	9.6	8.2	NC	17.3
	(g/tonne *)	NC	NC	0.39	0.14	0.45	0.19	0.19	0.55	0.43	0.81	0.09	NC	1.04
ARSENIC	(g/h)	NC	NC	27.0	6.5	23.2	9.1	9.6	28.1	22.6	37.6	5.2	NC	23.4
	(ug/g)	NC	NC	20	15	19	17	22	21	19	18	16	NC	21
	(g/tonne *)	NC	NC	0.88	0.24	0.84	0.34	0.33	0.92	0.87	1.48	0.19	NC	1.24
CADMIUM	(g/h)	NC	NC	134	30	119	49	27	156	101	208	43	NC	111
	(ug/g)	NC	NC	96	70	96	90	62	119	87	97	138	NC	98
	(g/tonne *)	NC	NC	4.4	1.1	4.3	1.9	0.9	5.1	3.9	8.2	1.6	NC	5.9
CHROMIUM	(g/h)	NC	NC	248	113	190	81	91	377	320	513	59	NC	256
	(ug/g)	NC	NC	179	264	154	147	210	287	274	240	187	NC	226
	(g/tonne *)	NC	NC	8.1	4.2	6.9	3.1	3.2	12.4	12.3	20.2	2.1	NC	13.5
COPPER	(g/h)	NC	NC	537	185	464	177	311	833	743	1,452	115	NC	680
	(ug/g)	NC	NC	388	431	374	323	717	632	637	679	365	NC	600
	(g/tonne *)	NC	NC	17.5	6.8	16.9	6.7	10.9	27.4	28.5	57.1	4.1	NC	35.9

(continued)

TABLE A-4. PERFORMANCE TEST SUMMARY DATA: ASH ORGANICS/METALS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14	
LEAD	(g/h)	NC	NC	4,726	853	4,542	1,678	1,058	5,986	2,742	5,148	904	NC	3,120
	(ug/g)	NC	NC	3,413	1,987	3,666	3,051	2,439	4,545	2,352	2,405	2,869	NC	2,754
	(g/tonne *)	NC	NC	154	32	165	64	37	197	105	202	32	NC	165
MERCURY	(g/h)	NC	NC	66	11	44	21	11	49	32	63	10	NC	51
	(ug/g)	NC	NC	48	25	36	37	25	37	27	30	32	NC	45
	(g/tonne *)	NC	NC	2.1	0.39	1.6	0.78	0.38	1.6	1.2	2.5	0.36	NC	2.7
NICKEL	(g/h)	NC	NC	317	319	464	137	170	547	354	940	78	NC	613
	(ug/g)	NC	NC	229	744	374	249	392	415	304	439	246	NC	541
	(g/tonne *)	NC	NC	10.3	11.8	16.9	5.2	5.9	18.0	13.6	37.0	2.8	NC	32.4
ZINC	(g/h)	NC	NC	8,957	2,344	12,127	5,060	2,490	11,190	6,855	14,311	1,515	NC	8,914
	(ug/g)	NC	NC	6,467	5,463	9,788	9,200	5,738	8,497	5,879	6,687	4,811	NC	7,867
	(g/tonne *)	NC	NC	292	87	441	192	87	368	263	563	54	NC	471

NA - not available

NC - not collected

* - refuse as fired

TABLE A-5. PERFORMANCE TEST SUMMARY DATA: FLUE GAS ORGANICS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
PREHEATER INLET													
TOTAL PCDD (mg/h)						54.5	33.2	18.1	20.8				
(ng/Sm3 **)						390	258	141	174				
(mg/tonne *)						2.06	1.16	0.60	0.80				
TOTAL PCDF (mg/h)						270	235	98	98				
(ng/Sm3 **)						1,932	1,827	767	816				
(mg/tonne *)						10.2	8.2	3.2	3.8				
TOTAL CB (mg/h)						1,950	1,632	1,546	1,443				
(ng/Sm3 **)						13,954	12,691	12,055	12,030				
(mg/tonne *)						74	57	51	55.3				
TOTAL PCB (mg/h)						38	18	7.4	30.2				
(ng/Sm3 **)						269	142	58	252				
(mg/tonne *)						1.42	0.64	0.24	1.16				
TOTAL CP (mg/h)						8,281	6,688	3,322	2,541				
(ng/Sm3 **)						59,256	52,022	25,911	21,181				
(mg/tonne *)						313	233	109	97				
TOTAL PAH (mg/h)						12,418	4,896	6,613	1,261				
(ng/Sm3 **)						88,865	38,080	51,575	10,512				
(mg/tonne *)						470	171	217	48				
SPRAY DRYER INLET													
TOTAL PCDD (mg/h)	27.9	34.1	22.8	77.3	48.5	32.9	31.0	10.2	32.8	12.9	10.2	15.8	8.5
(ng/Sm3 **)	213	230	151	580	317	207	211	71	243	92	67	147	72
(mg/tonne *)	1.01	1.11	0.74	2.86	1.76	1.25	1.08	0.33	1.26	0.51	0.36	0.76	0.45
TOTAL PCDF (mg/h)	96	115	95	171	135	127	140	54	57	62	33	49	42
(ng/Sm3 **)	733	778	623	1281	885	796	951	378	424	444	215	452	356
(mg/tonne *)	3.48	3.75	3.08	6.32	4.92	4.80	4.87	1.78	2.19	2.46	1.18	2.35	2.23
TOTAL CB (mg/h)	775	1,157	905	2,108	1,439	1,126	1,038	696	832	636	924	355	549
(ng/Sm3 **)	5,919	7,792	5,964	15,801	9,403	7,074	7,071	4,848	6,170	4,526	6,027	3,286	4,627
(mg/tonne *)	28.1	37.6	29.5	77.9	52.3	42.6	36.2	22.9	31.9	25.0	33.0	17.1	29.0
TOTAL PCB (mg/h)	3.41	2.43	0	2.68	1.78	2.63	3.49	0.87	1.78	9.52	5.25	0	0
(ng/Sm3 **)	26	16	0	20	12	17	24	6	13	68	34	0	0
(mg/tonne *)	0.12	0.08	0	0.10	0.06	0.10	0.12	0.03	0.07	0.37	0.19	0	0

(continued)

TABLE A-5. PERFORMANCE TEST SUMMARY DATA: FLUE GAS ORGANICS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
TOTAL CP (mg/h)	1,611	4,480	2,573	15,148	6,365	4,006	2,968	1,626	2,184	1,604	2,550	1,464	1,550
(ng/Sm3 **)	12,308	30,186	16,964	113,568	41,588	25,168	20,226	11,329	16,198	11,410	16,636	13,553	13,069
(mg/tonne *)	58	145	84	560	231	152	104	53	84	63	91	71	82
TOTAL PAH (mg/h)	1,097	12,949	3,416	14,935	13,565	8,241	1,505	4,654	848	942	2,484	489	297
(ng/Sm3 **)	8,377	87,246	25,519	111,975	88,626	51,774	10,259	32,421	6,289	6,706	16,208	4,532	2,501
(mg/tonne *)	40	420	111	552	493	312	53	153	33	37	89	24	16
FABRIC FILTER OUTLET													
TOTAL PCDD (mg/h)	0.0102	0.0834	0.0563	0.0455	0.0510	0.0247	0.0405	0.0823	0.0231	0.0175	0.0102	0.0118	0.0013
(ng/Sm3 **)	0.079	0.562	0.368	0.371	0.346	0.167	0.286	0.582	0.181	0.131	0.067	0.108	0.012
(ug/tonne*)	0.37	2.71	1.83	1.68	1.86	0.93	1.41	2.71	0.89	0.69	0.36	0.57	0.07
TOTAL PCDF (mg/h)	0.0155	0.0559	0.0745	0.1377	0.0239	0.0215	0.0660	0.0700	0.0131	0.0258	0.0115	0.0294	0.0023
(ng/Sm3 **)	0.121	0.376	0.486	1.124	0.162	0.145	0.467	0.495	0.103	0.194	0.075	0.269	0.020
(ug/tonne*)	0.56	1.81	2.43	5.09	0.87	0.81	2.30	2.30	0.50	1.02	0.41	1.42	0.12
TOTAL CB (mg/h)	8.3	18.9	14.2	92.4	79.4	16.0	15.8	16.0	5.3	61.1	0	9.4	3.8
(ng/Sm3 **)	65	127	93	754	539	108	112	113	42	460	0	86	34
(ug/tonne*)	301	614	464	3,415	2,887	607	552	527	203	2,403	0	453	199
TOTAL PCB (mg/h)	0	2.4	2.9	0	0	0	1.0	1.9	0	4.9	0	0	0
(ng/Sm3 **)	0	16.3	19.3	0	0	0	6.8	13.7	0	36.8	0	0	0
(ug/tonne*)	0	79	96	0	0	0	33	64	0	192	0	0	0
TOTAL CP (mg/h)	6.3	36.9	25.5	397.2	188.9	33.5	26.8	55.4	10.1	18.1	12.6	11.7	7.8
(ng/Sm3 **)	49	248	167	3,242	1,282	226	190	391	79	136	82	107	71
(ug/tonne*)	230	1,197	832	14,687	6,866	1,268	936	1,822	387	711	450	566	414
TOTAL PAH (mg/h)	252	338	304	947	300	206	337	345	332	678	521	513	50
(ng/Sm3 **)	1,958	2,275	1,983	7,730	2,034	1,390	2,386	2,438	2,603	5,098	3,415	4,691	450
(ug/tonne*)	9,136	10,962	9,893	35,019	10,897	7,787	11,755	11,347	12,711	26,647	18,642	24,739	2,638
TOTAL VOST (mg/h)	6,815	89,222	46,709	414,556	25,549	147,277	35,990	58,754	19,161	8,024	106,821	10,608	6,155
(ng/Sm3 **)	53,462	605,852	307,018	3,365,500	174,647	983,615	253,192	415,538	150,945	59,802	684,764	100,372	56,180
(ug/tonne*)	247	2,897	1,522	15,330	929	5,575	1,255	1,932	735	316	3,820	512	325

** - corrected to 12% CO2

* - refuse as fired

TABLE A-6. PERFORMANCE TEST SUMMARY DATA: FLUE GAS METALS

STEAM LOAD OPERATION TEST #		INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
SPRAY DRYER INLET														
ANTIMONY	(g/h)	11.3	6.5	12.4	16.6	7.9	8.8	19.8	23.2	21.2	16.3	27.0	11.7	12.7
	(ug/Sm3**)	84	44	80	122	51	55	133	159	156	114	173	116	110
	(g/tonne *)	0.41	0.21	0.40	0.61	0.29	0.33	0.69	0.76	0.81	0.64	0.96	0.56	0.67
ARSENIC	(g/h)	36	31	26	31	30	28	33	29	29	30	38	16	29
	(ug/Sm3**)	270	214	168	230	194	176	224	196	210	213	247	159	250
	(g/tonne *)	1.32	1.02	0.85	1.15	1.10	1.06	1.16	0.95	1.10	1.20	1.37	0.77	1.52
CADMIUM	(g/h)	76	89	83	72	68	82	124	98	82	83	87	50	75
	(ug/Sm3**)	568	605	536	527	437	515	832	668	599	583	562	492	653
	(g/tonne *)	2.77	2.89	2.70	2.65	2.47	3.11	4.32	3.22	3.14	3.28	3.13	2.39	3.98
CHROMIUM	(g/h)	147	82	83	85	55	83	128	219	119	86	116	109	117
	(ug/Sm3**)	1,095	558	538	623	353	520	862	1,491	871	600	745	1,084	1,017
	(g/tonne *)	5.3	2.7	2.7	3.1	2.0	3.1	4.5	7.2	4.6	3.4	4.1	5.3	6.2
COPPER	(g/h)	287	276	199	194	197	228	362	472	252	277	173	177	261
	(ug/Sm3**)	2,134	1,878	1,289	1,429	1,264	1,428	2,436	3,219	1,849	1,937	1,112	1,757	2,263
	(g/tonne *)	10.4	9.0	6.5	7.2	7.2	8.6	12.6	15.5	9.7	10.9	6.2	8.5	13.8
LEAD	(g/h)	1,701	2,164	1,555	1,940	1,125	938	691	380	651	1,179	628	1,158	1,171
	(ug/Sm3**)	12,658	14,706	10,050	14,286	7,229	5,877	4,649	2,592	4,770	8,252	4,036	11,497	10,155
	(g/tonne *)	62	70	51	72	41	36	24	12	25	46	22	56	62
MERCURY	(g/h)	98	86	95	86	91	93	96	94	98	94	87	53	105
	(ug/Sm3**)	726	583	614	634	583	584	646	644	718	661	558	531	914
	(g/tonne *)	3.54	2.79	3.10	3.18	3.30	3.53	3.35	3.10	3.76	3.71	3.10	2.58	5.57
NICKEL	(g/h)	299	73	91	276	40	68	60	231	83	62	81	529	175
	(ug/Sm3**)	2,226	497	586	2,030	257	427	406	1,574	608	435	523	5,247	1,516
	(g/tonne *)	10.8	2.4	3.0	10.2	1.5	2.6	2.1	7.6	3.2	2.4	2.9	25.5	9.2
ZINC	(g/h)	5,310	5,993	4,898	4,233	4,829	5,475	6,474	6,763	6,611	6,186	5,390	5,026	5,380
	(ug/Sm3**)	39,515	40,724	31,654	31,169	31,029	34,312	43,550	46,159	48,469	43,304	34,660	49,887	46,654
	(g/tonne *)	193	195	160	157	176	207	226	222	253	243	193	243	284
PARTICULATE	(g/h)	731,020	683,458	506,688	605,434	514,887	674,975	705,466	570,505	618,071	568,884	527,662	323,382	426,293
	(ug/Sm3**)	5,440,400	4,644,195	3,274,268	4,457,958	3,308,088	4,229,858	4,745,363	3,893,710	4,531,219	3,982,547	3,393,046	3,209,968	3,696,710
	(g/tonne *)	26,508	22,190	16,515	22,388	18,716	25,552	24,609	18,759	23,697	22,369	18,869	15,604	22,509

(continued)

TABLE A-6. PERFORMANCE TEST SUMMARY DATA: FLUE GAS METALS

STEAM LOAD OPERATION TEST #	INTERM GOOD PT-02	NORMAL POOR PT-03	NORMAL POOR PT-04	INTERM V POOR PT-05	HIGH POOR PT-06	NORMAL POOR PT-07	NORMAL GOOD PT-08	NORMAL GOOD PT-09	INTERM GOOD PT-10	NORMAL GOOD PT-11	HIGH GOOD PT-12	LOW GOOD PT-13	LOW GOOD PT-14
FABRIC FILTER OUTLET													
ANTIMONY	(g/h)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(ug/Sm3**)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(g/tonne *)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ARSENIC	(g/h)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(ug/Sm3**)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(g/tonne *)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CADMIUM	(g/h)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(ug/Sm3**)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(g/tonne *)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHROMIUM	(g/h)	2.0	1.2	1.5	1.8	1.1	1.3	4.5	1.6	1.2	1.1	1.2	1.3
	(ug/Sm3**)	15	8	10	15	8	8	31	11	9	8	8	12
	(g/tonne *)	0.071	0.039	0.049	0.068	0.040	0.048	0.157	0.052	0.045	0.044	0.043	0.061
COPPER	(g/h)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(ug/Sm3**)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(g/tonne *)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
LEAD	(g/h)	5.7	4.6	5.7	5.9	5.4	4.3	5.8	5.4	5.5	7.5	7.4	9.2
	(ug/Sm3**)	45	31	37	47	37	29	40	39	43	55	47	91
	(g/tonne *)	0.21	0.15	0.18	0.22	0.19	0.16	0.20	0.18	0.21	0.29	0.27	0.45
MERCURY	(g/h)	0.82	3.13	2.02	0.85	1.68	1.12	0.60	2.00	1.06	2.40	0.51	1.13
	(ug/Sm3**)	6.5	21.4	13.4	6.8	11.5	7.4	4.2	14.1	8.4	17.8	3.2	11.0
	(g/tonne *)	0.030	0.102	0.066	0.031	0.061	0.042	0.021	0.066	0.041	0.095	0.018	0.054
NICKEL	(g/h)	0.84	0.56	0.75	0.28	0.55	0.90	9.54	0.74	0.27	0.83	0.56	3.99
	(ug/Sm3**)	6.6	3.8	5.0	2.2	3.8	6.0	66.7	5.2	2.2	6.1	3.5	39.1
	(g/tonne *)	0.030	0.018	0.025	0.010	0.020	0.034	0.333	0.024	0.010	0.033	0.020	0.193
ZINC	(g/h)	4.6	10.9	7.3	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(ug/Sm3**)	36	74	48	ND	ND	ND	ND	ND	ND	ND	ND	ND
	(g/tonne *)	0.17	0.35	0.24	ND	ND	ND	ND	ND	ND	ND	ND	ND
PARTICULATE	(g/h)	729	803	1153	481	389	665	555	818	518	772	634	785
	(ug/Sm3**)	5,774	5,500	7,624	3,880	2,681	4,391	3,882	5,790	4,092	5,703	3,978	7,688
	(g/tonne *)	26.4	26.1	37.6	17.8	14.2	25.2	19.4	26.9	19.9	30.4	22.7	37.9

** - corrected to 12% CO2; * - refuse as fired; ND - values below detection limit.

Appendix B

Combustion System Summary by Performance Test Condition


COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	160	klb/h
TEMPERATURE	985	°C
— Furnace	588	°C
— Boiler Inlet	356	°C
— Economizer Outlet	186	°C
— Air Heater Outlet		
UNDERORATE : OVERFIRE AIR RATIO	82:48	%
EFFICIENCY		
— Output/Input	71.18	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
GAS			
— FLOW	NA	133,374	Sm ³ /h
— TEMPERATURE	NA	191	°C
— MOISTURE	NA	12.2	%
CONTINUOUS MONITORS			
— O ₂	NA	9.9	%
— CO ₂	NA	10.0	%
— CO	NA	114	ppm
— NO _x	NA	167	ppm
— SO ₂	NA	182	ppm
— HCl	NA	432	ppm
— THC	NA	4.7	ppm
TRACE ORGANICS			
— PCDD	NA	109	ng/Sm ³
— PCDF	NA	404	ng/Sm ³
— PCB	NA	ND	ng/Sm ³
— CB	NA	3,957	ng/Sm ³
— CP	NA	13,311	ng/Sm ³
— PAH	NA	3,516	ng/Sm ³
PARTICULATE	NA	3,453.3	mg/Sm ³
TRACE METALS			
— Sb	NA	113	µg/Sm ³
— As	NA	205	µg/Sm ³
— Cd	NA	573	µg/Sm ³
— Cr	NA	1,050	µg/Sm ³
— Cu	NA	2,010	µg/Sm ³
— Pb	NA	10,826	µg/Sm ³
— Hg	NA	723	µg/Sm ³
— Ni	NA	3,381	µg/Sm ³
— Zn	NA	48,270	µg/Sm ³

* Corrected to 12% CO₂

REFUSE DERIVED FUEL		
FEED RATE	18,939	kg/h
MOISTURE	17.1	% wet, as fired*
HHV	6,881	Bit/lb, wet
TRACE ORGANICS		
— PCDD	6.3	mg/tonne
— PCDF	0.17	mg/tonne
— PCB	ND	mg/tonne
— CB	22	mg/tonne
— CP	626	mg/tonne
— PAH	57,088	mg/tonne
TRACE METALS		
— Sb	6.5	g/tonne
— As	1.8	g/tonne
— Cd	4.3	g/tonne
— Cr	26	g/tonne
— Cu	243	g/tonne
— Pb	180	g/tonne
— Hg	0.05	g/tonne
— Ni	37	g/tonne
— Zn	455	g/tonne

* PT 14 only




ASH	BOTTOM ASH	GRATE SIFTINGS	ECONOMIZER ASH	
ASH RATE (dry)	2,373	89	12.7	kg/h
TRACE ORGANICS				
— PCDD	ND	ND	ND	ng/g
— PCDF	ND	ND	ND	ng/g
— PCB	ND	ND	ND	ng/g
— CB	ND	ND	ND	ng/g
— CP	10	24	24	ng/g
— PAH	44	ND	ND	ng/g
TRACE METALS				
— Sb	1.7	21	8.1	µg/g
— As	12	9.7	14.4	µg/g
— Cd	9.1	8.8	6.5	µg/g
— Cr	316	297	310	µg/g
— Cu	4,369	3,958	1,130	µg/g
— Pb	3,601	8,545	940	µg/g
— Hg	ND	0.56	0.028	µg/g
— Ni	333	432	660	µg/g
— Zn	1,877	1,628	1,819	µg/g

COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	193	kg/h
TEMPERATURE		°C
— Furnace	1,018	°C
— Boiler Inlet	905	°C
— Economizer Outlet	364	°C
— Air Heater Outlet	193	°C
UNDERGRATE : OVERFIRE AIR RATIO	48:52	%
EFFICIENCY		%
— Output/Input	53.99	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
GAS			
— FLOW	NA	154,014	Sm ³ /h
— TEMPERATURE	NA	192	°C
— MOISTURE	NA	14.1	%
CONTINUOUS MONITORS			
— O ₂	NA	9.2	%
— CO ₂	NA	10.5	%
— CO	NA	93	ppm
— NO _x	NA	185	ppm
— SO ₂	NA	186	ppm
— HCl	NA	450	ppm
— THC	NA	2.5	ppm
TRACE ORGANICS			
— PCDD	174	228	ng/Sm ³
— PCDF	816	579	ng/Sm ³
— PCB	252	20	ng/Sm ³
— CB	12,030	6,045	ng/Sm ³
— CP	21,181	14,253	ng/Sm ³
— PAH	10,512	7,333	ng/Sm ³
PARTICULATE	NA	4,985.8	mg/Sm ³
TRACE METALS			
— Sb	NA	120	µg/Sm ³
— As	NA	240	µg/Sm ³
— Cd	NA	584	µg/Sm ³
— Cr	NA	983	µg/Sm ³
— Cu	NA	1,992	µg/Sm ³
— Pb	NA	8,714	µg/Sm ³
— Hg	NA	722	µg/Sm ³
— Ni	NA	1,417	µg/Sm ³
— Zn	NA	43,992	µg/Sm ³

* Corrected to 12% CO₂.

REFUSE DERIVED FUEL		
FEED RATE	26,830	kg/h
MOISTURE	21.9	% wet, as fired
HHV	5,704	Btu/lb, wet
TRACE ORGANICS		
— PCDD	2.5	mg/tonne
— PCDF	0.087	mg/tonne
— PCB	57	mg/tonne
— CB	13	mg/tonne
— CP	473	mg/tonne
— PAH	5,137	mg/tonne
TRACE METALS		
— Sb	2.1	g/tonne
— As	2.3	g/tonne
— Cd	1.5	g/tonne
— Cr	20	g/tonne
— Cu	641	g/tonne
— Pb	87	g/tonne
— Hg	0.045	g/tonne
— Ni	34	g/tonne
— Zn	335	g/tonne




ASH	BOTTOM ASH	GRATE EFFINGS	ECONOMIZER ASH	
ASH RATE (dry)	3,068	115.5	16.7	kg/h
TRACE ORGANICS				
— PCDD	ND	ND	ND	ng/g
— PCDF	ND	0.029	ND	ng/g
— PCB	ND	ND	ND	ng/g
— CB	ND	ND	ND	ng/g
— CP	12	15	15	ng/g
— PAH	6,432	6.0	6.0	ng/g
TRACE METALS				
— Sb	ND	26	10	µg/g
— As	10	10	12	µg/g
— Cd		8.7	8	µg/g
— Cr	184	409	245	µg/g
— Cu	6,712	8,365	660	µg/g
— Pb	1,247	12,694	785	µg/g
— Hg	0.04	0.45	0.01	µg/g
— Ni	337	693	355	µg/g
— Zn	1,623	3,242	1,200	µg/g

COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	184	kg/h
TEMPERATURE		°C
— Furnace	1,020	°C
— Boiler Inlet	805	°C
— Economizer Outlet	367	°C
— Air Heater Outlet	190	°C
UNDERGRATE : OVERFIRE AIR RATIO	62:38	%
EFFICIENCY		%
— Output/Input	50.65	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
GAS			
— FLOW	NA	146,831	Sm ³ /h
— TEMPERATURE	NA	189	°C
— MOISTURE	NA	13.3	%
CONTINUOUS MONITORS			
— O ₂	NA	8.7	%
— CO ₂	NA	11.0	%
— CO	NA	835	ppm
— NO _x	NA	149	ppm
— SO ₂	NA	169	ppm
— HCl	NA	469	ppm
— THC	NA	82.4	ppm
TRACE ORGANICS			
— PCDD	NA	880	ng/Sm ³
— PCDF	NA	1,281	ng/Sm ³
— PCB	NA	20	ng/Sm ³
— CB	NA	15,801	ng/Sm ³
— CP	NA	113,968	ng/Sm ³
— PAH	NA	111,975	ng/Sm ³
PARTICULATE	NA	4,457.96	mg/Sm ³
TRACE METALS			
— Sb	NA	122	µg/Sm ³
— As	NA	230	µg/Sm ³
— Cd	NA	827	µg/Sm ³
— Cr	NA	823	µg/Sm ³
— Cu	NA	1,429	µg/Sm ³
— Pb	NA	14,286	µg/Sm ³
— Hg	NA	834	µg/Sm ³
— Ni	NA	2,030	µg/Sm ³
— Zn	NA	31,169	µg/Sm ³

* Corrected to 12% CO₂.

REFUSE DERIVED FUEL		
FEED RATE	27,043	kg/h
MOISTURE	23.3	% wet, as fired
HHV	8,233	Btu/lb, wet
TRACE ORGANICS		
— PCDD	8.2	mg/tonne
— PCDF	ND	mg/tonne
— PCB	184	mg/tonne
— CB	22	mg/tonne
— CP	825	mg/tonne
— PAH	4,065	mg/tonne
TRACE METALS		
— Sb	4.7	g/tonne
— As	2.2	g/tonne
— Cd	3.0	g/tonne
— Cr	16	g/tonne
— Cu	26	g/tonne
— Pb	159	g/tonne
— Hg	0.041	g/tonne
— Ni	19	g/tonne
— Zn	206	g/tonne




ASH	BOTTOM ASH	GRATE SIFTINGS	ECONOMIZER ASH	
ASH RATE (dry)	2,828	103	13.8	kg/h
TRACE ORGANICS				
— PCDD	ND		0.43	ng/g
— PCDF	ND		1.83	ng/g
— PCB	ND		ND	ng/g
— CB	ND		10	ng/g
— CP	15		10	ng/g
— PAH	76		475	ng/g
TRACE METALS				
— Sb	1.1	25.5	13	µg/g
— As	10.5	8.1	15	µg/g
— Cd	6	11	5.9	µg/g
— Cr	196	454	330	µg/g
— Cu	3,835	856	679	µg/g
— Pb	1,913	3,881	949	µg/g
— Hg	ND	2.0	0.02	µg/g
— Ni	294	1,136	1,289	µg/g
— Zn	1,153	1,789	1,408	µg/g

COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	211	klb/h
TEMPERATURE		
— Furnace	1,025	°C
— Boiler Inlet	574	°C
— Economizer Outlet	377	°C
— Air Heater Outlet	194	°C
UNDERGRATE : OVERFIRE AIR RATIO	50:50	%
EFFICIENCY		
— Output/Input	60.16	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
QAS			
— FLOW	NA	147,679	Sm ³ /h
— TEMPERATURE	NA	194	°C
— MOISTURE	NA	15.5	%
CONTINUOUS MONITORS			
— O ₂	NA	7.7	%
— CO ₂	NA	11.8	%
— CO	NA	83	ppm
— NO _x	NA	185	ppm
— SO ₂	NA	179	ppm
— HCl	NA	461	ppm
— THC	NA	3.3	ppm
TRACE ORGANICS			
— PCDD	200	125	ng/Sm ³
— PCDF	1,297	891	ng/Sm ³
— PCB	100	33	ng/Sm ³
— CB	12,373	5,482	ng/Sm ³
— CP	38,966	14,322	ng/Sm ³
— PAH	44,827	16,462	ng/Sm ³
PARTICULATE			
	NA	4,207.21	mg/Sm ³
TRACE METALS			
— Sb	NA	135	µg/Sm ³
— As	NA	211	µg/Sm ³
— Cd	NA	694	µg/Sm ³
— Cr	NA	984	µg/Sm ³
— Cu	NA	2,531	µg/Sm ³
— Pb	NA	5,164	µg/Sm ³
— Hg	NA	650	µg/Sm ³
— Ni	NA	805	µg/Sm ³
— Zn	NA	44,338	µg/Sm ³

* Corrected to 12% CO₂

REFUSE DERIVED FUEL		
FEED RATE	28,170	kg/h
MOISTURE	23.7	% wet, as fired
HHV	5,704	Btu/lb, wet
TRACE ORGANICS		
— PCDD	3.5	mg/tonne
— PCDF	0.34	mg/tonne
— PCB	270	mg/tonne
— CB	5.9	mg/tonne
— CP	452	mg/tonne
— PAH	4,640	mg/tonne
TRACE METALS		
— Sb	3.8	g/tonne
— As	1.9	g/tonne
— Cd	2.1	g/tonne
— Cr	66	g/tonne
— Cu	583	g/tonne
— Pb	429	g/tonne
— Hg	0.116	g/tonne
— Ni	52	g/tonne
— Zn	286	g/tonne




ASH	BOTTOM ASH	GRATE SFTINGS	ECONOMIZER ASH	
ASH RATE (dry)	3,123	109	18.5	kg/h
TRACE ORGANICS				
— PCDD	0.10		0.061	ng/g
— PCDF	0.17		0.38	ng/g
— PCB	ND		ND	ng/g
— CB	ND		ND	ng/g
— CP	2.5		13	ng/g
— PAH	16		14	ng/g
TRACE METALS				
— Sb	1.9	37	3.2	µg/g
— As	10	11	11	µg/g
— Cd	7	10	7.3	µg/g
— Cr	204	282	400	µg/g
— Cu	4,545	2,337	1,540	µg/g
— Pb	2,399	9,733	923	µg/g
— Hg	ND	0.88	0.14	µg/g
— Ni	211	401	377	µg/g
— Zn	1,395	2,277	1,933	µg/g

COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	220	ktb/h
TEMPERATURE		
— Furnace	1,033	°C
— Boiler Inlet	579	°C
— Economizer Outlet	376	°C
— Air Heater Outlet	202	°C
UNDERGRATE : OVERFIRE AIR RATIO	80:90	%
EFFICIENCY		
— Output/Input	88.87	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
GAS			
— FLOW	NA	153,452	Sm ³ /h
— TEMPERATURE	NA	199	°C
— MOISTURE	NA	16.0	%
CONTINUOUS MONITORS			
— O ₂	NA	7.2	%
— CO ₂	NA	12.0	%
— CO	NA	308	ppm
— NO _x	NA	168	ppm
— SO ₂	NA	189	ppm
— HCl	NA	430	ppm
— THC	NA	13.9	ppm
TRACE ORGANICS			
— PCDD	390	196	ng/Sm ³ *
— PCDF	1,932	732	ng/Sm ³ *
— PCB	269	11	ng/Sm ³ *
— CB	13,854	6,944	ng/Sm ³ *
— CP	89,258	24,106	ng/Sm ³ *
— PAH	88,865	53,846	ng/Sm ³ *
PARTICULATE	NA	4,049.4	mg/Sm ³ *
TRACE METALS			
— Sb	NA	60	µg/Sm ³ *
— As	NA	186	µg/Sm ³ *
— Cd	NA	552	µg/Sm ³ *
— Cr	NA	639	µg/Sm ³ *
— Cu	NA	1,531	µg/Sm ³ *
— Pb	NA	10,211	µg/Sm ³ *
— Hg	NA	594	µg/Sm ³ *
— Ni	NA	603	µg/Sm ³ *
— Zn	NA	35,563	µg/Sm ³ *

* Corrected to 12% CO₂.

REFUSE DERIVED FUEL		
FEED RATE	29,299	kg/h
MOISTURE	23.8	% wet, as fired
HHV	5,883	Btu/lb, wet
TRACE ORGANICS		
— PCDD	3.9	mg/tonne
— PCDF	0.058	mg/tonne
— PCB	ND	mg/tonne
— CB	702	mg/tonne
— CP	580	mg/tonne
— PAH	5,542	mg/tonne
TRACE METALS		
— Sb	7.9	g/tonne
— As	4.8	g/tonne
— Cd	3.5	g/tonne
— Cr	86	g/tonne
— Cu	100	g/tonne
— Pb	296	g/tonne
— Hg	0.052	g/tonne
— Ni	68	g/tonne
— Zn	167	g/tonne




ASH	BOTTOM ASH	GRATE SIFTINGS	ECONOMIZER ASH	
ASH RATE (dry)	3,950	115	13.5	kg/h
TRACE ORGANICS				
— PCDD	ND	ND	0.35	ng/g
— PCDF	ND	ND	ND	ng/g
— PCB	ND	ND	ND	ng/g
— CB	11	11	78	ng/g
— CP	161	78	78	ng/g
— PAH				
TRACE METALS				
— Sb	0.4	45	8.9	µg/g
— As	8	8.7	12	µg/g
— Cd	7	11	7.0	µg/g
— Cr	232	337	307	µg/g
— Cu	2,781	1,540	606	µg/g
— Pb	1,601	7,712	949	µg/g
— Hg	0.103	1.8	0.019	µg/g
— Ni	172	337	396	µg/g
— Zn	1,200	4,205	1,519	µg/g

COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	235	klb/h
TEMPERATURE		°C
— Furnace	1,049	°C
— Boiler Inlet	607	°C
— Economizer Outlet	387	°C
— Air Heater Outlet	197	°C
UNDERGRATE : OVERFIRE AIR RATIO	47:53	%
EFFICIENCY		%
— Output/Input	62.73	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
GAS			
— FLOW	NA	143,620	Sm ³ /h
— TEMPERATURE	NA	201	°C
— MOISTURE	NA	16.3	%
CONTINUOUS MONITORS			
— O ₂	NA	6.4	%
— CO ₂	NA	12.9	%
— CO	NA	105	ppm
— NO _x	NA	180	ppm
— SO ₂	NA	198	ppm
— HCl	NA	470	ppm
— THC	NA	6.1	ppm
TRACE ORGANICS			
— PCDD	NA	67	ng/Sm ³
— PCDF	NA	215	ng/Sm ³
— PCB	NA	34	ng/Sm ³
— CB	NA	6,027	ng/Sm ³
— CP	NA	16,636	ng/Sm ³
— PAH	NA	16,208	ng/Sm ³
PARTICULATE	NA	3,393.05	mg/Sm ³
TRACE METALS			
— Sb	NA	173	µg/Sm ³
— As	NA	247	µg/Sm ³
— Cd	NA	562	µg/Sm ³
— Cr	NA	745	µg/Sm ³
— Cu	NA	1,112	µg/Sm ³
— Pb	NA	4,036	µg/Sm ³
— Hg	NA	658	µg/Sm ³
— Ni	NA	623	µg/Sm ³
— Zn	NA	34,660	µg/Sm ³

* Corrected to 12% CO₂.

REFUSE DERIVED FUEL		
FEED RATE	27,964	kg/h
MOISTURE	20.0	% wet, as fired
HHV	6,815	Btu/lb, wet
TRACE ORGANICS		
— PCDD	4.8	mg/tonne
— PCDF	0.11	mg/tonne
— PCB	188	mg/tonne
— CB	53	mg/tonne
— CP	558	mg/tonne
— PAH	11,169	mg/tonne
TRACE METALS		
— Sb	7.3	g/tonne
— As	3.7	g/tonne
— Cd	3.0	g/tonne
— Cr	11	g/tonne
— Cu	5,886	g/tonne
— Pb	324	g/tonne
— Hg	0.038	g/tonne
— Ni	23	g/tonne
— Zn	3,335	g/tonne




ASH	BOTTOM ASH	GRATE SFTINGS	ECONOMIZER ASH	
ASH RATE (dry)	3,280	106	17.0	kg/h
TRACE ORGANICS				
— PCDD	ND	ND	ND	ng/g
— PCDF	ND	0.11	ND	ng/g
— PCB	ND	ND	ND	ng/g
— CB	ND	ND	ND	ng/g
— CP	ND	10	ND	ng/g
— PAH	196	ND	ND	ng/g
TRACE METALS				
— Sb	2.1	23	2.7	µg/g
— As	14	13	12	µg/g
— Cd	4	13	8.9	µg/g
— Cr	189	192	210	µg/g
— Cu	16,067	1,616	580	µg/g
— Pb	1,289	8,558	979	µg/g
— Hg	0.026	0.76	ND	µg/g
— Ni	172	253	260	µg/g
— Zn	1,100	1,930	1,349	µg/g

COMBUSTION SYSTEM OPERATING CONDITIONS		
STEAM FLOW	234	kg/h
TEMPERATURE		°C
— Furnace	976	°C
— Boiler Inlet	812	°C
— Economizer Outlet	365	°C
— Air Heater Outlet	185	°C
UNDERGRATE : OVERFIRE AIR RATIO	43:57	%
EFFICIENCY		%
— Output/Input	62.97	%

FLUE GAS	PREHEATER INLET	SPRAY DRYER INLET	
GAS			
— FLOW	NA	181,062	Sm ³ /h
— TEMPERATURE	NA	185	°C
— MOISTURE	NA	14.0	%
CONTINUOUS MONITORS			
— O ₂	NA	7.9	%
— CO ₂	NA	11.5	%
— CO	NA	397	ppm
— NO _x	NA	157	ppm
— SO ₂	NA	192	ppm
— HCl	NA	404	ppm
— THC	NA	28.6	ppm
TRACE ORGANICS			
— PCDD	NA	317	ng/Sm ³
— PCDF	NA	885	ng/Sm ³
— PCB	NA	12	ng/Sm ³
— CB	NA	9,403	ng/Sm ³
— CP	NA	41,588	ng/Sm ³
— PAH	NA	88,626	ng/Sm ³
PARTICULATE			
	NA	3,308.09	mg/Sm ³
TRACE METALS			
— Sb	NA	51	µg/Sm ³
— As	NA	194	µg/Sm ³
— Cd	NA	437	µg/Sm ³
— Cr	NA	353	µg/Sm ³
— Cu	NA	1,264	µg/Sm ³
— Pb	NA	7,229	µg/Sm ³
— Hg	NA	583	µg/Sm ³
— Ni	NA	257	µg/Sm ³
— Zn	NA	31,029	µg/Sm ³

REFUSE DERIVED FUEL		
FEED RATE	27,511	kg/h
MOISTURE	17.2	% wet, as fired
HHV	6,991	BRU/lb, wet
TRACE ORGANICS		
— PCDD	13	mg/tonne
— PCDF	0.15	mg/tonne
— PCB	ND	mg/tonne
— CB	ND	mg/tonne
— CP	2,278	mg/tonne
— PAH	8,263	mg/tonne
TRACE METALS		
— Sb	14.0	g/tonne
— As	1.6	g/tonne
— Cd	2.0	g/tonne
— Cr	13	g/tonne
— Cu	404	g/tonne
— Pb	143	g/tonne
— Hg	0.034	g/tonne
— Ni	13	g/tonne
— Zn	357	g/tonne

* Corrected to 12% CO₂



ASH	BOTTOM ASH	GRATE SFTINGS	ECONOMIZER ASH	
ASH RATE (dry)	3,352	71	10.5	kg/h
TRACE ORGANICS				
— PCDD	ND		0.03	ng/g
— PCDF	ND		1.2	ng/g
— PCB	ND		ND	ng/g
— CB	ND		ND	ng/g
— CP	14		4.0	ng/g
— PAH	136		1,087	ng/g
TRACE METALS				
— Sb	ND	44	9.3	µg/g
— As	7.8	9.4	18	µg/g
— Cd	4.6	12	6.2	µg/g
— Cr	158	284	150	µg/g
— Cu	1,121	11,534	509	µg/g
— Pb	1,016	16,829	659	µg/g
— Hg	0.32	1.0	0.024	µg/g
— Ni	96	303	170	µg/g
— Zn	1,261	2,798	1,758	µg/g


Appendix C

**Air Pollution Control System Summary by Performance
Test Condition**

APC SYSTEM OPERATING CONDITIONS			
RUN		PT07	
FFO SO ₂ SET POINT		LOW	
SDO TEMP. SET POINT		120	°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	158,054	NA	172,768	Sm ³ /h
— TEMPERATURE	201	124	108	°C
— MOISTURE	15.7	NA	18.9	%
CONTINUOUS MONITORS				
— O ₂	7.2	NA	8.4	%
— CO ₂	12.1	11.1	10.4	%
— CO	338	NA	411	ppm
— NO _x	172	NA	NA	ppm
— SO ₂	183	127	17	ppm
— HCl	399	10	8	ppm
— THC	13.3	NA	12.4	ppm
TRACE ORGANICS				
— PCDD	207	NA	0.167	ng/Sm ³
— PCDF	796	NA	0.145	ng/Sm ³
— PCB	17	NA	ND	ng/Sm ³
— CB	7,074	NA	108	ng/Sm ³
— CP	25,168	NA	226	ng/Sm ³
— PAH	51,774	NA	1,390	ng/Sm ³
PARTICULATE	4,229.9	NA	4.39	mg/Sm ³
TRACE METALS				
— Sb	85	NA	ND	µg/Sm ³
— As	176	NA	ND	µg/Sm ³
— Cd	515	NA	ND	µg/Sm ³
— Cr	520	NA	8.4	µg/Sm ³
— Cu	1,428	NA	ND	µg/Sm ³
— Pb	5,877	NA	29	µg/Sm ³
— Hg	884	NA	7.4	µg/Sm ³
— Ni	427	NA	6.0	µg/Sm ³
— Zn	34,312	NA	ND	µg/Sm ³

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	550	.kg/h
TRACE ORGANICS		
— PCDD	154	ng/g
— PCDF	271	ng/g
— PCB	ND	ng/g
— CB	841	ng/g
— CP	4,997	ng/g
— PAH	1,992	ng/g
TRACE METALS		
— Sb	9.3	µg/g
— As	17	µg/g
— Cd	90	µg/g
— Cr	147	µg/g
— Cu	323	µg/g
— Pb	3,051	µg/g
— Hg	37	µg/g
— Ni	249	µg/g
— Zn	9,200	µg/g

APC SYSTEM OPERATING CONDITIONS			
RUN		PT10	
FFO SO ₂ SET POINT		MEDIUM	
SDO TEMP. SET POINT		120	°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	158,978	NA	187,398	Sm ³ /h
— TEMPERATURE	193	123	106	°C
— MOISTURE	13.8	NA	15.4	%
CONTINUOUS MONITORS				
— O ₂	9.2	NA	10.9	%
— CO ₂	10.5	9.6	9.1	%
— CO	77	NA	39	ppm
— NO _x	186	NA	NA	ppm
— SO ₂	194	131	74	ppm
— HCl	429	15	19	ppm
— THC	1.6	NA	1.9	ppm
TRACE ORGANICS				
— PCDD	243	NA	0.181	ng/Sm ³
— PCDF	424	NA	0.103	ng/Sm ³
— PCB	13	NA	ND	ng/Sm ³
— CB	8,170	NA	42	ng/Sm ³
— CP	16,198	NA	79	ng/Sm ³
— PAH	6,289	NA	2,603	ng/Sm ³
PARTICULATE	4,531.2	NA	4.09	mg/Sm ³
TRACE METALS				
— Sb	156	NA	ND	µg/Sm ³
— As	210	NA	ND	µg/Sm ³
— Cd	599	NA	ND	µg/Sm ³
— Cr	871	NA	9.4	µg/Sm ³
— Cu	1,849	NA	ND	µg/Sm ³
— Pb	4,770	NA	43	µg/Sm ³
— Hg	718	NA	8.4	µg/Sm ³
— Ni	608	NA	2.2	µg/Sm ³
— Zn	48,469	NA	ND	µg/Sm ³

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	1,166	kg/h
TRACE ORGANICS		
— PCDD	27	ng/g
— PCDF	47	ng/g
— PCB	ND	ng/g
— CB	664	ng/g
— CP	1,924	ng/g
— PAH	1,402	ng/g
TRACE METALS		
— Sb	10	µg/g
— As	19	µg/g
— Cd	87	µg/g
— Cr	274	µg/g
— Cu	637	µg/g
— Pb	2,352	µg/g
— Hg	27	µg/g
— Ni	304	µg/g
— Zn	5,879	µg/g

APC SYSTEM OPERATING CONDITIONS			
RUN	PT02	PT05	
FFO SO ₂ SET POINT	HIGH	HIGH	
SDO TEMP. SET POINT	120	120	°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	149,940	NA	159,958	Sm ³ /h
— TEMPERATURE	191	122	106	°C
— MOISTURE	13.8	NA	15.7	%
CONTINUOUS MONITORS				
— O ₂	8.9	NA	10.6	%
— CO ₂	10.7	8.6	8.4	%
— CO	321	NA	508	ppm
— NO _x	166	NA	NA	ppm
— SO ₂	173	NA	112	ppm
— HCl	470	50	20	ppm
— THC	28.7	NA	18.5	ppm
TRACE ORGANICS				
— PCDD	396	NA	0.225	ng/Sm ³ *
— PCDF	1,007	NA	0.622	ng/Sm ³ *
— PCB	23	NA	ND	ng/Sm ³ *
— CB	10,860	NA	409	ng/Sm ³ *
— CP	62,938	NA	1,645	ng/Sm ³ *
— PAH	60,176	NA	4,844	ng/Sm ³ *
PARTICULATE	4,949	NA	4.82	mg/Sm ³ *
TRACE METALS				
— Sb	103	NA	ND	µg/Sm ³ *
— As	250	NA	ND	µg/Sm ³ *
— Cd	647	NA	ND	µg/Sm ³ *
— Cr	859	NA	15.1	µg/Sm ³ *
— Cu	1,781	NA	ND	µg/Sm ³ *
— Pb	13,472	NA	46.2	µg/Sm ³ *
— Hg	660	NA	6.6	µg/Sm ³ *
— Ni	2,128	NA	4.4	µg/Sm ³ *
— Zn	35,342	NA	ND	µg/Sm ³ *

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	429	kg/h
TRACE ORGANICS		
— PCDD	96	ng/g
— PCDF	71	ng/g
— PCB	ND	ng/g
— CB	1,085	ng/g
— CP	2,870	ng/g
— PAH	9,437	ng/g
TRACE METALS		
— Sb	9.0	µg/g
— As	15	µg/g
— Cd	70	µg/g
— Cr	264	µg/g
— Cu	431	µg/g
— Pb	1,987	µg/g
— Hg	25	µg/g
— Ni	744	µg/g
— Zn	5,463	µg/g

* PT 05 only

APC SYSTEM OPERATING CONDITIONS			
RUN	PT06		
FFO SO ₂ SET POINT	LOW		
SDO TEMP. SET POINT	190		°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	161,062	NA	172,107	Sm ³ /h
— TEMPERATURE	185	141	123	°C
— MOISTURE	14.0	NA	15.5	%
CONTINUOUS MONITORS				
— O ₂	7.9	NA	9.8	%
— CO ₂	11.5	10.8	10.2	%
— CO	397	NA	NA	ppm
— NO _x	157	NA	NA	ppm
— SO ₂	192	108	9	ppm
— HCl	404	20	10	ppm
— THC	28.6	NA	26.1	ppm
TRACE ORGANICS				
— PCDD	317	NA	0.346	ng/Sm ³ *
— PCDF	885	NA	0.162	ng/Sm ³ *
— PCB	12	NA	ND	ng/Sm ³ *
— CB	9,403	NA	839	ng/Sm ³ *
— CP	41,588	NA	1,282	ng/Sm ³ *
— PAH	89,626	NA	2,034	ng/Sm ³ *
PARTICULATE	3,308.1	NA	2.68	mg/Sm ³ *
TRACE METALS				
— Sb	51	NA	ND	µg/Sm ³ *
— As	194	NA	ND	µg/Sm ³ *
— Cd	437	NA	ND	µg/Sm ³ *
— Cr	353	NA	7.6	µg/Sm ³ *
— Cu	1,264	NA	ND	µg/Sm ³ *
— Pb	7,229	NA	37	µg/Sm ³ *
— Hg	683	NA	11.5	µg/Sm ³ *
— Ni	257	NA	3.8	µg/Sm ³ *
— Zn	31,029	NA	ND	µg/Sm ³ *

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	1,239	kg/h
TRACE ORGANICS		
— PCDD	227	ng/g
— PCDF	282	ng/g
— PCB	ND	ng/g
— CB	1,684	ng/g
— CP	6,095	ng/g
— PAH	7,431	ng/g
TRACE METALS		
— Sb	10	µg/g
— As	19	µg/g
— Cd	96	µg/g
— Cr	154	µg/g
— Cu	374	µg/g
— Pb	3,666	µg/g
— Hg	36	µg/g
— Ni	374	µg/g
— Zn	9,788	µg/g

APC SYSTEM OPERATING CONDITIONS				
RUN	PT 12	PT 13	PT 14	
FFO SO ₂ SET POINT	MEDIUM	MEDIUM	MEDIUM	
SDO TEMP. SET POINT	190	190	190	°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	136,789	NA	155,124	Sm ³ /h
— TEMPERATURE	194	140	117	°C
— MOISTURE	13.6	NA	14.5	%
CONTINUOUS MONITORS				
— O ₂	8.7	NA	10.7	%
— CO ₂	11.0	10.2	8.5	%
— CO	111	NA	201	ppm
— NO _x	171	NA	NA	ppm
— SO ₂	187	136	59	ppm
— HCl	445	32	18	ppm
— THC	5.2	NA	3.0	ppm
TRACE ORGANICS				
— PCDD	95	NA	0.062	ng/Sm ³
— PCDF	341	NA	0.122	ng/Sm ³
— PCB	ND	NA	ND	ng/Sm ³
— CB	4,647	NA	ND	ng/Sm ³
— CP	14,419	NA	87	ng/Sm ³
— PAH	7,747	NA	2,852	ng/Sm ³
PARTICULATE	3,433	NA	5.46	mg/Sm ³
TRACE METALS				
— Sb	133	NA	ND	µg/Sm ³
— As	219	NA	ND	µg/Sm ³
— Cd	569	NA	ND	µg/Sm ³
— Cr	948	NA	17.2	µg/Sm ³
— Cu	1,711	NA	ND	µg/Sm ³
— Pb	8,563	NA	43	µg/Sm ³
— Hg	668	NA	9.2	µg/Sm ³
— Ni	2,428	NA	22.9	µg/Sm ³
— Zn	43,733	NA	ND	µg/Sm ³

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	724	kg/h
TRACE ORGANICS		
— PCDD	102	ng/g
— PCDF	111	ng/g
— PCB	ND	ng/g
— CB	1,218	ng/g
— CP	1,832	ng/g
— PAH	4,093	ng/g
TRACE METALS		
— Sb	12.8	µg/g
— As	19	µg/g
— Cd	118	µg/g
— Cr	207	µg/g
— Cu	483	µg/g
— Pb	2,812	µg/g
— Hg	39	µg/g
— Ni	394	µg/g
— Zn	6,339	µg/g

APC SYSTEM OPERATING CONDITIONS			
RUN	PT08		
FFO SO ₂ SET POINT	HIGH		
SDO TEMP. SET POINT	190		°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS	150,203	NA	184,013	Sm ³ /h
— FLOW	199	142	118	°C
— TEMPERATURE	18.3	NA	18.0	%
— MOISTURE				
CONTINUOUS MONITORS				
— O ₂	7.5	NA	9.6	%
— CO ₂	11.8	11	10.4	%
— CO	89	NA	35	ppm
— NO _x	193	NA	NA	ppm
— SO ₂	184	164	126	ppm
— HCl	538	44	41	ppm
— THC	3.0	NA	1.6	ppm
TRACE ORGANICS				
— PCDD	211	NA	0.286	ng/Sm ³
— PCDF	951	NA	0.467	ng/Sm ³
— PCB	24	NA	7	ng/Sm ³
— CB	7,071	NA	112	ng/Sm ³
— CP	20,226	NA	190	ng/Sm ³
— PAH	10,259	NA	2,386	ng/Sm ³
PARTICULATE	4,745.4	NA	3.88	mg/Sm ³
TRACE METALS				
— Sb	133	NA	ND	µg/Sm ³
— As	224	NA	ND	µg/Sm ³
— Cd	832	NA	ND	µg/Sm ³
— Cr	862	NA	31.4	µg/Sm ³
— Cu	2,436	NA	ND	µg/Sm ³
— Pb	4,649	NA	40	µg/Sm ³
— Hg	646	NA	4.2	µg/Sm ³
— Ni	406	NA	86.7	µg/Sm ³
— Zn	43,550	NA	ND	µg/Sm ³

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	434	kg/h
TRACE ORGANICS		
— PCDD	62	ng/g
— PCDF	96	ng/g
— PCB	ND	ng/g
— CB	729	ng/g
— CP	1,636	ng/g
— PAH	2,905	ng/g
TRACE METALS		
— Sb	12.7	µg/g
— As	22	µg/g
— Cd	62	µg/g
— Cr	210	µg/g
— Cu	717	µg/g
— Pb	2,439	µg/g
— Hg	25	µg/g
— Ni	392	µg/g
— Zn	5,738	µg/g

APC SYSTEM OPERATING CONDITIONS			
RUN	PT03	PT11	
FFO SO ₂ SET POINT	LOW	LOW	
SDO TEMP. SET POINT	165	165	°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	147,186	NA	161,525	Sm ³ /h
— TEMPERATURE	199	165	140	°C
— MOISTURE	16.1	NA	15.2	%
CONTINUOUS MONITORS				
— O ₂	7.4	NA	8.5	%
— CO ₂	11.8	11.0	10.5	%
— CO	219	NA	249	ppm
— NO _x	168	NA	NA	ppm
— SO ₂	187	107	17	ppm
— HCl	416	15	21	ppm
— THC	10.8	NA	8.6	ppm
TRACE ORGANICS				
— PCDD	181	NA	0.347	ng/Sm ³
— PCDF	611	NA	0.285	ng/Sm ³
— PCB	42	NA	27	ng/Sm ³
— CB	6,159	NA	294	ng/Sm ³
— CP	20,798	NA	192	ng/Sm ³
— PAH	47,066	NA	3,686	ng/Sm ³
PARTICULATE	4,313	NA	5.60	mg/Sm ³
TRACE METALS				
— Sb	79	NA	ND	µg/Sm ³
— As	214	NA	ND	µg/Sm ³
— Cd	594	NA	ND	µg/Sm ³
— Cr	579	NA	6.3	µg/Sm ³
— Cu	1,908	NA	ND	µg/Sm ³
— Pb	11,479	NA	43	µg/Sm ³
— Hg	622	NA	19.6	µg/Sm ³
— Ni	466	NA	5.0	µg/Sm ³
— Zn	42,014	NA	ND	µg/Sm ³

* Corrected to 12% CO₂.




ASH	FABRIC * FILTER ASH	
ASH RATE (dry)	2,140	kg/h
TRACE ORGANICS		
— PCDD	49	ng/g
— PCDF	100	ng/g
— PCB	ND	ng/g
— CB	704	ng/g
— CP	2,225	ng/g
— PAH	1,087	ng/g
TRACE METALS		
— Sb	10	µg/g
— As	16	µg/g
— Cd	97	µg/g
— Cr	240	µg/g
— Cu	679	µg/g
— Pb	2,405	µg/g
— Hg	30	µg/g
— Ni	439	µg/g
— Zn	6,687	µg/g

* PT 11 only

APC SYSTEM OPERATING CONDITIONS			
RUN	PT04		
FFO SO ₂ SET POINT	MEDIUM		
SDO TEMP. SET POINT	185		°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	154,509	NA	185,970	Sm ³ /h
— TEMPERATURE	191	188	142	°C
— MOISTURE	14.6	NA	14.9	%
CONTINUOUS MONITORS				
— O ₂	7.6	NA	8.3	%
— CO ₂	11.9	11.0	11.0	%
— CO	214	NA	168	ppm
— NO _x	172	NA	NA	ppm
— SO ₂	186	NA	44	ppm
— HCl	471	45	31	ppm
— THC	7.7	NA	6.1	ppm
TRACE ORGANICS				
— PCDD	151	NA	0.368	ng/Sm ³
— PCDF	623	NA	0.486	ng/Sm ³
— PCB	ND	NA	19	ng/Sm ³
— CB	8,964	NA	93	ng/Sm ³
— CP	16,964	NA	167	ng/Sm ³
— PAH	22,519	NA	1,983	ng/Sm ³
PARTICULATE	3,274.3	NA	7.62	mg/Sm ³
TRACE METALS				
— Sb	80	NA	ND	µg/Sm ³
— As	168	NA	ND	µg/Sm ³
— Cd	636	NA	ND	µg/Sm ³
— Cr	638	NA	10.0	µg/Sm ³
— Cu	1,289	NA	ND	µg/Sm ³
— Pb	10,050	NA	37	µg/Sm ³
— Hg	814	NA	13.4	µg/Sm ³
— Ni	686	NA	8.0	µg/Sm ³
— Zn	31,654	NA	48	µg/Sm ³

* Corrected to 12% CO₂.




ASH	FABRIC FILTER ASH	
ASH RATE (dry)	1,385	kg/h
TRACE ORGANICS		
— PCDD	84	ng/g
— PCDF	172	ng/g
— PCB	ND	ng/g
— CB	1,059	ng/g
— CP	3,320	ng/g
— PAH	1,806	ng/g
TRACE METALS		
— Sb	8.6	µg/g
— As	20	µg/g
— Cd	96	µg/g
— Cr	179	µg/g
— Cu	388	µg/g
— Pb	3,413	µg/g
— Hg	48	µg/g
— Ni	229	µg/g
— Zn	6,467	µg/g

APC SYSTEM OPERATING CONDITIONS			
RUN	PT09		
FFO SO ₂ SET POINT	HIGH		
SDO TEMP. SET POINT	185		°C

FLUE GAS	SPRAY DRYER INLET	SPRAY DRYER OUTLET	FABRIC FILTER OUTLET	
GAS				
— FLOW	146,255	NA	163,144	Sm ³ /h
— TEMPERATURE	191	170	140	°C
— MOISTURE	17.5	NA	15.3	%
CONTINUOUS MONITORS				
— O ₂	7.6	NA	9.7	%
— CO ₂	11.9	11.1	10.4	%
— CO	92	NA	72	ppm
— NO _x	188	NA	NA	ppm
— SO ₂	178	159	189	ppm
— HCl	432	146	96	ppm
— THC	5.4	NA	8.5	ppm
TRACE ORGANICS				
— PCDD	71	NA	0.582	ng/Sm ³
— PCDF	378	NA	0.495	ng/Sm ³
— PCB	6	NA	14	ng/Sm ³
— CB	4,848	NA	113	ng/Sm ³
— CP	11,329	NA	391	ng/Sm ³
— PAH	32,421	NA	2,438	ng/Sm ³
PARTICULATE	3,893.7	NA	6.79	mg/Sm ³
TRACE METALS				
— Sb	159	NA	ND	µg/Sm ³
— As	196	NA	ND	µg/Sm ³
— Cd	868	NA	ND	µg/Sm ³
— Cr	1,491	NA	11.1	µg/Sm ³
— Cu	3,219	NA	ND	µg/Sm ³
— Pb	2,592	NA	39	µg/Sm ³
— Hg	644	NA	14.1	µg/Sm ³
— Ni	1,574	NA	8.2	µg/Sm ³
— Zn	46,159	NA	ND	µg/Sm ³

* Corrected to 12% CO₂.



ASH	FABRIC FILTER ASH	
ASH RATE (dry)	1,317	Kg/h
TRACE ORGANICS		
— PCDD	112	ng/g
— PCDF	222	ng/g
— PCB	ND	ng/g
— CB	1,266	ng/g
— CP	4,336	ng/g
— PAH	4,780	ng/g
TRACE METALS		
— Sb	13	µg/g
— As	21	µg/g
— Cd	119	µg/g
— Cr	287	µg/g
— Cu	632	µg/g
— Pb	4,545	µg/g
— Hg	37	µg/g
— Ni	415	µg/g
— Zn	8,497	µg/g

Appendix D

Symbols and Abbreviations

SI Prefixes			
Prefix	Symbol	Multiplication Factor	Exponent
mega	M	1 000 000	= 10 ⁶
kilo	k	1 000	= 10 ³
hecto	h	100	= 10 ²
deca	da	10	= 10 ¹
unit	-	1	= 10 ⁰
deci	d	0.1	= 10 ⁻¹
centi	c	0.01	= 10 ⁻²
milli	m	0.001	= 10 ⁻³
micro	μ	0.000 001	= 10 ⁻⁶
nano	n	0.000 000 001	= 10 ⁻⁹
pico	p	0.000 000 000 001	= 10 ⁻¹²
Units			
Symbol	Unit	Comments	
Mass/Weight			
g	gram	-	
tonne	metric tonne	1 tonne = 1 Mg	
lb	pound	1 pound = 453.592 g	
Length			
m	metre	-	
ft	foot	1 ft = 0.3048 m	
Volume			
L	litre	-	
m ³	cubic metre	1 m ³ = 1000 L	
Sm ³	standard cubic metre	at standard conditions 25°C and 101.325 kPa	
cm ³	cubic centimetre		
ft ³ or cf	cubic foot	1 ft ³ = 0.02832 m ³	
Time			
s	second	-	
m (min)	minute	1 min = 60 s	
h (h)	hour	1 h = 3600 s	
Temperature			
°C	degree Celsius	°C = 5/9 (°F - 32)	
°F	degree Fahrenheit	°F = 9/5 (°C + 32)	
Pressure			
bar	bar	-	
Pa	pascal	1 Pa = 10 ⁻⁵ bar	
psig	pounds/square inch gauge	1 psig = 6.894 kPa	

Sampling and Analytical Terminology	
XAD-2	Amberlite Resin used to absorb organics
GC	Gas Chromatography
MS	Mass Spectrometry
ECD	Electron Capture Detector
MID	Multiple Ion Detection
MM5	Modified Method 5
CT	Characterization Test
PT	Performance Test
QA/QC	Quality Assurance/Quality Control
Compounds	
PCDD	Polychlorinated Dibenzo- <i>para</i> -dioxins
PCDF	Polychlorinated Dibenzofurans
PCB	Polychlorinated Biphenyls
PAH	Polycyclic Aromatic Hydrocarbons
THC	Total Hydrocarbons
TOX	Total Organic Halides
CP	Chlorophenols
CB	Chlorobenzenes
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
O ₂	Oxygen
SO ₂	Sulphur Dioxide
HCl	Hydrogen Chloride
TSP	Total Suspended Particulate or Particulate Matter
NaOH	Sodium Hydroxide
KMnO ₄	Potassium Permanganate
H ₂ O	Water
H ₂ SO ₄	Sulphuric Acid
HNO ₃	Nitric Acid
Na ₂ SO ₄	Sodium Sulphate
HClO ₄	Perchloric Acid
Ca(OH) ₂	Calcium Hydroxide

Metals	
Cd	Cadmium
Be	Beryllium
Mo	Molybdenum
Ca	Calcium
V	Vanadium
Al	Aluminum
Mg	Magnesium
Ba	Barium
K	Potassium
Na	Sodium
Zn	Zinc
Mn	Manganese
Co	Cobalt
Cu	Copper
Ag	Silver
Fe	Iron
Pb	Lead
Cr	Chromium
Ni	Nickel
Si	Silicon
Ti	Titanium
B	Boron
P	Phosphorus
Hg	Mercury
As	Arsenic
Sb	Antimony
Bi	Bismuth
Se	Selenium
Te	Tellurium
Sn	Tin
Miscellaneous	
ND	Not Detected
ppm	part per million
°	Degree (angle or temperature)
±	plus or minus
<	less than
>	greater than
ID	Induced Draft (fan)
d	dry
S	standardized gas conditions

Acronyms

AA	atomic absorption
ANC	acid neutralization capacity
APC	air pollution control
API	air preheater inlet
APO	air preheater outlet
BA	bottom ash
CEM	continuous emissions monitoring
DAS	Data Acquisition System
EFW	energy-from-waste
FF	fabric filter
FFA	fabric filter ash
FFO	fabric filter outlet
FID	flame ionization detection
GFC	gas filter correlation
GS	grate siftings
ICP	inductively coupled plasma
LOI	loss-on-ignition
MS	mass spectrometry
MWC	municipal waste combustion
NDUV	nondispersive ultraviolet
NDIR	nondispersive infrared
OFA	overfire air systems
OSR	overall stoichiometric ratio
PHI	preheater inlet

RDF refuse-derived fuel
RSR reduced stoichiometric ratio
RW-OFA rear-wall overfire air
SAS Statistical Analysis System
SBEP sequential batch extraction procedure
SCE sequential chemical extraction
SD spray dryer
SDA spray dryer atomizer
SDI spray dryer inlet
SDO spray dryer outlet
SR stoichiometric ratio
VOST volatile organic sampling train

Organizations

APHA American Public Health Association
ASME American Society of Mechanical Engineers
ASTM American Society for Testing and Materials
CARB California Air Resources Board
CE Combustion Engineering
EPA Environmental Protection Agency - United States of America
NITEP National Incinerator Testing and Evaluation Program